

WOOLSHED, Australia

WMO: 952930

Lat: 19.4167S

Lon: 146.5364E

Elev: 1826

StdP: 13.75

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	43.3	47.0	25.1	20.4	62.9	30.0	25.7	60.3	12.0	61.2	11.4	62.4	1.4	200	0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.2	87.2	70.9	84.9	71.5	83.2	71.5	77.3	80.9	76.0	79.6	75.0	78.5	8.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.4	147.4	78.3	75.1	141.3	77.4	74.1	136.2	76.4	42.4	81.4	41.0	79.8	40.0	78.4	95.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.3	13.6	11.7	DB	38.0	92.9	3.1	2.3	35.8	94.5	34.0	95.9	32.2	97.2	30.0	98.9
			WB	36.3	78.1	3.1	1.3	34.1	79.0	32.3	79.7	30.6	80.4	28.3	81.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.8	75.6	75.5	74.0	70.9	65.9	62.4	61.4	63.1	67.9	71.2	73.7	76.1 (6)
	DBStd	6.17	2.52	2.65	2.24	2.20	3.82	4.31	4.41	3.99	3.36	2.96	2.48	2.46 (7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0 (8)
	HDD65	351	0	0	0	1	35	98	123	81	12	1	0	0 (9)
	CDD50	7224	795	714	745	628	494	371	353	407	538	657	712	810 (10)
	CDD65	2097	330	294	280	178	63	19	11	23	99	193	262	345 (11)
	CDH74	8693	1601	1449	1076	443	102	19	10	43	293	712	1098	1847 (12)
	CDH80	1450	293	293	126	14	2	1	0	1	28	93	176	423 (13)
(14) Wind	WSAvg	5.9	6.4	6.1	5.7	5.5	5.0	4.5	4.4	5.0	6.2	7.4	7.6	7.0 (14)
(15) Precipitation	PrecAvg	44.2	10.3	12.8	6.8	2.5	0.9	1.0	0.7	0.7	0.5	0.9	2.5	4.5 (15)
	PrecMax	86.8	33.0	35.0	26.3	12.3	3.9	5.1	4.4	8.0	3.2	3.7	12.4	15.6 (16)
	PrecMin	19.7	0.3	0.9	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2 (17)
	PrecStd	20.7	8.3	9.4	7.9	3.8	1.0	1.1	1.1	1.6	0.8	1.0	3.1	4.1 (18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	91.6	85.7	81.9	79.4	76.4	75.3	77.5	83.2	86.4	87.9	89.2 (19)
		MCWB	73.7	69.4	71.2	67.0	66.4	64.3	61.8	62.1	62.4	62.5	65.8	72.1 (20)
	2%	DB	85.1	86.7	83.0	79.7	76.8	73.6	72.6	75.0	79.7	82.3	84.1	86.3 (21)
		MCWB	73.6	71.9	71.9	67.7	64.9	63.1	61.4	61.2	63.5	67.3	69.8	72.0 (22)
	5%	DB	83.1	83.2	81.2	78.3	74.6	71.7	70.8	72.9	77.3	80.0	81.8	84.1 (23)
		MCWB	73.0	72.8	71.2	67.6	63.7	61.6	60.4	60.6	63.9	67.5	69.1	72.7 (24)
	10%	DB	81.3	81.3	79.4	76.8	72.6	69.7	69.1	70.8	75.0	78.1	80.0	82.4 (25)
		MCWB	72.5	73.0	70.9	67.5	63.1	61.4	59.8	59.6	63.1	66.3	68.4	71.8 (26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.3	78.6	76.6	74.0	71.0	69.3	68.1	67.3	70.4	73.0	74.8	81.7 (27)
		MCDB	82.0	81.5	80.6	75.5	74.4	70.9	69.4	71.5	75.5	78.7	78.8	82.6 (28)
	2%	WB	76.5	77.1	75.0	71.9	69.2	67.1	65.6	65.6	68.8	71.7	73.4	77.2 (29)
		MCDB	80.2	80.3	79.0	75.1	71.9	70.1	69.1	69.3	73.0	75.6	77.9	81.5 (30)
	5%	WB	75.4	76.0	74.1	70.7	67.6	65.6	64.4	64.4	67.5	70.2	72.1	75.3 (31)
		MCDB	79.2	79.0	77.6	74.3	70.8	68.3	67.3	68.2	71.5	74.7	76.5	79.1 (32)
	10%	WB	74.5	74.8	73.2	69.7	66.2	64.1	63.0	63.0	66.5	68.9	71.1	73.9 (33)
		MCDB	78.0	77.8	76.4	73.4	69.8	67.1	66.1	67.1	70.4	73.8	75.4	77.8 (34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.0	11.4	12.5	14.2	15.6	16.5	16.8	15.4	14.9	13.4	13.2 (35)
		MCDBR	14.3	15.7	14.2	15.0	16.4	16.7	17.5	18.2	18.2	17.2	15.8	15.4 (36)
	5% WB	MCWBR	5.4	6.1	5.8	6.0	7.2	7.8	8.2	7.3	6.7	5.6	4.9	6.1 (37)
		MCWBR	11.7	11.6	11.1	10.7	11.3	10.6	11.6	12.8	13.3	14.5	13.2	13.6 (38)
(40) Clear-Sky Solar Irradiance	taub		0.374	0.369	0.351	0.335	0.322	0.309	0.298	0.310	0.339	0.359	0.364	0.376 (40)
		taud	2.558	2.580	2.619	2.644	2.629	2.653	2.679	2.619	2.523	2.492	2.519	2.513 (41)
	Ebn at Noon		308	306	304	297	290	288	295	301	303	305	309	307 (42)
		Edh at Noon	35	33	31	28	27	25	25	28	34	36	36	36 (43)
(44) All-Sky Solar Radiation	RadAvg		1989	1913	1788	1613	1376	1234	1386	1667	1988	2187	2208	2184 (44)
	RadStd		183	224	177	151	109	112	109	120	132	145	246	221 (45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page