

WOOLSHED, Australia

WMO: 952930

Lat: 19.4167S

Lon: 146.5364E

Elev: 557

StdP: 94.82

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	8.3	-3.8	2.9	17.2	-1.1	3.7	15.7	5.4	16.2	5.1	16.9	0.6	200	0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.3	30.6	21.6	29.4	21.9	28.4	22.0	25.1	27.2	24.5	26.5	23.9	25.8	3.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	21.1	25.7	24.0	20.2	25.2	23.4	19.5	24.7	80.6	27.4	77.5	26.6	75.2	25.8	35.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.1	5.2	DB	3.3	33.8	1.7	1.3	2.1	34.7	1.1	35.5	0.1	36.2	-1.1	37.2	(4)
(5)			WB	2.4	25.6	1.7	0.7	1.2	26.1	0.2	26.5	-0.8	26.9	-2.0	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	24.2	24.2	23.4	21.6	18.8	16.9	16.3	17.3	20.0	21.8	23.2	24.5	(6)	
	DBStd	3.43	1.40	1.47	1.25	1.22	2.12	2.40	2.45	2.21	1.87	1.64	1.38	1.37	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	195	0	0	0	1	19	54	68	45	7	1	0	0	(9)	
	CDD10.0	4013	442	397	414	349	274	206	196	226	299	365	396	450	(10)	
	CDD18.3	1165	183	163	156	99	35	11	6	13	55	107	146	192	(11)	
	CDH23.3	4829	889	805	598	246	57	11	6	24	163	396	610	1026	(12)	
(13)	CDH26.7	806	163	163	70	8	1	1	0	1	16	52	98	235	(13)	
(14)	Wind	WSAvg	2.6	2.9	2.7	2.5	2.5	2.2	2.0	2.0	2.2	2.8	3.3	3.4	3.2	(14)
(15) Precipitation	PrecAvg	1123	262	325	172	63	24	26	19	19	13	22	63	114	(15)	
	PrecMax	2205	839	890	667	313	99	130	113	203	81	93	314	395	(16)	
	PrecMin	501	8	22	10	0	1	0	0	0	0	0	0	6	(17)	
	PrecStd	526	210	238	200	96	25	28	29	41	20	25	78	104	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	33.1	29.8	27.7	26.4	24.7	24.0	25.3	28.5	30.2	31.1	31.8	(19)	
		MCWB	23.1	20.8	21.8	19.4	19.1	17.9	16.5	16.7	16.9	17.0	18.8	22.3	(20)	
	2%	DB	29.5	30.4	28.4	26.5	24.9	23.1	22.5	23.9	26.5	27.9	29.0	30.2	(21)	
		MCWB	23.1	22.2	22.1	19.8	18.3	17.3	16.3	16.2	17.5	19.6	21.0	22.2	(22)	
	5%	DB	28.4	28.5	27.3	25.7	23.7	22.0	21.6	22.7	25.2	26.7	27.7	29.0	(23)	
		MCWB	22.8	22.7	21.8	19.8	17.6	16.5	15.8	15.9	17.7	19.7	20.6	22.6	(24)	
	10%	DB	27.4	27.4	26.3	24.9	22.5	21.0	20.6	21.6	23.9	25.6	26.6	28.0	(25)	
		MCWB	22.5	22.8	21.6	19.7	17.3	16.3	15.5	15.3	17.3	19.1	20.2	22.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	25.9	24.8	23.3	21.7	20.7	20.1	19.6	21.3	22.8	23.8	27.6	(27)	
		MCDB	27.8	27.5	27.0	24.2	23.6	21.6	20.8	22.0	24.2	25.9	26.0	28.1	(28)	
	2%	WB	24.7	25.0	23.9	22.2	20.7	19.5	18.7	18.7	20.4	22.0	23.0	25.1	(29)	
		MCDB	26.8	26.8	26.1	23.9	22.2	21.2	20.6	20.7	22.8	24.2	25.5	27.5	(30)	
	5%	WB	24.1	24.4	23.4	21.5	19.8	18.7	18.0	18.0	19.7	21.2	22.3	24.1	(31)	
		MCDB	26.2	26.1	25.4	23.5	21.6	20.2	19.6	20.1	21.9	23.7	24.7	26.2	(32)	
	10%	WB	23.6	23.8	22.9	20.9	19.0	17.8	17.2	17.2	19.1	20.5	21.7	23.3	(33)	
		MCDB	25.6	25.4	24.7	23.0	21.0	19.5	19.0	19.5	21.3	23.2	24.1	25.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	6.3	7.0	7.9	8.6	9.2	9.3	8.5	8.3	7.5	7.3	(35)	
		MCDBR	7.9	8.7	7.9	8.4	9.1	9.3	9.7	10.1	10.1	9.6	8.8	8.6	(36)	
	5% WB	MCWBR	3.0	3.4	3.2	3.3	4.0	4.3	4.5	4.0	3.7	3.1	2.7	3.4	(37)	
		MCWBR	6.5	6.5	6.2	5.9	6.3	5.9	6.5	7.1	7.4	8.1	7.3	7.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.374	0.369	0.351	0.335	0.322	0.309	0.298	0.310	0.339	0.359	0.364	0.376	(40)	
		taud	2.558	2.580	2.619	2.644	2.629	2.653	2.679	2.619	2.523	2.492	2.519	2.513	(41)	
	Ebn at Noon	Ebn at Noon	970	964	958	936	913	908	931	948	955	962	973	968	(42)	
		Edh at Noon	109	105	98	89	84	79	78	89	106	114	113	114	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.27	6.03	5.64	5.09	4.34	3.89	4.37	5.25	6.27	6.89	6.96	6.88	(44)	
	RadStd	RadStd	0.58	0.70	0.56	0.48	0.34	0.35	0.34	0.38	0.42	0.46	0.78	0.70	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)	

Nomenclature: See separate page