

BARROW ISLAND AP, Australia

WMO: 953040

Lat: 20.874S

Lon: 115.406E

Elev: 23

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 61.4	(c) 63.0	(d) 42.5	(e) 40.1	(f) 68.4	(g) 44.7	(h) 43.7	(i) 69.1	(j) 31.6	(k) 68.1	(l) 29.8	(m) 68.0	(n) 6.4	(o) 10	(p) 0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.0	95.7	76.6	93.5	76.9	91.6	77.1	81.4	88.5	80.6	88.0	79.8	87.4	14.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	153.0	85.4	78.5	147.9	85.5	77.7	143.9	85.2	45.1	89.2	44.2	88.1	43.5	87.5	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.1	30.6	27.0	DB	57.4	101.8	1.5	3.3	56.4	104.1	55.5	106.0	54.7	107.9	53.7	110.2
			WB	49.9	83.1	2.0	1.1	48.5	83.9	47.3	84.5	46.2	85.1	44.8	85.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.9	84.2	84.9	85.6	82.2	76.1	70.9	69.0	70.2	73.4	77.5	79.6	82.1	(6)
	DBStd	6.50	3.42	3.15	2.76	2.83	3.05	2.91	2.53	2.34	2.72	3.45	3.44	3.69	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	5	0	0	0	0	0	1	3	1	0	0	0	0	(9)
	CDD50	10195	1060	976	1103	966	808	627	589	628	703	853	887	995	(10)
	CDD65	4724	595	556	638	516	343	177	127	164	253	388	437	530	(11)
	CDH74	43162	6983	6801	8246	5837	2203	309	92	308	918	2577	3534	5354	(12)
	CDH80	15909	2933	3002	3890	2097	339	8	1	10	116	598	975	1940	(13)
(14) Wind	WSAvg	14.9	16.8	15.2	13.8	12.5	13.1	14.6	13.0	13.1	15.1	16.9	17.8	17.2	(14)
(15) Precipitation	PrecAvg	13.1	1.0	2.2	2.4	0.9	1.9	2.6	0.7	0.3	0.2	0.0	0.0	0.5	(15)
	PrecMax	29.4	7.9	12.4	9.7	5.2	9.6	11.3	4.1	1.7	1.0	0.3	0.8	7.9	(16)
	PrecMin	5.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	6.2	2.0	2.8	2.7	1.3	2.7	3.4	0.9	0.5	0.3	0.1	0.2	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.7	97.9	97.2	92.9	87.0	80.9	78.3	81.3	86.9	91.2	94.5	96.8	(19)
		MCWB	77.6	77.5	77.1	74.6	72.1	70.0	67.0	66.7	67.2	69.9	71.8	75.3	(20)
	2%	DB	94.8	94.8	94.2	90.7	85.1	78.4	76.2	78.6	83.0	87.7	90.2	93.2	(21)
		MCWB	77.6	77.7	77.6	74.7	71.6	68.6	65.7	66.4	66.9	70.3	72.3	75.8	(22)
	5%	DB	92.1	92.2	92.1	89.1	83.5	77.1	74.8	77.0	80.7	85.5	87.4	90.5	(23)
		MCWB	77.9	78.3	78.0	74.1	71.2	67.6	65.4	65.5	67.1	70.6	72.8	75.8	(24)
	10%	DB	89.9	90.1	90.5	87.7	81.8	75.7	73.7	75.6	78.7	83.3	85.2	88.1	(25)
		MCWB	77.9	78.4	77.9	74.2	70.6	66.6	64.6	64.6	66.5	70.4	72.8	75.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	82.5	82.7	80.5	76.5	74.6	71.5	71.1	72.4	75.4	77.4	80.7	(27)
		MCDB	89.0	89.0	88.4	87.9	81.2	77.6	75.1	77.0	79.7	83.6	85.6	89.1	(28)
	2%	WB	80.8	81.3	81.3	78.9	75.5	72.5	69.4	69.3	70.9	74.0	76.1	79.4	(29)
		MCDB	88.1	88.4	88.4	85.7	80.9	76.2	73.1	74.9	77.7	82.2	84.4	87.6	(30)
	5%	WB	79.9	80.5	80.3	77.8	74.2	70.7	68.2	68.0	69.7	72.9	75.1	78.3	(31)
		MCDB	87.4	87.9	87.9	84.9	80.4	74.9	72.3	74.1	76.4	81.1	83.3	86.5	(32)
	10%	WB	79.1	79.7	79.5	76.9	72.8	69.2	66.8	66.8	68.7	71.9	74.1	77.1	(33)
		MCDB	86.8	87.2	87.2	84.3	79.7	74.0	71.8	73.2	75.8	80.2	82.2	85.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.7	10.0	10.2	9.3	8.1	9.2	11.1	11.4	11.5	11.1	11.3	(35)
		MCDBR	14.0	13.7	12.5	12.0	11.6	9.1	10.3	12.9	14.7	13.9	14.0	14.6	(36)
	5% WB	MCWBR	4.7	5.0	4.8	6.2	6.7	6.5	6.5	6.8	6.5	5.6	5.1	4.8	(37)
		MCWBR	11.8	11.6	11.0	10.7	10.4	8.1	9.5	12.3	13.1	12.6	12.5	12.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.401	0.397	0.375	0.354	0.334	0.325	0.316	0.317	0.334	0.352	0.356	0.373	(40)
		taud	2.536	2.564	2.619	2.639	2.637	2.649	2.651	2.612	2.557	2.531	2.550	2.570	(41)
	Ebn at Noon		300	297	296	290	284	281	287	298	304	307	311	308	(42)
		Edh at Noon	36	34	31	28	26	25	25	28	32	35	35	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2431	2325	2066	1758	1464	1316	1432	1781	2118	2401	2574	2591	(44)
	RadStd		130	148	135	112	117	97	101	55	78	49	59	92	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page