

BARROW ISLAND AP, Australia

WMO: 953040

Lat: 20.874S

Lon: 115.406E

Elev: 7

StdP: 101.24

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	17.2	5.8	5.7	20.2	7.1	6.2	20.6	14.1	20.1	13.3	20.0	2.9	10	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.5	35.4	24.8	34.2	25.0	33.1	25.1	27.4	31.4	27.0	31.1	26.6	30.8	6.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.4	21.9	29.6	25.8	21.1	29.7	25.4	20.6	29.6	87.1	31.8	85.0	31.2	83.3	30.8	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	13.7	12.1	14.1	38.8	0.8	1.8	13.6	40.1	13.1	41.1	12.6	42.1	12.0	43.5
			10.0	28.4	1.1	0.6	9.2	28.8	8.5	29.2	7.9	29.5	7.1	30.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	29.0	29.4	29.8	27.9	24.5	21.6	20.6	21.2	23.0	25.3	26.4	27.8
	DBStd	3.61	1.90	1.75	1.53	1.57	1.69	1.62	1.40	1.30	1.51	1.92	1.91	2.05
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	0	0	0	0	0	1	2	1	0	0	0	0
	CDD10.0	5664	589	542	613	537	449	348	327	349	391	474	493	553
	CDD18.3	2624	331	309	354	287	191	98	71	91	141	216	243	294
	CDH23.3	23979	3879	3778	4581	3243	1224	172	51	171	510	1432	1963	2974
	CDH26.7	8838	1629	1668	2161	1165	188	4	1	6	64	332	542	1078
Wind	WSAvg	6.7	7.5	6.8	6.2	5.6	5.8	6.5	5.8	5.8	6.7	7.6	7.9	7.7
Precipitation	PrecAvg	332	25	55	61	22	49	65	17	8	4	1	1	12
	PrecMax	747	200	316	246	131	244	288	104	42	25	8	20	201
	PrecMin	137	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	157	52	71	69	34	69	87	22	13	7	2	4	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	36.6	36.2	33.9	30.5	27.2	25.7	27.4	30.5	32.9	34.7	36.0
		MCWB	25.3	25.3	25.0	23.7	22.3	21.1	19.4	19.3	19.5	21.1	22.1	24.0
	2%	DB	34.9	34.9	34.6	32.6	29.5	25.8	24.5	25.9	28.4	31.0	32.3	34.0
		MCWB	25.3	25.4	25.3	23.7	22.0	20.4	18.7	19.1	19.4	21.3	22.4	24.3
	5%	DB	33.4	33.4	33.4	31.7	28.6	25.0	23.8	25.0	27.1	29.7	30.8	32.5
		MCWB	25.5	25.7	25.5	23.4	21.8	19.8	18.6	18.6	19.5	21.5	22.6	24.3
	10%	DB	32.2	32.3	32.5	30.9	27.7	24.3	23.2	24.2	25.9	28.5	29.5	31.2
		MCWB	25.5	25.8	25.5	23.4	21.4	19.2	18.1	18.1	19.2	21.3	22.6	24.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.1	28.2	26.9	24.7	23.7	21.9	21.7	22.4	24.1	25.2	27.1
		MCDB	31.7	31.6	31.3	31.1	27.3	25.3	24.0	25.0	26.5	28.7	29.8	31.7
	2%	WB	27.1	27.4	27.4	26.1	24.1	22.5	20.8	20.7	21.6	23.3	24.5	26.3
		MCDB	31.1	31.3	31.3	29.8	27.2	24.5	22.9	23.8	25.4	27.9	29.1	30.9
	5%	WB	26.6	26.9	26.8	25.4	23.5	21.5	20.1	20.0	21.0	22.7	23.9	25.7
		MCDB	30.8	31.1	31.0	29.4	26.9	23.8	22.4	23.4	24.7	27.3	28.5	30.3
	10%	WB	26.1	26.5	26.4	24.9	22.7	20.7	19.3	19.4	20.4	22.2	23.4	25.1
		MCDB	30.5	30.7	30.6	29.0	26.5	23.4	22.1	22.9	24.3	26.8	27.9	29.6
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.9	5.5	5.7	5.2	4.5	5.1	6.2	6.4	6.4	6.2	6.3
		MCDBR	7.8	7.6	6.9	6.7	6.4	5.1	5.7	7.2	8.2	7.7	7.8	8.1
		MCWBR	2.6	2.8	2.7	3.5	3.7	3.6	3.6	3.8	3.6	3.1	2.8	2.7
	5% WB	MCDBR	6.6	6.4	6.1	5.9	5.8	4.5	5.3	6.8	7.3	7.0	7.0	7.2
		MCWBR	2.6	2.7	2.7	3.3	3.7	3.4	3.7	4.1	3.7	3.1	2.7	2.8
Clear-Sky Solar Irradiance	taub	0.401	0.397	0.375	0.354	0.334	0.325	0.316	0.317	0.334	0.352	0.356	0.373	
	taud	2.536	2.564	2.619	2.639	2.637	2.649	2.651	2.612	2.557	2.531	2.550	2.570	
	Ebn at Noon	945	936	933	914	895	886	906	938	958	968	981	972	
	Edh at Noon	112	107	97	89	82	78	80	89	102	109	109	108	
All-Sky Solar Radiation	RadAvg	7.67	7.33	6.51	5.54	4.62	4.15	4.51	5.61	6.68	7.57	8.11	8.17	
	RadStd	0.41	0.47	0.43	0.35	0.37	0.31	0.32	0.17	0.25	0.16	0.19	0.29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page