

ONSLOW AP, Australia

WMO: 953050

Lat: 21.669S

Lon: 115.109E

Elev: 11

StdP: 101.19

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	13.2	-2.2	3.1	25.1	-0.4	3.7	24.2	10.6	20.7	9.7	21.4	4.0	150	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.2	40.8	21.5	38.8	21.9	37.2	22.3	27.2	32.5	26.7	32.0	26.2	31.5	6.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.2	30.2	25.3	20.4	29.9	24.8	19.9	29.6	86.2	32.6	84.0	31.9	81.9	31.6	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	11.0	9.9	DB	9.9	46.1	0.9	1.3	9.2	47.0	8.7	47.7	8.2	48.5	7.5	49.4	(4)
(5)			WB	6.1	28.2	0.8	0.6	5.5	28.6	5.0	28.9	4.5	29.2	3.9	29.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	30.3	30.4	30.5	28.4	24.0	20.7	19.9	21.0	22.9	25.8	27.1	28.8	(6)	
	DBStd	4.46	2.68	2.38	2.18	2.16	2.18	2.01	1.79	1.83	1.92	2.74	2.59	2.81	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	11	0	0	0	0	0	3	6	2	0	0	0	0	(9)	
	CDD10.0	5767	628	572	634	552	435	321	307	342	388	491	513	583	(10)	
	CDD18.3	2736	369	339	376	302	177	74	54	86	138	233	263	324	(11)	
	CDH23.3	30553	4852	4507	4971	3386	1337	374	313	590	1119	2369	2821	3913	(12)	
	CDH26.7	14988	2616	2434	2687	1653	465	52	43	127	382	1141	1360	2028	(13)	
(14) Wind	WSAvg	5.6	6.7	6.2	5.7	4.9	4.5	4.6	4.6	4.8	5.6	6.4	6.7	6.8	(14)	
(15) Precipitation	PrecAvg	287	26	74	50	18	45	49	13	8	2	1	1	1	(15)	
	PrecMax	998	144	545	369	117	229	227	90	60	25	27	23	19	(16)	
	PrecMin	75	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	200	37	131	82	27	54	58	19	14	4	5	4	4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.5	43.1	41.7	38.9	35.0	29.8	29.6	31.8	35.1	39.7	40.5	42.3	(19)	
		MCWB	21.1	21.6	22.0	20.3	19.5	18.1	16.4	16.2	17.9	18.7	19.6	20.7	(20)	
	2%	DB	40.1	39.2	39.0	36.9	32.3	28.2	27.8	29.5	32.3	36.7	37.5	39.0	(21)	
		MCWB	22.3	23.4	22.8	21.0	19.1	17.1	16.0	16.6	17.3	18.6	19.7	21.1	(22)	
	5%	DB	37.4	36.9	36.9	35.3	30.7	26.9	26.3	28.0	30.4	34.4	35.1	36.6	(23)	
		MCWB	23.6	24.1	23.3	21.1	18.8	16.6	15.8	16.2	17.2	19.0	20.2	22.0	(24)	
	10%	DB	35.2	35.1	35.2	33.7	29.3	25.6	25.1	26.6	28.8	32.5	32.9	34.5	(25)	
		MCWB	24.3	24.7	23.9	21.4	19.0	16.7	15.8	16.3	17.0	18.8	20.5	22.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.2	27.5	26.3	24.7	23.0	21.6	21.4	21.9	23.3	25.1	27.2	(27)	
		MCDB	33.6	33.5	32.5	31.1	27.2	25.0	24.0	24.7	27.1	29.0	30.1	31.8	(28)	
	2%	WB	27.0	27.2	26.7	25.3	23.1	21.6	20.1	20.2	20.8	22.4	24.3	26.2	(29)	
		MCDB	32.9	32.6	31.8	29.8	26.8	23.7	22.9	24.1	26.1	28.7	29.7	31.2	(30)	
	5%	WB	26.5	26.7	26.2	24.6	22.0	20.5	18.8	19.2	20.0	21.7	23.5	25.3	(31)	
		MCDB	32.1	32.1	31.5	29.4	26.3	23.2	22.2	23.6	25.7	28.4	29.5	31.0	(32)	
	10%	WB	26.0	26.2	25.7	24.0	21.1	19.3	17.7	18.3	19.2	20.9	22.7	24.5	(33)	
		MCDB	31.4	31.5	31.2	29.4	25.8	22.8	21.9	23.2	24.8	27.9	29.2	30.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.2	9.8	11.0	10.9	10.3	11.2	12.3	12.7	12.9	11.5	10.6	(35)	
		MCDBR	13.9	12.5	12.4	12.8	12.6	11.6	12.9	14.0	14.9	15.6	14.7	14.3	(36)	
	5% WB	MCWBR	4.9	4.6	4.9	5.0	5.2	5.0	5.7	5.9	6.0	5.4	5.3	5.0	(37)	
		MCWBR	8.9	8.8	9.3	10.0	10.0	7.5	9.3	11.6	12.2	12.2	10.6	9.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.393	0.394	0.374	0.352	0.330	0.321	0.314	0.317	0.328	0.345	0.351	0.367	(40)	
		taud	2.512	2.525	2.570	2.594	2.596	2.606	2.605	2.558	2.519	2.493	2.510	2.531	(41)	
	Ebn at Noon		952	938	932	913	896	886	905	936	962	974	986	978	(42)	
		Edh at Noon	114	111	102	92	85	81	83	94	105	113	114	112	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.72	7.30	6.44	5.43	4.54	4.06	4.38	5.47	6.56	7.49	8.08	8.18	(44)	
	RadStd		0.37	0.41	0.40	0.30	0.33	0.28	0.33	0.18	0.21	0.20	0.22	0.34	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.31	N/A	-1.02	N/A	N/A	N/A	N/A	N/A	+153	+160

Nomenclature: See separate page