

RABBIT FLAT, Australia

WMO: 953220

Lat: 20.1825S

Lon: 130.0147E

Elev: 1120

StdP: 14.11

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.2	41.1	3.2	6.8	76.7	7.9	8.6	76.0	16.8	72.2	16.0	71.9	2.6	180	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	107.6	67.2	105.6	67.1	103.7	67.2	78.1	87.4	77.0	86.0	76.2	85.4	9.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.2	142.6	81.0	75.1	137.1	80.1	74.1	132.5	80.0	42.6	87.5	41.5	85.7	40.6	85.2	93.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.1	17.3	15.5	32.9	110.8	2.4	2.2	31.1	112.3	29.7	113.6	28.3	114.8	26.6	116.4		
			29.6	84.3	2.2	5.1	28.1	88.0	26.8	90.9	25.6	93.8	24.0	97.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	88.1	86.7	84.8	78.9	69.3	62.4	62.1	65.7	75.3	81.8	85.9	88.0	
	DBStd	11.06	4.49	4.25	4.17	5.09	5.50	5.94	5.59	6.37	6.52	5.55	4.57	4.71	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	342	0	0	0	0	23	121	125	68	5	0	0	0	
	CDD50	9986	1182	1028	1078	867	597	372	374	488	760	985	1078	1177	
	CDD65	4854	717	608	613	418	155	43	35	91	314	520	628	712	
	CDH74	71087	10471	8592	8382	5566	2080	715	899	1941	4886	7839	9250	10466	
	CDH80	42326	6569	5246	4992	3174	834	190	228	783	2774	4967	5909	6660	
Wind	WSAvg	6.9	7.7	7.0	7.2	6.6	6.2	6.1	5.6	6.4	6.9	7.6	7.6	7.7	
Precipitation	PrecAvg	17.6	3.9	4.3	1.4	0.8	0.6	0.4	0.2	0.1	0.4	0.7	1.3	2.4	
	PrecMax	33.3	12.8	16.1	10.4	5.5	3.5	3.4	2.5	1.3	4.4	3.1	4.0	8.2	
	PrecMin	6.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	
	PrecStd	7.2	3.4	4.0	2.2	1.4	0.9	0.9	0.5	0.3	0.9	0.9	1.1	2.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.0	107.8	106.1	101.2	93.9	89.7	88.5	94.8	100.7	106.0	107.2	111.1	
		MCWB	70.7	66.8	67.5	67.9	64.0	62.8	59.6	61.7	62.6	64.1	65.6	66.2	
	2%	DB	106.6	105.3	103.1	98.8	90.6	85.0	85.1	91.1	98.3	103.5	105.2	108.2	
		MCWB	69.2	67.8	67.9	66.5	61.9	61.4	58.2	59.5	62.0	63.6	65.8	66.4	
	5%	DB	104.0	102.9	100.6	96.8	88.0	81.4	82.6	87.9	96.1	101.7	103.4	105.2	
		MCWB	69.5	68.0	68.1	65.4	60.9	59.1	57.1	59.3	61.8	63.5	65.7	67.3	
	10%	DB	101.5	100.3	98.3	94.4	85.2	78.0	79.7	84.6	93.6	99.3	101.2	101.8	
		MCWB	69.5	68.9	67.8	64.5	60.0	56.7	55.7	56.8	60.6	63.1	66.0	68.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	78.5	79.2	78.1	72.3	68.2	67.9	66.7	69.1	72.8	76.1	78.1
			MCDB	98.7	85.1	89.6	95.4	79.7	75.3	76.8	84.2	88.1	89.7	86.7	87.0
2%		WB	78.2	77.2	77.0	73.5	69.6	64.2	62.7	63.6	66.6	70.8	73.9	76.5	
		MCDB	87.7	84.7	85.9	84.2	79.1	79.8	79.5	82.9	88.7	85.0	86.7	86.3	
5%		WB	77.2	76.4	75.7	71.3	66.7	61.6	59.4	61.2	64.7	69.5	72.7	75.6	
		MCDB	86.3	84.6	85.4	83.8	78.4	77.3	78.1	83.9	88.6	85.1	87.0	85.7	
10%		WB	76.2	75.6	74.5	68.7	63.9	59.0	56.8	58.4	62.8	68.0	71.5	74.6	
		MCDB	85.3	84.5	85.0	85.8	77.2	74.7	76.4	82.7	87.9	85.3	87.0	85.8	
Mean Daily Temperature Range	5% DB	MDBR	22.9	23.4	24.7	29.0	28.8	29.9	32.8	34.6	33.3	31.7	27.3	24.1	
		MCDBR	28.1	29.1	29.4	31.0	33.2	32.2	36.4	36.8	34.8	35.7	32.5	31.1	
		MCWBR	8.0	8.1	8.2	10.1	12.3	13.6	16.2	15.5	12.6	11.9	9.7	8.7	
	5% WB	MCDBR	19.5	18.1	20.3	24.3	21.0	26.8	29.2	30.3	27.0	24.1	23.0	20.4	
		MCWBR	6.5	5.4	7.3	10.6	8.5	12.0	13.4	13.4	10.8	8.6	6.8	5.9	
Clear-Sky Solar Irradiance	taub	0.374	0.377	0.364	0.340	0.330	0.311	0.318	0.329	0.384	0.383	0.392	0.386		
	taud	2.530	2.524	2.552	2.537	2.510	2.540	2.494	2.433	2.322	2.356	2.400	2.472		
	Ebn at Noon	308	303	299	294	285	285	286	293	288	298	300	304		
	Edh at Noon	36	35	33	31	30	28	30	34	41	41	40	38		
All-Sky Solar Radiation	RadAvg	2274	2231	2043	1886	1580	1465	1554	1867	2133	2296	2325	2256		
	RadStd	146	154	172	99	141	84	109	60	102	147	143	133		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page