

SHARK BAY AP, Australia

WMO: 954020

Lat: 25.892S

Lon: 113.577E

Elev: 113

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	47.6	49.7	27.3	21.3	77.7	31.1	25.4	75.7	21.7	67.1	19.9	66.4	7.9	120	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.7	102.5	69.8	98.9	69.8	95.4	69.8	76.7	89.7	75.4	88.2	74.2	86.7	14.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)															
73.4	124.6	82.1	71.8	117.9	81.0	70.4	112.2	80.1	40.3	90.5	39.0	88.0	37.8	86.9	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
31.2	25.0	22.6	DB	42.6	110.0	1.8	3.0	41.3	112.2	40.3	114.0	39.3	115.7	38.0	117.9	
			WB	40.2	78.0	1.8	1.5	38.9	79.1	37.8	79.9	36.8	80.7	35.5	81.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.2	81.1	82.3	81.0	75.8	69.4	63.8	61.6	63.5	66.2	70.4	74.6	77.9	(6)
	DBStd	8.31	4.77	4.89	5.06	4.53	4.04	3.30	3.21	3.29	3.74	3.88	4.56	4.95	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	282	0	0	0	0	8	60	115	70	27	2	0	0	(9)
	CDD50	8119	964	906	961	774	600	415	360	418	486	632	738	865	(10)
	CDD65	2924	499	486	496	324	143	25	9	22	64	168	288	400	(11)
	CDH74	26071	4865	5014	4949	2562	961	171	65	224	519	1141	2184	3416	(12)
	CDH80	11670	2381	2551	2467	1039	249	12	3	32	135	362	880	1559	(13)
(14) Wind	WSAvg	12.9	16.1	15.3	14.1	12.2	10.4	9.6	9.4	10.2	12.0	14.3	15.4	16.6	(14)
(15) Precipitation	PrecAvg	8.7	0.2	0.6	0.6	0.7	1.5	1.9	1.7	0.9	0.3	0.2	0.2	0.0	(15)
	PrecMax	16.8	2.5	5.7	8.2	3.6	5.4	6.3	5.9	2.9	0.9	1.8	2.0	1.2	(16)
	PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.4	0.5	1.1	1.4	0.9	1.3	1.3	1.5	0.7	0.2	0.4	0.5	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.0	107.2	104.9	98.1	90.5	81.8	79.5	84.1	89.0	94.7	100.2	104.2	(19)
		MCWB	70.3	70.2	68.7	66.1	63.0	58.8	59.5	59.2	60.5	63.2	65.3	68.0	(20)
	2%	DB	100.6	101.5	100.5	93.5	86.0	78.4	75.6	79.3	83.9	88.6	94.7	98.4	(21)
		MCWB	71.3	71.0	69.6	65.9	62.1	59.3	58.7	58.6	60.2	63.2	65.9	68.6	(22)
	5%	DB	95.6	96.8	96.4	89.8	82.4	75.7	72.9	76.1	79.8	83.6	89.2	93.0	(23)
		MCWB	71.9	72.4	69.9	66.4	62.2	59.7	58.7	58.8	60.6	63.6	66.4	69.2	(24)
	10%	DB	91.3	92.8	92.0	86.0	79.3	72.9	70.8	73.2	76.2	79.7	84.6	88.0	(25)
		MCWB	72.0	73.0	69.9	66.7	62.2	59.4	58.2	58.8	60.3	63.5	67.0	69.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.6	78.9	76.5	74.4	71.9	68.8	67.3	66.6	67.8	69.2	72.0	75.1	(27)
		MCDB	90.3	89.8	90.1	83.5	77.2	72.4	71.7	72.6	78.0	82.5	87.2	92.1	(28)
	2%	WB	76.1	77.4	75.0	72.4	69.4	66.1	64.4	64.6	65.4	67.4	70.4	73.0	(29)
		MCDB	89.0	89.9	87.6	81.4	75.5	70.7	69.9	70.9	75.4	79.6	84.0	88.2	(30)
	5%	WB	74.8	76.1	73.7	70.9	67.7	64.1	62.4	63.1	63.8	66.2	69.2	71.8	(31)
		MCDB	87.7	88.8	85.4	80.2	74.9	69.5	67.9	70.1	72.9	77.5	81.9	85.6	(32)
	10%	WB	73.5	74.7	72.6	69.7	66.0	62.5	60.6	61.6	62.3	65.0	67.9	70.5	(33)
		MCDB	86.8	87.1	84.0	79.1	73.4	68.5	66.9	69.2	71.4	75.5	80.1	82.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.6	19.7	20.1	20.2	20.8	19.3	19.6	21.0	21.1	20.3	19.7	19.6	(35)
		MCDBR	26.7	26.5	26.8	25.8	26.1	24.1	23.3	26.4	27.1	27.3	28.1	28.3	(36)
	5% WB	MCWBR	7.1	6.7	6.6	7.7	8.8	10.0	10.4	11.0	10.0	9.0	8.3	7.6	(37)
		MCWBR	20.2	19.9	19.8	19.7	18.6	16.3	18.4	21.2	21.5	20.7	21.7	21.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.363	0.369	0.351	0.330	0.310	0.304	0.297	0.301	0.318	0.328	0.336	0.343	(40)
		taud	2.576	2.586	2.616	2.655	2.677	2.674	2.690	2.655	2.578	2.562	2.564	2.585	(41)
	Ebn at Noon		311	304	300	293	287	282	289	299	306	313	317	318	(42)
		Edh at Noon	34	33	30	27	24	23	23	26	31	33	34	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2588	2413	2065	1652	1329	1136	1206	1533	1960	2327	2578	2695	(44)
	RadStd		108	76	128	85	77	56	72	57	56	65	61	93	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	-3.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page