

LEINSTER, Australia

WMO: 954480

Lat: 27.8386S

Lon: 120.7031E

Elev: 498

StdP: 95.48

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 3.4	(c) 4.6	(d) -11.5	(e) 1.5	(f) 25.3	(g) -9.5	(h) 1.8	(i) 24.6	(j) 9.6	(k) 16.9	(l) 8.8	(m) 17.1	(n) 1.9	(o) 70	(p) 0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 12.8	(c) 41.4	(d) 18.2	(e) 39.9	(f) 18.2	(g) 38.3	(h) 17.9	(i) 23.3	(j) 28.9	(k) 22.4	(l) 29.3	(m) 21.4	(n) 29.5	(o) 5.0	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	17.9	24.9	20.6	16.2	24.8	19.2	14.8	24.3	72.3	28.6	68.5	28.8	64.8	29.3	36.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.5	(b) 8.5	(c) 7.8	(e) 0.5	(f) 43.4	(g) 0.7	(h) 1.5	(i) 0.0	(j) 44.5	(k) -0.4	(l) 45.4	(m) -0.9	(n) 46.2	(o) -1.4	(p) 47.3		
(a) 9.5	(b) 8.5	(c) 7.8	(e) -1.1	(f) 24.3	(g) 0.9	(h) 1.3	(i) -1.8	(j) 25.3	(k) -2.3	(l) 26.1	(m) -2.9	(n) 26.8	(o) -3.5	(p) 27.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	29.9	28.5	25.4	21.8	16.6	13.1	12.5	14.6	17.9	22.2	25.2	28.2
	DBStd	7.01	4.07	4.06	4.00	3.50	3.34	2.84	2.88	3.43	3.73	3.89	3.92	3.72
	HDD10.0	14	0	0	0	0	0	4	8	2	0	0	0	0
	HDD18.3	621	1	0	2	9	76	158	184	126	54	11	1	1
	CDD10.0	4130	617	517	477	356	204	98	84	143	236	377	457	564
	CDD18.3	1696	359	284	220	114	22	2	2	9	40	130	209	306
	CDH23.3	22321	5266	3907	2616	1121	197	13	18	129	554	1590	2651	4260
CDH26.7	12464	3341	2353	1357	455	43	1	1	21	192	743	1425	2533	
Wind	WSAvg	4.3	5.0	4.7	4.5	3.8	3.5	3.6	3.6	3.9	4.3	4.7	4.8	4.8
Precipitation	PrecAvg	255	37	32	30	28	23	19	18	11	6	11	11	20
	PrecMax	449	139	110	160	162	100	67	72	42	44	70	66	96
	PrecMin	118	0	0	0	0	3	2	0	0	0	0	0	0
	PrecStd	95	42	33	37	35	23	16	19	13	9	18	15	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	43.3	39.6	35.9	30.7	25.1	25.7	29.1	33.3	37.4	40.2	42.0
		MCWB	18.5	17.9	18.0	17.3	15.2	13.5	13.2	12.9	14.3	15.9	17.1	18.2
	2%	DB	41.5	41.0	37.3	33.3	27.5	22.7	22.9	26.7	31.0	35.2	37.8	40.1
		MCWB	18.5	18.2	17.8	16.2	14.2	12.4	11.4	12.5	13.7	15.8	16.5	17.7
	5%	DB	40.1	39.0	35.6	31.4	25.4	21.1	20.9	24.6	29.0	33.2	36.0	38.3
		MCWB	18.7	18.1	18.0	16.3	14.0	11.6	11.0	11.8	13.3	15.0	16.3	17.5
	10%	DB	38.3	36.8	33.5	29.3	23.5	19.4	19.0	22.3	26.8	31.0	34.0	36.5
		MCWB	18.5	18.5	17.9	15.8	13.5	11.2	10.5	11.2	12.7	14.6	16.0	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	28.4	22.8	20.6	19.0	16.2	15.6	15.6	16.4	20.0	20.5	23.0
		MCDB	28.6	28.4	26.6	28.1	22.1	19.1	20.6	21.4	24.9	28.0	27.6	30.0
	2%	WB	23.1	23.6	21.6	19.2	16.9	14.9	13.8	14.2	15.2	17.7	19.1	21.5
		MCDB	29.6	28.5	27.4	25.7	22.4	18.6	17.6	21.7	25.7	26.6	28.1	29.7
	5%	WB	22.2	22.6	20.6	18.4	15.8	13.8	12.8	13.2	14.3	16.6	18.2	20.5
		MCDB	30.6	28.7	28.0	24.9	21.8	18.4	17.4	21.3	25.5	27.2	29.1	29.7
	10%	WB	21.2	21.6	19.7	17.6	14.7	12.6	11.8	12.2	13.5	15.6	17.4	19.3
		MCDB	31.6	28.8	28.2	24.6	21.2	17.2	17.3	20.6	24.8	28.2	29.6	30.9
Mean Daily Temperature Range	5% DB	MDBR	12.8	12.2	11.8	12.0	12.0	11.4	11.8	13.1	14.0	13.8	13.5	13.2
		MCDBR	14.8	15.0	14.3	14.7	13.7	13.3	14.4	15.5	17.1	16.6	15.5	15.1
		MCWBR	4.1	4.3	4.3	4.8	5.3	6.1	6.7	6.8	6.7	6.1	5.2	4.7
	5% WB	MCDBR	12.2	10.6	10.9	10.8	10.2	9.8	10.8	12.5	14.2	13.9	13.8	13.2
		MCWBR	4.1	3.6	4.1	4.1	4.4	5.3	5.8	6.3	5.9	5.3	4.7	4.5
Clear-Sky Solar Irradiance	taub	0.340	0.342	0.324	0.308	0.288	0.277	0.275	0.279	0.298	0.318	0.326	0.328	
	taud	2.575	2.586	2.612	2.628	2.634	2.653	2.642	2.612	2.540	2.502	2.517	2.558	
	Ebn at Noon	1001	983	971	941	919	910	926	960	983	995	1009	1015	
	Edh at Noon	107	103	95	85	76	71	74	84	100	111	113	109	
All-Sky Solar Radiation	RadAvg	7.80	7.02	6.08	4.99	4.08	3.49	3.82	4.93	6.28	7.19	7.90	8.20	
	RadStd	0.62	0.49	0.43	0.23	0.27	0.21	0.26	0.25	0.22	0.46	0.34	0.47	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page