

TIBOOBURRA, Australia

WMO: 954850

Lat: 29.4447S

Lon: 142.0567E

Elev: 581

StdP: 14.39

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.4	41.3	6.0	7.7	81.5	10.6	9.6	79.7	25.0	64.8	22.5	61.9	6.9	250	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.5	107.4	65.8	104.4	65.3	101.5	64.6	74.0	85.1	72.0	85.6	70.4	86.0	12.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	119.3	76.9	68.9	108.3	76.0	66.0	97.9	75.6	38.0	83.7	36.2	84.7	34.7	86.0	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 26.0	22.6	20.3	DB	35.1	111.7	1.7	2.9	33.8	113.8	32.9	115.5	31.9	117.1	30.7	119.3	(4)
(5)			WB	31.4	76.6	1.5	3.0	30.4	78.8	29.5	80.5	28.6	82.2	27.6	84.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	87.2	84.4	78.9	71.0	61.1	54.8	54.4	57.3	64.5	71.9	78.1	82.6	(6)
(7)		DBStd	13.10	6.74	7.19	6.71	6.42	5.56	5.04	5.08	5.52	6.82	7.44	7.68	7.10	(7)
(8)		HDD50	25	0	0	0	0	1	11	10	3	0	0	0	0	(8)
(9)		HDD65	1179	0	0	1	19	149	310	331	251	94	20	4	0	(9)
(10)		CDD50	7485	1154	963	895	630	345	154	148	228	435	679	844	1010	(10)
(11)		CDD65	3163	689	543	432	199	28	3	3	11	78	234	398	545	(11)
(12)		CDH74	42108	10380	7588	5204	1982	233	18	29	155	979	2817	5092	7631	(12)
(13)		CDH80	23931	6680	4617	2740	770	25	0	2	34	374	1352	2808	4529	(13)
(14)	Wind	WSAvg	10.7	12.1	11.6	10.9	9.5	9.1	9.4	9.4	9.8	10.7	12.0	12.1	12.3	(14)
(15)	Precipitation	PrecAvg	9.7	1.6	1.1	0.8	0.7	0.8	0.5	0.8	0.5	0.6	0.7	0.7	0.8	(15)
(16)		PrecMax	29.7	15.2	7.0	6.9	3.6	3.6	2.4	3.6	2.0	5.5	2.9	3.4	4.9	(16)
(17)		PrecMin	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.7	3.0	1.7	1.3	0.9	0.9	0.6	0.9	0.5	1.0	0.8	0.8	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.8	109.5	104.1	94.5	83.0	76.9	77.4	84.2	95.5	100.1	107.4	108.5	(19)
MCWB			66.0	68.1	65.3	62.0	58.9	59.2	56.4	55.9	59.1	61.6	64.2	64.9	(20)	
2%		DB	108.3	105.6	99.2	91.4	79.7	71.9	73.1	78.2	88.3	96.0	102.3	104.4	(21)	
		MCWB	65.9	66.3	63.9	62.7	57.7	55.4	53.7	54.0	56.4	59.8	62.9	63.8	(22)	
5%		DB	104.8	102.4	96.2	87.7	76.5	67.8	69.2	73.7	84.1	92.2	98.1	101.1	(23)	
		MCWB	65.7	65.6	62.9	60.4	56.7	54.0	51.9	52.5	55.7	59.0	61.8	63.7	(24)	
10%		DB	101.6	99.0	92.8	84.6	72.9	64.8	65.4	69.8	79.7	87.8	93.7	97.6	(25)	
		MCWB	65.5	65.4	62.8	59.6	55.6	52.7	50.7	51.1	54.2	57.7	61.0	62.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	76.5	72.9	69.2	67.0	62.0	63.0	61.3	65.1	68.4	71.1	75.8	(27)
MCD B			85.2	84.4	81.1	80.6	69.3	68.9	69.2	66.2	70.1	75.4	83.2	86.0	(28)	
2%		WB	74.0	73.8	71.0	66.8	61.6	59.1	57.4	56.7	61.3	64.8	68.9	71.9	(29)	
		MCD B	86.3	85.7	82.7	77.5	71.1	66.0	64.8	73.0	74.8	81.9	81.3	83.0	(30)	
5%		WB	71.7	71.9	69.2	64.4	59.4	56.7	54.1	54.4	58.6	62.4	67.2	69.7	(31)	
		MCD B	88.4	86.6	83.3	77.2	71.6	63.7	65.7	71.2	77.0	81.5	80.5	84.9	(32)	
10%		WB	69.6	70.1	66.9	62.0	57.4	54.7	52.0	52.3	56.4	60.3	65.0	67.3	(33)	
		MCD B	90.3	86.9	84.9	80.2	70.9	62.8	63.4	67.4	74.9	82.7	83.4	87.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.5	21.6	21.5	21.8	20.4	18.5	20.2	22.3	23.5	23.7	22.8	22.8	(35)
MCDBR			25.3	24.6	24.9	24.8	23.8	21.9	24.3	26.9	29.5	28.6	27.4	26.4	(36)	
MCWBR			8.2	8.0	9.2	9.9	10.5	10.8	11.9	12.3	12.0	11.1	9.7	9.4	(37)	
5% WB		MCD BR	20.9	19.2	19.7	19.1	19.4	17.3	20.5	23.1	22.0	22.4	20.9	20.6	(38)	
		MCWBR	9.3	7.3	8.6	8.5	9.9	9.8	11.3	12.0	11.2	10.5	9.6	9.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.342	0.324	0.309	0.296	0.286	0.286	0.299	0.344	0.338	0.349	0.342	(40)	
taud		2.467	2.498	2.525	2.537	2.530	2.553	2.538	2.480	2.351	2.386	2.406	2.441	(41)		
Ebn at Noon		316	311	307	296	285	281	286	295	295	309	312	318	(42)		
Edh at Noon		38	36	32	29	26	24	25	30	38	39	40	39	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2558	2337	2036	1626	1251	1054	1164	1478	1894	2259	2424	2549	(44)	
(45)		RadStd	111	152	122	69	61	58	57	69	98	116	154	137	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page