

TIBOOBURRA, Australia

WMO: 954850

Lat: 29.4447S

Lon: 142.0567E

Elev: 177

StdP: 99.22

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.1	5.2	-14.4	1.1	27.5	-11.9	1.4	26.5	11.2	18.2	10.1	16.6	3.1	250	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	41.9	18.8	40.2	18.5	38.6	18.1	23.3	29.5	22.2	29.8	21.4	30.0	5.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.0	24.9	20.5	15.5	24.4	18.9	14.0	24.2	70.5	28.7	66.3	29.3	62.9	30.0	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	10.1	9.1	DB	1.7	44.3	0.9	1.6	1.0	45.4	0.5	46.4	0.0	47.3	-0.7	48.5	(4)
(5)			WB	-0.3	24.8	0.8	1.7	-0.9	26.0	-1.4	27.0	-1.9	27.9	-2.5	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	30.7	29.1	26.0	21.7	16.2	12.7	12.5	14.0	18.0	22.2	25.6	28.1	(6)	
	DBStd	7.28	3.74	4.00	3.73	3.57	3.09	2.80	2.82	3.07	3.79	4.14	4.27	3.95	(7)	
	HDD10.0	14	0	0	0	0	1	6	6	2	0	0	0	0	(8)	
	HDD18.3	655	0	0	1	11	83	172	184	139	52	11	2	0	(9)	
	CDD10.0	4158	641	535	497	350	192	86	82	127	242	377	469	561	(10)	
	CDD18.3	1757	383	302	240	111	16	2	2	6	43	130	221	303	(11)	
	CDH23.3	23393	5767	4216	2891	1101	129	10	16	86	544	1565	2829	4239	(12)	
(13)	CDH26.7	13295	3711	2565	1522	428	14	0	1	19	208	751	1560	2516	(13)	
(14)	Wind	WSAvg	4.8	5.4	5.2	4.9	4.3	4.1	4.2	4.4	4.8	5.3	5.4	5.5	(14)	
(15) Precipitation	PrecAvg	247	41	28	21	17	21	12	20	12	16	18	17	20	(15)	
	PrecMax	755	385	178	176	91	92	62	92	50	140	73	86	124	(16)	
	PrecMin	70	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	146	75	44	33	23	24	14	24	13	26	20	21	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	43.0	40.0	34.7	28.4	24.9	25.2	29.0	35.3	37.8	41.9	42.5	(19)	
		MCWB	18.9	20.0	18.5	16.7	14.9	15.1	13.6	13.3	15.1	16.4	17.9	18.3	(20)	
	2%	DB	42.4	40.9	37.4	33.0	26.5	22.2	22.9	25.7	31.3	35.6	39.1	40.2	(21)	
		MCWB	18.8	19.1	17.7	17.0	14.3	13.0	12.0	12.2	13.6	15.5	17.1	17.7	(22)	
	5%	DB	40.5	39.1	35.7	31.0	24.7	19.9	20.6	23.2	29.0	33.5	36.7	38.4	(23)	
		MCWB	18.7	18.7	17.2	15.8	13.7	12.2	11.1	11.4	13.2	15.0	16.6	17.6	(24)	
	10%	DB	38.7	37.2	33.8	29.2	22.7	18.2	18.5	21.0	26.5	31.0	34.3	36.5	(25)	
		MCWB	18.6	18.5	17.1	15.3	13.1	11.5	10.4	10.6	12.3	14.3	16.1	17.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	24.7	22.7	20.7	19.4	16.7	17.2	16.3	18.4	20.2	21.7	24.3	(27)	
		MCDB	29.6	29.1	27.3	27.0	20.7	20.5	20.7	19.0	21.1	24.1	28.4	30.0	(28)	
	2%	WB	23.3	23.2	21.7	19.3	16.4	15.1	14.1	13.7	16.3	18.2	20.5	22.2	(29)	
		MCDB	30.2	29.8	28.2	25.3	21.7	18.9	18.2	22.8	23.8	27.7	27.4	28.4	(30)	
	5%	WB	22.1	22.2	20.7	18.0	15.2	13.7	12.3	12.4	14.8	16.9	19.5	20.9	(31)	
		MCDB	31.3	30.3	28.5	25.1	22.0	17.6	18.7	21.8	25.0	27.5	26.9	29.4	(32)	
	10%	WB	20.9	21.2	19.4	16.7	14.1	12.6	11.1	11.3	13.5	15.7	18.3	19.6	(33)	
		MCDB	32.4	30.5	29.4	26.8	21.6	17.1	17.5	19.7	23.8	28.2	28.6	30.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.0	12.0	12.1	11.3	10.3	11.2	12.4	13.1	13.2	12.7	12.7	(35)	
		MCDBR	14.1	13.7	13.8	13.8	13.2	12.2	13.5	14.9	16.4	15.9	15.2	14.7	(36)	
		MCWBR	4.6	4.4	5.1	5.5	5.8	6.0	6.6	6.8	6.7	6.1	5.4	5.2	(37)	
	5% WB	MCDBR	11.6	10.7	10.9	10.6	10.8	9.6	11.4	12.9	12.2	12.5	11.6	11.4	(38)	
		MCWBR	5.2	4.0	4.8	4.7	5.5	5.4	6.3	6.7	6.2	5.9	5.3	5.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.344	0.342	0.324	0.309	0.296	0.286	0.286	0.299	0.344	0.338	0.349	0.342	(40)	
	taud		2.467	2.498	2.525	2.537	2.530	2.553	2.538	2.480	2.351	2.386	2.406	2.441	(41)	
	Ebn at Noon		997	980	967	933	899	887	902	930	930	973	985	1001	(42)	
	Edh at Noon		119	112	102	91	82	76	80	95	120	124	125	123	(43)	
(44) All-Sky Solar Radiation	RadAvg		8.06	7.37	6.42	5.13	3.94	3.32	3.67	4.66	5.97	7.12	7.64	8.04	(44)	
	RadStd		0.35	0.48	0.38	0.22	0.19	0.18	0.18	0.22	0.31	0.36	0.48	0.43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page