

MOREE, Australia

WMO: 955270

Lat: 29.4897S

Lon: 149.8472E

Elev: 219

StdP: 98.73

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.8	2.2	-8.9	1.8	20.4	-6.5	2.2	18.7	10.6	14.8	9.4	14.8	2.2	90	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	38.1	19.7	36.3	19.5	34.7	19.2	23.2	30.1	22.5	29.5	21.8	28.8	5.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.6	16.7	24.7	20.7	15.8	24.5	19.9	15.0	24.4	70.1	30.0	67.3	29.3	64.9	28.8	35.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	9.0	8.1	-1.6	41.1	1.1	2.3	-2.4	42.8	-3.0	44.2	-3.6	45.5	-4.4	47.1		
(5)			-2.1	25.3	1.4	2.7	-3.1	27.2	-3.9	28.8	-4.6	30.3	-5.6	32.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	27.0	26.1	24.0	19.9	15.3	12.3	11.3	12.6	16.4	20.2	23.2	25.6		
	DBStd	6.34	3.00	2.98	2.66	2.85	2.99	2.82	2.73	3.09	3.47	3.59	3.70	3.31		
	HDD10.0	37	0	0	0	0	1	10	17	8	1	0	0	0		
	HDD18.3	803	0	0	1	17	100	181	220	179	78	22	4	1		
	CDD10.0	3489	527	451	433	298	166	79	56	90	192	317	397	483		
	CDD18.3	1214	269	218	176	64	7	0	1	3	20	81	151	225		
	CDH23.3	13679	3198	2421	1719	624	73	2	3	38	308	939	1711	2643		
	CDH26.7	6396	1704	1203	714	150	4	0	0	7	86	356	811	1360		
(14) Wind	WSAvg	4.1	4.7	4.4	4.2	3.7	3.6	3.6	3.6	3.8	4.2	4.4	4.7	4.8		
(15) Precipitation	PrecAvg	588	77	69	46	37	46	28	46	37	32	45	56	67		
	PrecMax	848	228	249	225	241	177	74	189	159	114	113	221	241		
	PrecMin	320	1	3	0	0	0	0	0	0	1	6	2	4		
	PrecStd	134	58	59	49	51	45	21	41	35	25	30	43	55		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.1	39.7	36.5	31.9	27.1	23.1	23.5	27.1	32.1	34.9	39.5	39.7		
		MCWB	20.8	20.7	19.4	17.6	15.7	14.7	13.5	14.5	15.1	16.8	18.5	19.7		
	2%	DB	37.8	36.8	33.8	29.8	25.2	21.6	21.2	23.9	29.3	32.4	36.1	37.0		
		MCWB	20.4	20.5	18.9	17.4	15.1	13.8	12.6	13.3	14.9	16.4	18.1	18.7		
	5%	DB	35.9	34.7	32.1	28.3	23.9	20.3	19.6	22.0	26.8	30.5	33.6	35.1		
		MCWB	19.9	20.3	18.8	16.7	14.5	13.0	12.0	12.2	14.3	16.2	17.8	18.7		
	10%	DB	34.1	32.8	30.5	27.0	22.5	18.9	18.0	20.2	24.6	28.5	31.2	33.2		
		MCWB	19.8	19.9	18.7	16.2	13.9	12.4	11.3	11.7	13.7	15.7	17.3	18.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.2	22.8	20.5	18.6	16.7	17.3	16.7	18.7	20.5	21.9	23.2		
		MCDB	30.8	31.3	28.4	26.7	22.7	20.0	19.8	24.2	25.1	27.4	29.3	30.1		
	2%	WB	23.1	23.3	22.0	19.4	17.2	15.5	14.9	15.0	17.3	19.1	20.7	22.2		
		MCDB	30.5	30.0	27.3	25.2	21.9	18.8	18.1	20.0	22.9	26.6	27.5	29.4		
	5%	WB	22.4	22.6	21.2	18.4	16.1	14.5	13.3	13.9	16.3	18.1	20.0	21.4		
		MCDB	29.9	29.2	27.0	24.9	20.9	18.0	17.2	19.3	22.8	25.6	26.9	28.7		
	10%	WB	21.7	21.7	20.4	17.4	15.0	13.5	12.3	12.7	15.2	17.3	19.3	20.7		
		MCDB	29.3	28.7	26.8	24.6	20.5	17.4	16.6	18.6	22.0	24.8	26.8	28.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	12.3	12.7	13.7	13.5	12.4	13.2	14.6	15.0	14.4	13.5	13.4		
		MCDBR	14.9	14.5	14.1	14.6	14.3	13.8	14.9	16.6	17.5	16.4	16.1	15.6		
	5% WB	MCWBR	4.7	4.6	4.9	5.8	6.5	7.1	7.9	8.1	7.5	6.3	5.6	5.4		
		MCWBR	11.6	11.2	10.8	12.2	11.2	10.3	11.2	13.1	13.1	13.2	11.9	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.361	0.360	0.334	0.318	0.298	0.291	0.286	0.298	0.333	0.353	0.374	0.365		
	taud		2.528	2.540	2.608	2.610	2.612	2.644	2.633	2.570	2.463	2.441	2.432	2.494		
	Ebn at Noon		980	962	958	925	899	884	905	933	943	959	961	979		
	Edh at Noon		112	107	95	85	76	70	74	87	107	117	122	116		
(44) All-Sky Solar Radiation	RadAvg		7.47	6.81	5.86	4.86	3.81	3.11	3.50	4.47	5.65	6.56	7.06	7.47		
	RadStd		0.47	0.49	0.35	0.24	0.20	0.26	0.24	0.26	0.40	0.50	0.69	0.57		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.58	N/A	N/A	+1.30	N/A	N/A	N/A	N/A	+286	+218
(47) Regional (6 neighbors)		+0.61	N/A	N/A	+1.30	N/A	N/A	N/A	N/A	+270	+208

Nomenclature: See separate page