

MILES, Australia

WMO: 955290

Lat: 26.6569S

Lon: 150.1819E

Elev: 1001

StdP: 14.17

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.6	34.2	18.2	14.3	70.6	22.4	17.4	68.5	13.7	62.1	12.2	61.9	0.4	0	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	99.0	68.5	96.2	68.3	93.8	67.8	75.2	86.4	73.8	84.2	72.6	83.2	8.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.6	125.5	78.3	71.1	119.0	77.5	69.7	113.2	76.8	39.5	86.3	38.1	84.3	37.0	82.8	97.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	13.2	11.8	DB	27.1	103.8	2.0	2.5	25.6	105.6	24.5	107.1	23.4	108.5	21.9	110.3
			WB	29.6	80.0	2.2	6.5	28.1	84.6	26.8	88.4	25.6	92.0	24.1	96.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	80.6	78.9	75.4	68.7	60.0	55.3	53.8	56.6	64.0	70.5	76.0	78.8	(6)
	DBStd	10.89	4.07	4.65	4.36	4.37	5.35	5.41	5.36	6.00	6.53	5.99	5.24	5.06	(7)
	HDD50	40	0	0	0	0	1	12	19	8	0	0	0	0	(8)
	HDD65	1220	0	0	1	16	171	293	348	272	98	19	1	1	(9)
	CDD50	6659	948	809	787	560	310	171	138	211	419	635	779	892	(10)
	CDD65	2364	483	389	323	126	15	2	2	11	67	189	330	427	(11)
	CDH74	25604	5469	4286	3139	1188	211	15	21	184	920	2132	3418	4621	(12)
	CDH80	11521	2803	2089	1269	264	23	2	0	37	285	847	1587	2315	(13)
(14) Wind	WSAvg	5.1	6.5	6.2	5.7	4.2	3.4	3.5	3.4	4.1	5.0	5.9	6.5	6.5	(14)
(15) Precipitation	PrecAvg	25.4	3.8	2.7	2.1	1.5	1.7	1.4	1.3	1.2	1.1	2.0	2.7	3.9	(15)
	PrecMax	39.7	11.0	8.5	6.9	8.3	9.4	7.6	6.6	6.7	4.5	4.6	6.9	17.4	(16)
	PrecMin	15.2	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.8	(17)
	PrecStd	6.1	2.6	2.1	1.7	1.9	1.8	1.5	1.5	1.2	1.0	1.1	1.8	2.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.7	102.1	97.5	88.7	82.8	75.5	76.7	84.6	92.1	96.2	99.0	102.6	(19)
		MCWB	70.8	70.1	67.8	65.1	62.1	60.8	58.0	58.9	62.4	64.2	67.6	66.7	(20)
	2%	DB	97.8	97.5	92.6	85.4	79.0	72.6	73.0	78.5	86.9	91.6	95.2	98.2	(21)
		MCWB	69.1	69.4	68.5	64.0	60.3	58.9	57.4	57.6	60.9	62.9	65.8	68.4	(22)
	5%	DB	95.2	94.0	89.6	83.0	76.0	70.3	70.3	75.0	83.2	88.2	92.1	94.5	(23)
		MCWB	69.3	69.4	67.5	63.4	59.1	57.6	56.0	55.7	60.1	62.4	65.2	67.9	(24)
	10%	DB	92.5	90.9	86.9	80.7	73.4	67.6	67.4	71.6	79.5	84.9	88.9	91.2	(25)
		MCWB	68.5	68.8	66.8	63.0	58.2	56.5	54.7	54.5	58.9	61.9	64.5	67.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.1	76.7	74.6	71.0	66.1	64.7	64.7	63.7	67.5	71.0	72.5	77.2	(27)
		MCDB	86.5	86.7	82.1	79.4	73.6	71.0	71.2	72.4	80.6	84.3	84.2	85.0	(28)
	2%	WB	75.4	74.6	72.8	68.6	63.8	62.2	61.5	61.2	64.8	68.5	70.6	73.6	(29)
		MCDB	86.4	86.5	81.9	77.5	72.8	67.8	67.8	72.6	77.1	80.5	83.1	83.5	(30)
	5%	WB	73.8	73.4	71.3	66.7	62.0	60.4	58.9	59.2	63.1	66.8	69.2	72.1	(31)
		MCDB	84.5	84.2	80.9	76.5	71.6	66.1	65.7	69.9	76.2	78.3	82.3	82.9	(32)
	10%	WB	72.5	72.1	70.1	65.4	60.5	58.5	56.7	57.2	61.5	65.1	67.9	71.0	(33)
		MCDB	83.6	83.1	80.2	75.6	69.5	65.0	64.4	68.1	74.8	77.1	81.4	82.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	21.5	21.9	24.6	27.2	23.9	27.4	30.0	28.8	26.4	23.2	22.0	(35)
		MCDBR	26.3	26.4	25.5	27.3	29.7	27.1	30.5	33.9	32.8	30.7	27.7	27.3	(36)
	5% WB	MCWBR	6.8	7.1	6.6	9.4	12.8	13.6	14.8	14.6	12.6	10.1	7.7	8.0	(37)
		MCWBR	20.3	20.3	19.7	21.0	22.8	19.2	22.0	25.1	25.7	23.0	21.8	20.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.367	0.356	0.336	0.319	0.299	0.292	0.285	0.298	0.332	0.356	0.369	0.372	(40)
		taud	2.530	2.571	2.624	2.632	2.629	2.655	2.658	2.598	2.492	2.460	2.470	2.497	(41)
	Ebn at Noon		309	308	305	296	289	285	292	299	301	304	307	308	(42)
		Edh at Noon	36	33	30	27	25	23	23	28	34	37	37	37	(43)
(44) All-Sky Solar Radiation	RadAvg		2261	2086	1844	1572	1281	1074	1214	1527	1859	2096	2246	2274	(44)
	RadStd		162	183	117	94	55	83	89	99	139	176	219	221	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page