

GAYNDAH, Australia

WMO: 955430

Lat: 25.617S

Lon: 151.616E

Elev: 366

StdP: 14.50

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	41.5	23.8	18.2	63.6	27.4	21.6	60.4	19.2	65.0	16.6	65.7	1.8	230	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	96.8	71.8	94.1	71.4	91.7	70.7	76.8	88.0	75.6	85.8	74.5	84.4	7.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.2	129.2	80.3	72.9	123.8	79.8	71.7	118.8	79.4	40.6	88.1	39.4	85.8	38.3	84.2	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.3	15.5	13.8	DB	33.4	103.4	1.7	2.9	32.1	105.5	31.1	107.2	30.1	108.9	28.9	111.0
			WB	31.6	79.9	1.8	3.1	30.3	82.1	29.2	83.9	28.2	85.6	26.8	87.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	80.2	79.2	76.9	71.3	64.6	60.0	58.7	60.9	67.0	72.2	75.9	78.7	(6)
(7)		DBStd	8.71	3.68	3.80	3.38	3.71	4.31	4.61	4.30	4.48	4.74	4.39	4.31	4.20	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	598	0	0	0	2	59	159	201	144	31	2	0	0	(9)
(10)		CDD50	7450	937	817	833	640	453	300	270	336	510	688	776	890	(10)
(11)		CDD65	2573	472	397	368	193	47	9	5	15	91	225	326	425	(11)
(12)		CDH74	23956	4695	3824	3177	1493	364	60	48	247	1060	2038	2895	4055	(12)
(13)		CDH80	9571	2175	1675	1223	371	30	2	2	35	293	737	1183	1845	(13)
(14)	Wind	WSAvg	5.1	6.3	5.7	5.7	4.6	4.0	4.1	4.1	4.3	4.9	5.7	5.9	6.0	(14)
(15)	Precipitation	PrecAvg	28.5	4.1	3.7	2.3	1.6	1.7	1.1	1.3	1.3	1.2	2.6	3.7	4.0	(15)
(16)		PrecMax	36.3	13.3	13.5	5.2	6.7	8.2	5.6	4.8	4.6	4.1	5.5	10.1	10.2	(16)
(17)		PrecMin	17.2	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)		PrecStd	4.8	2.8	2.5	1.4	1.6	1.5	1.1	1.3	1.2	1.1	1.5	2.4	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.7	98.6	95.0	89.6	83.1	78.4	78.1	83.8	91.7	95.8	98.0	100.4	(19)
(20)			MCWB	74.1	74.0	71.3	66.9	64.5	63.4	60.7	61.3	64.7	66.6	68.8	71.6	(20)
(21)		2%	DB	96.0	94.7	91.6	86.6	80.1	75.8	75.0	79.5	86.6	90.3	92.8	95.4	(21)
(22)			MCWB	72.9	73.4	71.4	67.3	63.7	62.0	59.3	60.4	63.1	66.1	68.6	71.4	(22)
(23)		5%	DB	93.1	91.7	89.1	84.1	77.9	73.7	72.8	76.5	83.2	87.1	89.8	92.1	(23)
(24)			MCWB	72.1	72.4	70.4	66.6	62.8	60.7	58.4	59.0	62.0	65.5	68.2	71.1	(24)
(25)		10%	DB	90.3	88.9	86.8	81.9	75.9	71.3	70.6	73.8	80.1	84.1	86.8	89.2	(25)
(26)			MCWB	71.6	71.6	69.9	65.7	62.1	59.6	57.3	57.8	61.4	64.9	67.8	70.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.3	78.5	76.5	73.2	70.2	67.0	66.4	66.0	69.8	72.0	75.8	77.3	(27)
(28)			MCD B	90.0	90.2	86.0	81.7	76.6	73.3	73.1	76.6	81.9	84.2	87.1	90.2	(28)
(29)		2%	WB	76.7	76.7	74.9	71.0	67.9	64.7	63.5	63.9	67.3	70.4	73.2	75.4	(29)
(30)			MCD B	87.7	87.7	83.8	79.7	75.0	71.4	70.2	74.3	78.0	81.8	83.8	87.3	(30)
(31)		5%	WB	75.5	75.3	73.5	69.6	65.9	63.1	61.4	61.9	65.6	69.0	71.7	74.0	(31)
(32)			MCD B	85.7	84.6	82.5	78.3	73.7	70.1	68.2	71.5	76.3	79.8	82.0	85.0	(32)
(33)		10%	WB	74.2	74.1	72.3	68.2	64.3	61.5	59.5	60.3	64.2	67.7	70.3	72.8	(33)
(34)			MCD B	84.2	83.5	81.7	77.7	72.6	68.8	67.4	70.0	75.0	78.2	80.8	83.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.9	19.5	20.2	22.3	23.5	23.1	25.6	27.9	27.5	24.3	22.1	20.9	(35)
(36)			MCDBR	24.8	24.1	24.2	25.2	26.0	25.6	28.3	31.3	31.7	29.0	26.3	25.5	(36)
(37)			MCWBR	6.0	6.1	6.8	8.7	11.3	12.8	14.0	13.8	11.2	9.1	6.8	7.0	(37)
(38)		5% WB	MCDBR	20.2	19.1	18.7	19.8	19.8	20.1	21.2	25.3	24.4	22.9	20.8	21.2	(38)
(39)			MCWBR	6.2	6.1	6.2	7.9	9.4	10.9	11.5	12.0	9.5	8.2	6.8	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.381	0.373	0.355	0.332	0.312	0.305	0.296	0.309	0.347	0.372	0.378	0.389	(40)	
(41)		taud	2.505	2.539	2.583	2.625	2.624	2.643	2.650	2.591	2.478	2.444	2.468	2.467	(41)	
(42)		Ebn at Noon	305	303	299	293	286	282	289	296	297	299	304	304	(42)	
(43)		Edh at Noon	36	35	31	28	25	23	24	28	34	37	37	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2089	1923	1681	1485	1253	1069	1213	1496	1819	2004	2130	2153	(44)	
(45)		RadStd	161	172	131	116	62	76	99	115	149	168	221	228	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-2.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-113	+340	+207

Nomenclature: See separate page