

GAYNDAH, Australia

WMO: 955430

Lat: 25.617S

Lon: 151.616E

Elev: 112

StdP: 99.99

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 3.7	(c) 5.3	(d) -4.6	(e) 2.6	(f) 17.5	(g) -2.6	(h) 3.1	(i) 15.8	(j) 8.6	(k) 18.3	(l) 7.4	(m) 18.7	(n) 0.8	(o) 230	(p) 0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 11.1	(c) 36.0	(d) 22.1	(e) 34.5	(f) 21.9	(g) 33.2	(h) 21.5	(i) 24.9	(j) 31.1	(k) 24.2	(l) 29.9	(m) 23.6	(n) 29.1	(o) 3.3	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.4	18.5	26.8	22.7	17.7	26.6	22.1	17.0	26.4	76.5	31.2	73.7	29.9	71.3	29.0	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.9	6.2	0.8	39.7	1.0	1.6	0.1	40.8	-0.5	41.8	-1.0	42.7	-1.7	43.9
			-0.2	26.6	1.0	1.7	-1.0	27.8	-1.6	28.8	-2.1	29.8	-2.9	31.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	26.8	26.2	24.9	21.9	18.1	15.6	14.8	16.0	19.4	22.3	24.4	25.9	(6)
(7)		DBStd	4.84	2.05	2.11	1.88	2.06	2.39	2.56	2.39	2.49	2.63	2.44	2.40	2.34	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	332	0	0	0	1	33	88	112	80	17	1	0	0	(9)
(10)		CDD10.0	4139	521	454	463	356	252	167	150	187	283	382	431	494	(10)
(11)		CDD18.3	1429	262	221	204	107	26	5	3	8	51	125	181	236	(11)
(12)		CDH23.3	13309	2608	2124	1765	829	202	33	27	137	589	1132	1608	2253	(12)
(13)		CDH26.7	5317	1208	931	679	206	17	1	1	19	163	409	657	1025	(13)
(14)	Wind	WSAvg	2.3	2.8	2.6	2.6	2.0	1.8	1.8	1.9	2.2	2.5	2.7	2.7	(14)	
(15)	Precipitation	PrecAvg	723	104	94	58	40	42	29	34	32	31	65	94	101	(15)
(16)		PrecMax	921	339	342	132	170	209	141	121	117	103	140	256	258	(16)
(17)		PrecMin	436	0	1	5	0	0	0	0	0	0	0	0	16	(17)
(18)		PrecStd	121	70	64	36	40	37	29	32	30	29	37	62	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	37.0	35.0	32.0	28.4	25.8	25.6	28.8	33.2	35.4	36.7	38.0	(19)
(20)			MCWB	23.4	23.3	21.9	19.4	18.1	17.4	16.0	16.3	18.2	19.2	20.4	22.0	(20)
(21)		2%	DB	35.6	34.8	33.1	30.3	26.7	24.3	23.9	26.4	30.3	32.4	33.8	35.2	(21)
(22)			MCWB	22.7	23.0	21.9	19.6	17.6	16.7	15.2	15.8	17.3	18.9	20.3	21.9	(22)
(23)		5%	DB	34.0	33.2	31.7	29.0	25.5	23.2	22.7	24.7	28.4	30.6	32.1	33.4	(23)
(24)			MCWB	22.3	22.4	21.3	19.2	17.1	15.9	14.7	15.0	16.7	18.6	20.1	21.7	(24)
(25)		10%	DB	32.4	31.6	30.4	27.7	24.4	21.9	21.4	23.2	26.7	28.9	30.4	31.8	(25)
(26)			MCWB	22.0	22.0	21.1	18.7	16.7	15.3	14.1	14.3	16.4	18.3	19.9	21.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	25.8	24.7	22.9	21.2	19.5	19.1	18.9	21.0	22.2	24.3	25.2	(27)
(28)			MCD B	32.2	32.4	30.0	27.6	24.8	23.0	22.8	24.8	27.7	29.0	30.6	32.3	(28)
(29)		2%	WB	24.8	24.8	23.8	21.6	20.0	18.2	17.5	17.7	19.6	21.3	22.9	24.1	(29)
(30)			MCD B	31.0	30.9	28.8	26.5	23.9	21.9	21.2	23.5	25.6	27.7	28.8	30.7	(30)
(31)		5%	WB	24.1	24.1	23.1	20.9	18.8	17.3	16.3	16.6	18.7	20.5	22.0	23.4	(31)
(32)			MCD B	29.8	29.2	28.0	25.7	23.1	21.2	20.1	22.0	24.6	26.5	27.8	29.5	(32)
(33)		10%	WB	23.5	23.4	22.4	20.1	17.9	16.4	15.3	15.7	17.9	19.8	21.3	22.7	(33)
(34)			MCD B	29.0	28.6	27.6	25.4	22.6	20.4	19.6	21.1	23.9	25.7	27.1	28.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	10.9	11.2	12.4	13.1	12.8	14.2	15.5	13.5	12.3	11.6	(35)	
(36)			MCDBR	13.8	13.4	13.4	14.0	14.5	14.2	15.7	17.4	17.6	16.1	14.6	14.2	(36)
(37)			MCWBR	3.3	3.4	3.8	4.9	6.3	7.1	7.8	7.7	6.2	5.1	3.8	3.9	(37)
(38)		5% WB	MCD BR	11.2	10.6	10.4	11.0	11.0	11.2	11.8	14.1	13.5	12.7	11.6	11.8	(38)
(39)			MCWBR	3.4	3.4	3.4	4.4	5.2	6.0	6.4	6.7	5.3	4.6	3.8	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.381	0.373	0.355	0.332	0.312	0.305	0.296	0.309	0.347	0.372	0.378	0.389	(40)	
(41)		taud	2.505	2.539	2.583	2.625	2.624	2.643	2.650	2.591	2.478	2.444	2.468	2.467	(41)	
(42)		Ebn at Noon	962	955	944	923	901	888	911	933	936	944	959	957	(42)	
(43)		Edh at Noon	115	109	99	87	79	74	76	88	108	118	118	120	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.58	6.06	5.30	4.68	3.95	3.37	3.82	4.71	5.73	6.32	6.71	6.79	(44)	
(45)		RadStd	0.51	0.54	0.41	0.37	0.19	0.24	0.31	0.36	0.47	0.53	0.70	0.72	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) -1.65	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-63	+189	+115

Nomenclature: See separate page