

NAMBOUR, Australia

WMO: 955720

Lat: 26.6442S

Lon: 152.9383E

Elev: 177

StdP: 14.60

Time Zone: 10.00 (E10)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.3	44.3	27.7	21.8	63.6	31.7	26.2	61.2	11.8	62.1	10.2	63.6	0.1	290	0.261

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	90.9	73.0	87.9	72.4	85.5	71.9	76.8	85.3	75.6	83.2	74.5	81.6	7.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.5	130.1	80.7	73.4	125.0	79.4	72.4	120.7	78.4	40.5	85.7	39.3	83.4	38.2	81.6	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.1	9.3	38.2	98.9	3.0	4.2	36.1	102.0	34.3	104.4	32.6	106.8	30.4	109.8		
(5)			36.3	79.2	2.4	1.4	34.6	80.3	33.2	81.1	31.9	81.9	30.2	83.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.4	76.3	75.7	73.8	69.4	64.6	60.8	59.5	60.8	65.4	68.8	71.8	74.7	(6)
(7)		DBStd	7.05	3.51	3.21	2.91	2.88	3.54	4.04	3.82	4.25	4.40	4.52	4.55	4.31	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	566	0	0	0	4	50	134	176	144	46	10	2	0	(9)
(10)		CDD50	6726	814	720	739	583	451	323	294	336	462	583	654	767	(10)
(11)		CDD65	1815	349	300	274	137	36	7	4	15	57	128	206	302	(11)
(12)		CDH74	11352	2487	1953	1465	512	123	20	22	119	415	829	1284	2123	(12)
(13)		CDH80	2780	669	492	271	41	4	1	1	17	82	221	344	637	(13)
(14)	Wind	WSAvg	3.0	3.6	3.2	2.9	2.5	2.1	2.2	2.4	2.8	3.3	3.5	3.7	3.5	(14)
(15)	Precipitation	PrecAvg	66.1	9.3	9.6	8.1	5.7	5.6	3.4	2.6	2.1	1.8	4.1	5.7	7.2	(15)
(16)		PrecMax	119.7	48.0	33.9	25.9	25.2	16.6	21.4	9.2	5.9	9.5	12.5	15.7	24.1	(16)
(17)		PrecMin	38.3	0.6	2.1	0.7	1.5	0.1	0.1	0.0	0.0	0.0	0.2	0.9	1.0	(17)
(18)		PrecStd	19.0	8.4	8.3	5.7	4.4	4.1	4.5	2.2	1.6	1.8	2.7	3.5	5.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	92.3	89.2	83.7	79.8	76.4	76.8	81.7	87.1	91.6	94.0	95.1	(19)
(20)			MCWB	75.7	75.7	74.5	70.6	64.6	63.8	60.9	62.6	64.2	67.6	69.5	73.1	(20)
(21)		2%	DB	88.9	87.9	85.5	80.9	77.2	73.4	73.6	77.0	81.9	85.5	87.2	89.9	(21)
(22)			MCWB	74.9	74.7	73.0	68.5	63.9	62.3	59.7	60.8	64.5	67.5	69.6	73.4	(22)
(23)		5%	DB	85.8	85.0	82.8	78.9	74.9	71.1	71.0	73.8	78.6	81.6	83.7	86.3	(23)
(24)			MCWB	73.5	73.6	71.7	67.9	63.4	61.2	59.1	59.4	63.4	67.0	69.5	72.4	(24)
(25)		10%	DB	83.5	82.8	80.8	77.0	72.9	69.0	68.6	70.9	75.6	78.4	80.7	83.2	(25)
(26)			MCWB	72.4	72.2	70.8	66.9	63.0	60.4	58.5	58.3	62.2	66.2	68.8	71.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.7	78.6	77.0	73.7	70.2	67.7	66.6	66.3	69.5	72.6	74.3	77.4	(27)
(28)			MCD B	88.5	88.9	84.8	79.4	74.8	71.7	72.3	76.1	78.9	82.7	84.6	89.0	(28)
(29)		2%	WB	76.7	76.7	75.2	71.2	68.0	65.5	63.9	64.2	67.5	70.8	72.7	75.7	(29)
(30)			MCD B	84.4	84.6	82.2	77.1	73.1	69.8	69.1	72.2	76.2	80.2	81.8	85.5	(30)
(31)		5%	WB	75.5	75.2	73.7	69.9	66.3	63.9	62.0	62.7	66.0	69.0	71.4	74.2	(31)
(32)			MCD B	82.5	81.9	79.7	75.8	71.7	68.5	67.8	69.9	74.6	77.8	79.7	82.6	(32)
(33)		10%	WB	74.3	73.9	72.6	68.7	65.0	62.4	60.3	60.9	64.5	67.7	70.2	72.9	(33)
(34)			MCD B	80.8	80.0	78.2	74.6	70.2	67.0	65.8	67.7	72.7	75.6	77.9	80.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.8	13.3	13.7	15.1	17.3	17.1	19.6	21.6	20.7	18.2	16.7	15.6	(35)
(36)			MCDBR	17.7	17.5	17.6	19.0	21.0	19.8	23.3	25.7	25.2	23.9	21.0	20.8	(36)
(37)			MCWBR	6.3	6.7	7.3	8.6	10.1	10.5	11.7	11.6	10.6	9.7	7.7	7.8	(37)
(38)		5% WB	MCDBR	15.1	15.2	14.7	15.1	15.1	15.2	17.4	19.7	20.5	19.7	17.9	18.2	(38)
(39)			MCWBR	6.2	6.6	6.9	7.7	8.2	9.1	10.2	10.3	9.8	8.8	7.2	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.395	0.383	0.361	0.344	0.320	0.314	0.304	0.318	0.356	0.377	0.382	0.399	(40)	
(41)		taud	2.486	2.530	2.590	2.615	2.635	2.647	2.657	2.595	2.485	2.459	2.483	2.460	(41)	
(42)		Ebn at Noon	301	299	297	288	282	277	285	292	293	298	303	300	(42)	
(43)		Edh at Noon	37	35	31	28	25	23	24	28	34	37	37	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2071	1901	1640	1421	1183	994	1151	1431	1758	1946	2122	2107	(44)	
(45)		RadStd	179	163	115	85	65	75	97	114	140	170	188	234	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.37	+4.23	-3.22	N/A	N/A	-0.81	N/A	-248	+574	+284
(47) Regional (25 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-119	+322	+196

Nomenclature: See separate page