

BEAUDESERT, Australia

WMO: 955750

Lat: 27.971S

Lon: 152.990E

Elev: 158

StdP: 14.61

Time Zone: 10.00 (E10)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.4	39.0	27.1	21.1	57.6	30.6	24.9	54.4	16.4	64.1	14.8	63.8	0.9	100	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	93.6	72.8	90.7	72.7	88.2	71.9	76.7	87.4	75.5	85.0	74.4	83.2	7.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.1	128.0	80.0	72.8	122.6	79.2	71.8	118.2	78.4	40.4	87.3	39.1	85.1	38.0	83.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.8	11.3	30.0	102.1	2.4	4.5	28.3	105.3	26.9	107.9	25.6	110.4	23.9	113.7		
(5)			29.1	79.5	2.4	1.2	27.4	80.3	25.9	81.0	24.6	81.7	22.8	82.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	77.2	76.1	74.0	68.6	62.0	58.2	56.8	58.2	64.1	68.1	73.4	75.3
	DBStd	8.34	3.80	3.71	3.25	3.16	3.98	4.16	4.35	4.36	4.36	4.45	4.65	4.31
	HDD50	4	0	0	0	0	0	1	2	1	0	0	0	0
	HDD65	877	0	0	0	6	109	204	256	216	67	19	0	0
	CDD50	6438	842	731	744	559	371	248	214	256	423	562	702	786
	CDD65	1836	377	311	279	115	15	1	3	6	39	116	253	321
	CDH74	14577	3206	2482	1827	683	145	11	23	127	502	1012	1988	2571
	CDH80	4732	1229	847	488	98	5	0	1	22	120	278	705	939
Wind	WSAvg	3.7	4.3	4.5	3.9	3.5	2.8	3.2	3.1	3.4	3.6	3.9	4.2	4.1
Precipitation	PrecAvg	35.4	4.5	4.3	3.4	2.6	2.7	1.7	1.7	1.4	1.3	2.7	3.6	5.2
	PrecMax	52.2	23.6	11.7	10.4	17.8	13.3	13.7	8.3	5.3	5.0	12.8	11.3	13.3
	PrecMin	17.9	0.6	0.5	0.0	0.2	0.2	0.1	0.0	0.0	0.0	0.5	0.3	1.6
	PrecStd	9.1	3.9	3.0	2.6	3.4	3.1	2.4	1.7	1.2	1.3	2.1	2.5	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.3	95.6	93.0	85.9	80.5	75.4	76.9	82.5	89.0	91.7	95.5	96.3
		MCWB	74.7	75.6	74.1	69.8	65.0	62.1	61.6	62.1	64.2	67.5	70.4	73.2
	2%	DB	92.5	91.0	87.9	82.8	77.9	72.5	73.1	77.3	83.2	86.3	90.7	91.4
		MCWB	73.7	75.2	72.8	68.6	63.8	60.4	59.7	60.3	64.1	67.1	70.6	72.1
	5%	DB	89.6	87.9	85.1	80.3	75.3	70.3	70.5	73.8	79.1	82.8	87.1	88.2
		MCWB	73.4	73.5	71.4	67.2	62.3	59.5	58.3	58.4	62.6	65.7	69.9	71.9
	10%	DB	86.5	85.2	82.5	78.1	73.0	68.3	68.1	71.1	76.2	79.7	83.9	85.3
		MCWB	72.5	72.1	70.4	66.7	61.4	58.8	57.7	57.3	61.2	64.8	68.8	71.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	78.6	76.3	72.9	68.9	65.7	67.0	66.0	69.1	72.1	75.3	77.0
		MCDB	88.3	90.1	85.3	78.9	75.5	69.1	71.6	77.8	81.8	84.6	86.7	89.3
	2%	WB	76.8	76.8	75.0	70.9	66.3	63.7	64.3	63.6	67.2	69.8	73.5	75.2
		MCDB	87.6	87.0	82.8	78.5	73.9	68.6	69.3	71.7	76.6	79.9	85.0	86.6
	5%	WB	75.3	75.3	73.8	69.5	64.6	62.1	61.4	61.4	65.6	68.1	72.0	74.0
		MCDB	84.3	84.1	81.3	77.0	71.9	67.4	67.1	69.4	74.1	77.7	81.7	83.4
	10%	WB	73.9	73.8	72.6	68.1	63.1	60.5	59.2	59.5	63.8	66.7	70.7	72.9
		MCDB	82.5	81.9	79.7	76.1	70.3	65.8	65.4	67.8	72.4	75.9	79.8	81.0
Mean Daily Temperature Range	5% DB	MDBR	18.9	18.2	17.6	20.2	23.6	22.0	25.1	28.5	26.4	23.4	21.0	19.5
		MCDBR	24.2	22.9	22.2	23.8	26.7	24.6	28.2	31.9	31.2	29.4	26.0	24.5
		MCWBR	8.2	8.0	8.3	10.8	13.2	13.6	15.1	15.6	13.3	11.4	9.2	8.4
	5% WB	MCDBR	19.4	20.4	18.2	20.9	21.0	18.4	20.5	26.4	24.7	22.6	21.8	20.2
		MCWBR	7.4	7.9	7.7	10.1	11.3	11.1	12.6	14.1	11.2	9.5	8.5	7.7
Clear-Sky Solar Irradiance	taub	0.387	0.374	0.355	0.337	0.313	0.308	0.298	0.311	0.356	0.378	0.382	0.394	
	taud	2.484	2.532	2.581	2.608	2.629	2.636	2.651	2.591	2.459	2.429	2.459	2.450	
	Ebn at Noon	303	302	298	289	282	277	285	293	292	297	302	302	
	Edh at Noon	37	35	31	28	24	23	23	28	35	38	38	39	
All-Sky Solar Radiation	RadAvg	2053	1872	1610	1384	1152	953	1106	1390	1711	1904	2066	2058	
	RadStd	172	161	94	68	68	66	87	107	139	177	181	216	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-115	+328	+198

Nomenclature: See separate page