

BUSSELTON JETTY, AustraliaWMO: **956020**Lat: **33.631S**Lon: **115.339E**Elev: **10**StdP: **14.69**Time Zone: **8.00 (E08)**Period: **01-11**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.1	42.0	37.0	32.3	48.8	38.4	34.2	49.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.8	89.6	67.6	86.5	66.8	83.9	66.1	70.8	82.0	69.3	80.8	68.1	79.5	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	101.3	74.4	65.7	94.8	73.4	64.0	89.4	72.5	34.5	81.1	33.4	81.6	32.3	79.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	36.3	95.5	1.5	1.3	35.2	96.4	34.3	97.1	33.4	97.8	32.3	98.7		
(5)			35.8	73.6	1.9	2.1	34.4	75.2	33.4	76.4	32.3	77.6	31.0	79.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	70.3	71.3	68.1	62.5	59.5	55.6	54.2	54.5	55.4	58.5	63.4	66.6		
	DBStd	7.43	4.49	5.23	5.32	4.13	3.83	3.55	3.59	3.63	3.38	4.18	4.92	5.70		
	HDD50	13	0	0	0	0	0	2	5	4	2	0	0	0		
	HDD65	1890	8	6	30	98	177	282	334	326	287	207	87	48		
	CDD50	4245	630	596	561	374	293	169	136	142	164	264	403	513		
	CDD65	650	173	182	126	22	5	0	0	0	0	6	40	96		
	CDH74	5551	1521	1621	1021	124	7	0	0	0	3	44	329	881		
	CDH80	1650	474	546	251	12	0	0	0	0	3	78	286			
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	31.1	0.3	0.4	0.8	1.7	4.4	6.5	6.5	4.6	3.0	1.7	1.0	0.5		
	PrecMax	45.2	2.8	2.5	3.9	6.4	9.6	12.2	13.0	9.1	5.8	4.8	3.2	2.8		
	PrecMin	20.9	0.0	0.0	0.0	0.0	1.3	2.5	2.5	1.4	1.2	0.0	0.0	0.0		
	PrecStd	5.2	0.6	0.6	1.0	1.3	2.1	2.4	2.3	1.7	1.2	1.0	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.1	94.3	90.6	81.5	74.5	68.4	65.9	66.6	71.0	79.3	86.7	92.6		
		MCWB	66.7	70.2	67.3	65.3	62.3	60.0	59.4	60.8	59.3	63.5	64.5	66.5		
	2%	DB	88.3	89.4	86.0	77.4	71.6	66.4	64.0	64.7	67.0	74.0	82.0	87.0		
		MCWB	66.7	68.9	65.9	63.8	62.1	59.7	58.1	58.8	58.1	61.2	63.3	66.5		
	5%	DB	85.1	86.0	82.4	74.4	69.7	65.2	62.9	63.4	65.0	70.3	77.3	82.8		
		MCWB	66.9	67.6	65.9	63.2	61.5	58.8	57.3	57.6	57.4	59.9	62.6	65.4		
	10%	DB	82.2	83.3	79.6	71.9	68.2	63.7	61.8	62.1	63.4	67.8	74.0	78.7		
		MCWB	66.0	66.5	65.2	62.5	60.9	57.5	56.6	56.5	56.5	58.9	61.8	63.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	74.9	71.2	69.4	66.5	63.5	61.4	62.9	62.2	65.9	67.6	70.7		
		MCDB	81.9	85.8	80.6	73.6	70.1	66.1	63.9	65.0	67.1	72.0	76.2	82.6		
	2%	WB	69.8	71.5	69.5	67.4	64.8	61.6	60.0	60.7	60.1	63.7	66.1	68.3		
		MCDB	82.6	84.0	78.9	72.1	69.0	64.7	62.9	63.5	64.8	70.1	74.1	82.3		
	5%	WB	68.1	69.6	68.2	65.6	63.3	60.1	58.5	59.0	58.7	61.6	64.6	66.4		
		MCDB	81.4	82.9	78.8	71.8	68.1	63.9	61.9	62.3	63.5	68.7	74.4	80.3		
	10%	WB	66.5	68.1	66.5	63.6	61.7	58.6	57.3	57.4	57.3	59.8	63.0	64.6		
		MCDB	80.1	80.2	76.8	71.0	66.9	62.8	61.1	61.4	62.2	66.8	73.4	77.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.5	21.8	20.9	18.7	16.9	15.3	14.2	14.8	15.8	17.8	19.3	21.3		
		MCDBR	27.4	25.1	23.6	21.9	18.9	16.2	14.1	14.8	18.1	22.3	24.2	26.8		
		MCWBR	11.1	9.7	10.2	11.5	11.6	10.6	9.8	9.9	11.2	12.0	10.9	11.1		
	5% WB	MCDBR	24.0	21.0	19.8	17.4	15.9	13.6	12.1	13.2	15.9	18.1	19.4	24.2		
		MCWBR	11.6	9.7	11.2	11.3	12.1	11.0	9.9	10.3	11.3	10.9	10.6	11.1		
(40) Clear-Sky Solar Irradiance	taub	0.334	0.334	0.323	0.317	0.312	0.308	0.305	0.314	0.329	0.327	0.333	0.327			
	taud	2.592	2.603	2.633	2.643	2.625	2.615	2.627	2.587	2.525	2.546	2.552	2.592			
	Ebn at Noon	318	312	305	289	273	266	273	285	297	311	317	322			
	Edh at Noon	33	31	29	25	23	22	22	26	31	33	34	33			
(44) All-Sky Solar Radiation	RadAvg	2493	2220	1779	1266	915	735	788	1052	1413	1876	2263	2493			
	RadStd	128	91	91	75	62	47	40	62	80	97	131	122			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page