

GARDEN ISLAND, Australia

WMO: 956070

Lat: 32.243S

Lon: 115.684E

Elev: 21

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	48.1	49.6	37.5	32.9	57.5	39.3	35.4	56.9	34.2	59.0	31.8	59.3	8.7	90	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.3	90.0	67.6	86.0	67.3	82.7	67.1	73.1	79.8	71.8	78.4	70.8	77.4	10.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.0	114.2	76.8	69.6	109.0	75.9	68.4	104.4	75.0	36.8	80.0	35.6	78.4	34.7	77.5	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.1	27.5	25.3	44.2	99.3	1.5	2.2	43.1	100.9	42.2	102.2	41.4	103.5	40.3	105.1		
(5)			41.4	74.7	1.8	2.2	40.1	76.3	39.1	77.5	38.1	78.8	36.8	80.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.3	72.6	73.7	72.0	67.4	63.6	60.0	58.1	58.3	59.5	62.5	66.9	69.6	(6)
(7)		DBStd	6.95	4.93	5.15	5.09	4.16	3.64	3.16	3.23	3.18	3.51	3.98	4.80	5.34	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	971	1	1	4	19	70	151	213	207	169	98	29	9	(9)
(10)		CDD50	5584	701	662	680	523	421	301	252	258	284	388	506	608	(10)
(11)		CDD65	1082	237	243	219	92	27	2	0	1	3	21	85	152	(11)
(12)		CDH74	4863	1137	1380	1042	218	40	0	0	0	10	74	313	649	(12)
(13)		CDH80	1370	318	424	285	37	2	0	0	0	1	14	86	203	(13)
(14)	Wind	WSAvg	13.7	16.0	14.8	13.8	12.0	11.5	12.2	12.7	13.8	13.9	15.1	15.9	(14)	
(15)	Precipitation	PrecAvg	30.6	0.2	0.6	0.7	1.7	4.3	6.4	6.6	4.4	2.6	1.5	0.9	0.3	(15)
(16)		PrecMax	41.7	1.6	3.3	2.8	4.0	10.2	13.6	10.2	7.5	7.0	3.4	3.9	1.5	(16)
(17)		PrecMin	18.3	0.0	0.0	0.0	0.0	1.5	2.7	3.7	1.4	0.8	0.0	0.1	0.0	(17)
(18)		PrecStd	6.5	0.4	0.8	0.8	1.2	2.3	2.6	1.9	1.5	1.3	0.8	0.9	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.9	94.3	93.2	84.5	78.4	70.8	68.6	70.6	74.3	81.7	88.4	93.1	(19)
(20)			MCWB	68.0	68.7	68.4	64.4	62.0	58.5	59.2	59.7	59.5	63.0	64.3	67.3	(20)
(21)		2%	DB	87.6	89.5	86.6	79.3	74.2	68.8	66.4	67.5	69.6	74.6	81.7	85.3	(21)
(22)			MCWB	68.4	68.1	66.8	64.7	61.4	59.3	59.2	59.9	60.7	60.7	63.9	66.7	(22)
(23)		5%	DB	83.2	85.3	82.5	75.9	71.6	67.1	64.8	65.7	67.0	71.1	77.0	80.3	(23)
(24)			MCWB	68.8	68.3	66.3	65.2	61.5	59.2	58.1	58.8	60.0	62.3	63.7	66.9	(24)
(25)		10%	DB	79.5	81.3	79.2	73.6	69.7	65.8	63.7	63.9	65.1	68.5	73.5	76.6	(25)
(26)			MCWB	68.4	68.3	66.7	65.1	61.7	58.6	57.4	57.7	59.0	61.6	63.7	66.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.5	75.5	73.1	71.1	67.5	64.5	63.2	64.4	65.1	66.8	69.1	72.5	(27)
(28)			MADB	82.9	81.9	79.9	75.0	71.7	67.4	66.0	67.5	68.6	72.4	76.1	80.6	(28)
(29)		2%	WB	73.1	73.2	71.8	69.6	65.7	62.7	61.2	62.1	62.9	65.2	67.7	70.7	(29)
(30)			MADB	80.2	79.6	77.8	73.7	69.8	66.3	64.3	65.5	66.8	70.3	74.0	78.7	(30)
(31)		5%	WB	71.5	71.9	70.6	68.2	64.4	61.2	59.9	60.3	61.3	63.9	66.6	69.2	(31)
(32)			MADB	78.3	78.4	76.8	72.9	69.1	65.3	63.4	64.3	65.7	68.8	73.0	76.3	(32)
(33)		10%	WB	70.1	70.7	69.5	66.6	62.9	59.8	58.5	58.8	59.7	62.6	65.5	67.9	(33)
(34)			MADB	76.8	77.6	76.2	71.8	68.2	64.2	62.7	63.2	64.5	67.6	71.9	74.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.3	12.3	12.3	11.1	11.1	10.2	9.6	10.0	10.0	10.2	10.9	10.8	(35)
(36)			MCDBR	19.2	20.3	19.7	15.8	14.3	11.7	10.6	12.3	13.4	16.1	19.3	19.4	(36)
(37)			MCWBR	9.5	9.5	9.4	8.8	8.3	7.6	7.1	8.3	8.8	9.6	10.1	9.9	(37)
(38)		5% WB	MCDBR	13.7	13.0	13.1	11.5	10.9	9.0	8.5	10.0	11.1	11.9	13.2	13.8	(38)
(39)			MCWBR	8.6	7.9	8.0	7.9	8.1	7.7	7.4	8.2	8.5	8.2	8.5	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.339	0.324	0.318	0.309	0.305	0.305	0.311	0.327	0.327	0.328	0.328	(40)	
(41)		taud	2.595	2.612	2.651	2.652	2.649	2.638	2.634	2.613	2.544	2.562	2.582	2.604	(41)	
(42)		Ebn at Noon	317	311	305	291	277	271	276	289	299	312	318	322	(42)	
(43)		Edh at Noon	33	31	28	25	23	22	23	26	31	33	33	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2590	2332	1919	1388	1028	831	881	1159	1557	2041	2442	2653	(44)	
(45)		RadStd	118	83	93	83	66	57	57	60	93	83	106	103	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page