

COLLIE, Australia

WMO: 956210

Lat: 33.3608S

Lon: 116.1717E

Elev: 656

StdP: 14.35

Time Zone: 8.00 (E08)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.4	33.5	29.3	23.9	34.3	31.3	26.2	36.9	17.5	60.9	15.6	58.7	0.0	90	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.4	95.2	67.0	92.2	66.3	89.0	65.3	70.7	86.7	68.7	85.2	67.2	83.6	7.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	97.0	76.4	63.4	89.6	73.6	61.5	83.5	72.4	34.9	87.3	33.2	85.3	32.0	83.7	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.6	11.3	DB	27.7	101.7	2.0	2.2	26.3	103.3	25.1	104.6	24.0	105.8	22.5	107.4
			WB	26.8	73.9	2.0	2.9	25.3	75.9	24.2	77.6	23.0	79.3	21.6	81.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	71.4	71.4	67.3	60.6	54.7	51.0	49.6	50.8	52.5	57.4	63.3	67.6	(6)
	DBStd	9.43	5.62	5.96	6.15	5.23	4.23	4.03	4.00	3.97	4.46	5.24	6.03	6.37	(7)
	HDD50	164	0	0	0	0	8	34	57	38	24	3	0	0	(8)
	HDD65	2649	11	15	48	151	320	420	478	440	376	242	102	46	(9)
	CDD50	3719	663	600	538	318	154	64	44	62	98	233	400	545	(10)
	CDD65	732	209	196	121	20	1	0	0	0	0	7	52	126	(11)
	CDH74	9376	2641	2320	1420	281	18	0	0	1	14	162	801	1718	(12)
	CDH80	4034	1262	1062	559	62	1	0	0	1	33	290	764		(13)
(14) Wind	WSAvg	4.4	5.8	5.6	4.8	3.2	2.8	3.1	3.3	3.8	4.6	4.8	5.3	5.1	(14)
(15) Precipitation	PrecAvg	34.6	0.5	0.6	0.9	1.9	4.7	6.8	6.5	5.0	3.5	2.2	1.4	0.6	(15)
	PrecMax	52.5	3.3	3.1	5.6	4.9	10.6	16.3	15.3	10.1	8.3	5.1	4.2	2.2	(16)
	PrecMin	23.5	0.0	0.0	0.0	0.0	1.3	2.2	2.5	1.3	0.7	0.1	0.0	0.0	(17)
	PrecStd	7.0	0.7	0.7	1.2	1.3	2.2	3.0	2.7	2.0	1.7	1.1	1.0	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.0	98.6	96.5	86.5	76.7	68.7	66.2	69.6	76.0	84.2	92.9	97.9	(19)
		MCWB	67.0	69.8	65.5	63.6	60.8	56.1	55.6	55.9	58.4	62.1	64.0	66.9	(20)
	2%	DB	94.9	93.9	90.4	81.0	71.6	65.4	63.2	65.8	70.6	78.2	87.9	93.2	(21)
		MCWB	66.8	68.1	65.8	62.1	58.1	55.7	55.1	55.9	56.9	60.7	63.3	66.2	(22)
	5%	DB	91.6	90.5	86.1	76.9	68.1	63.1	61.1	62.9	66.3	74.1	82.9	88.6	(23)
		MCWB	66.8	66.6	65.2	61.6	57.5	55.2	54.6	54.8	55.9	59.7	61.9	64.2	(24)
	10%	DB	87.6	87.0	82.1	72.9	65.5	60.8	59.2	60.5	63.2	69.7	78.4	83.7	(25)
		MCWB	65.4	65.6	63.9	60.5	57.2	54.2	53.5	53.8	54.7	57.6	60.7	62.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	73.4	70.6	67.4	63.7	60.5	59.4	60.3	61.3	65.2	67.8	70.5	(27)
		MCDB	87.6	89.8	85.7	77.1	68.8	64.6	62.8	64.9	70.8	78.2	84.2	89.1	(28)
	2%	WB	70.5	70.9	68.2	65.0	61.4	58.4	57.4	58.0	59.1	62.6	65.4	67.9	(29)
		MCDB	85.6	87.5	83.6	74.7	66.7	62.5	61.0	62.9	67.0	75.3	80.4	87.6	(30)
	5%	WB	68.4	68.6	66.6	63.4	59.7	56.7	55.6	56.1	57.1	60.4	63.5	65.8	(31)
		MCDB	84.9	85.3	81.4	72.4	65.4	60.9	59.6	61.0	64.2	71.4	78.2	83.4	(32)
	10%	WB	66.4	66.8	65.0	61.8	58.1	55.1	53.9	54.6	55.4	58.6	61.9	63.9	(33)
		MCDB	83.3	83.4	78.4	70.6	63.9	59.6	58.1	59.5	61.8	68.2	76.0	80.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	28.4	28.0	26.9	25.0	23.5	21.4	20.1	20.5	21.4	23.2	25.2	27.2	(35)
		MCDBR	35.4	33.7	33.2	31.8	28.5	24.9	22.8	25.2	28.3	30.7	33.8	34.8	(36)
	5% WB	MCWBR	11.9	11.7	12.5	15.0	16.8	16.2	15.4	15.9	16.0	15.0	12.9	12.0	(37)
		MCWBR	28.4	28.2	26.7	24.1	20.8	19.7	17.8	20.6	22.4	26.1	27.9	31.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.328	0.327	0.313	0.307	0.302	0.298	0.294	0.305	0.325	0.322	0.322	0.321	(40)
		taud	2.582	2.593	2.636	2.639	2.620	2.611	2.621	2.574	2.491	2.526	2.555	2.578	(41)
	Ebn at Noon		320	314	308	293	278	270	278	289	298	312	320	324	(42)
		Edh at Noon	33	32	29	25	23	22	23	26	32	34	34	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2536	2259	1818	1291	943	769	821	1070	1438	1882	2290	2548	(44)
	RadStd		141	89	97	86	69	47	45	59	79	99	142	139	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (24 neighbors)	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page