

CUNDERDIN, AustraliaWMO: **956250**Lat: **31.6219S**Lon: **117.2217E**Elev: **217**StdP: **98.74**Time Zone: **8.00 (E08)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.7	1.9	-6.1	2.3	24.9	-3.3	2.9	18.7	12.3	16.1	11.2	16.2	1.4	70	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.6	39.3	19.7	37.4	19.3	35.5	18.8	22.4	32.0	21.2	31.9	20.4	31.3	5.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.9	25.2	18.3	13.5	24.2	17.0	12.4	23.4	66.9	32.2	62.7	31.8	59.4	31.1	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.9	8.9	DB	-1.3	43.0	0.8	1.7	-1.9	44.2	-2.4	45.1	-2.9	46.1	-3.5	47.3	(4)
			WB	-1.8	24.1	1.0	1.5	-2.5	25.2	-3.1	26.1	-3.6	26.9	-4.3	28.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	25.6	25.3	23.0	19.1	14.9	12.0	10.8	11.1	12.6	16.8	21.2	23.7
	DBStd	6.28	3.44	3.35	3.57	3.29	2.83	2.39	2.38	2.38	2.81	3.47	3.65	3.80
	HDD10.0	49	0	0	0	0	1	8	19	15	6	0	0	0
	HDD18.3	1057	1	1	4	29	113	189	233	225	173	73	13	3
	CDD10.0	2957	484	428	402	273	152	69	45	48	84	210	336	425
	CDD18.3	923	227	195	148	52	6	0	0	0	1	24	99	170
	CDH23.3	11685	2933	2399	1673	519	69	1	0	5	70	455	1324	2238
	CDH26.7	6047	1688	1321	810	171	12	0	0	1	16	162	646	1222
Wind	WSAvg	4.3	5.4	4.9	4.9	4.0	3.5	3.7	3.7	3.6	3.9	4.4	5.0	5.2
Precipitation	PrecAvg	371	14	17	17	25	49	65	61	48	31	17	14	10
	PrecMax	602	135	94	115	86	127	190	137	129	79	67	88	42
	PrecMin	202	0	0	0	0	2	5	11	17	8	0	0	0
	PrecStd	83	28	22	23	20	34	33	28	21	15	13	16	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	40.9	38.5	33.7	28.1	22.8	20.8	23.4	28.8	34.5	38.6	41.4
		MCWB	20.2	20.8	19.0	17.5	14.6	12.8	12.7	14.1	15.2	16.8	17.9	19.0
	2%	DB	39.3	38.3	36.3	30.7	25.2	20.9	18.8	20.5	25.2	31.0	35.3	38.3
		MCWB	19.9	20.2	19.0	16.8	14.4	12.7	12.7	13.6	14.3	16.4	17.4	18.8
	5%	DB	37.0	36.1	33.9	28.5	23.0	19.1	17.2	18.5	22.2	28.0	33.0	35.8
		MCWB	19.6	19.6	19.0	16.5	14.0	12.5	12.5	13.3	13.9	15.4	16.6	18.3
	10%	DB	34.7	34.0	31.2	26.3	21.1	17.5	15.9	16.8	19.9	25.6	30.5	33.3
		MCWB	19.0	19.2	18.1	15.9	13.9	12.3	12.1	12.6	13.2	14.7	16.3	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.3	24.2	21.9	20.1	18.1	16.3	15.5	16.2	16.9	18.8	20.0	21.6
		MCDB	32.4	33.0	31.1	26.7	21.5	19.2	18.0	19.8	24.9	29.1	32.6	34.0
	2%	WB	22.6	22.5	20.8	18.9	16.7	15.0	14.2	15.0	15.7	17.4	18.9	20.3
		MCDB	31.6	32.3	29.9	26.1	20.8	18.0	16.5	18.4	22.1	27.4	31.0	33.3
	5%	WB	21.4	21.2	20.0	18.0	15.8	14.0	13.4	14.0	14.7	16.4	18.0	19.3
		MCDB	32.0	32.4	29.8	25.3	20.3	17.1	16.0	17.4	20.2	25.5	29.2	32.2
	10%	WB	20.2	20.2	19.1	17.1	14.9	13.1	12.5	13.0	13.7	15.4	17.0	18.3
		MCDB	32.0	31.0	28.5	24.0	19.3	16.1	15.2	16.2	18.9	23.8	28.3	30.4
Mean Daily Temperature Range	5% DB	MDBR	15.6	15.0	14.2	13.2	12.3	11.3	10.8	12.1	14.7	16.2	15.8	16.0
		MCDBR	19.2	18.4	17.5	16.2	15.6	14.2	12.4	15.1	19.2	20.2	19.9	19.6
		MCWBR	6.3	5.9	6.2	6.5	7.5	7.9	7.7	9.1	9.8	8.3	6.8	6.7
	5% WB	MCDBR	15.3	15.6	14.3	13.0	10.9	10.4	9.6	11.9	15.6	17.0	17.0	17.3
	MCWBR	5.7	5.7	5.6	5.9	6.2	6.9	6.6	8.0	8.7	7.5	6.1	6.2	
Clear-Sky Solar Irradiance	taub	0.334	0.335	0.319	0.308	0.293	0.285	0.285	0.291	0.313	0.319	0.320	0.324	
	taud	2.505	2.514	2.544	2.557	2.579	2.590	2.590	2.572	2.484	2.491	2.507	2.503	
	Ebn at Noon	1005	985	968	926	894	877	894	933	958	990	1013	1018	
	Edh at Noon	114	109	99	88	76	71	74	85	103	111	113	115	
All-Sky Solar Radiation	RadAvg	8.16	7.37	6.14	4.56	3.46	2.87	3.03	3.90	5.17	6.63	7.81	8.42	
	RadStd	0.43	0.33	0.33	0.26	0.25	0.18	0.16	0.17	0.24	0.37	0.36	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.34	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page