

BRIDGETOWN, Australia

WMO: 956320

Lat: 33.949S

Lon: 116.131E

Elev: 179

StdP: 99.19

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.3	1.4	-0.7	3.6	6.3	0.6	4.0	6.2	7.7	15.9	6.8	15.5	0.0	150	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.9	34.8	19.1	32.8	18.7	30.7	18.3	21.7	29.0	20.5	28.1	19.6	27.2	3.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.7	23.9	18.4	13.5	22.3	17.3	12.6	21.4	64.1	29.3	59.8	27.9	56.7	27.3	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.1	5.3	-1.5	38.5	0.6	1.4	-2.0	39.5	-2.4	40.3	-2.7	41.1	-3.2	42.1		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-1.8	24.3	1.1	1.9	-2.6	25.7	-3.3	26.8	-3.9	27.9	-4.6	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	21.1	21.3	19.3	15.9	12.8	10.8	10.0	10.5	11.3	13.6	16.8	18.8	(6)
(7)		DBStd	4.97	3.33	3.41	3.52	2.94	2.33	2.21	2.17	2.15	2.40	2.81	3.33	3.51	(7)
(8)		HDD10.0	82	0	0	0	0	4	16	27	19	13	3	0	0	(8)
(9)		HDD18.3	1505	12	12	31	85	172	227	258	242	210	151	69	38	(9)
(10)		CDD10.0	1962	345	317	290	177	90	38	27	36	53	113	203	273	(10)
(11)		CDD18.3	345	98	96	62	12	1	0	0	0	0	2	22	52	(11)
(12)		CDH23.3	4201	1166	1042	677	151	11	0	0	0	7	57	334	758	(12)
(13)		CDH26.7	1763	529	462	266	36	1	0	0	0	1	10	117	343	(13)
(14)	Wind	WSAvg	2.0	2.7	2.6	2.2	1.5	1.3	1.4	1.5	1.6	1.8	2.0	2.4	2.4	(14)
(15)	Precipitation	PrecAvg	781	15	15	25	47	103	138	143	112	81	52	35	17	(15)
(16)		PrecMax	1084	110	84	123	174	227	298	293	200	165	131	138	79	(16)
(17)		PrecMin	546	0	0	0	1	34	48	60	39	26	3	6	0	(17)
(18)		PrecStd	136	22	20	27	37	46	51	53	40	33	26	25	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	36.7	35.7	30.1	25.0	20.1	18.7	20.6	23.9	28.0	33.7	36.8	(19)
(20)		MCWB	19.6	20.5	18.6	17.2	14.8	13.0	13.8	14.1	15.6	17.2	18.0	18.7	(20)	
(21)		2%	DB	34.2	34.0	32.2	27.3	22.1	18.4	17.2	18.4	20.7	24.8	30.1	33.6	(21)
(22)		MCWB	18.8	19.4	19.0	16.7	14.9	13.8	13.5	13.8	14.6	17.1	17.3	18.6	(22)	
(23)		5%	DB	31.9	31.8	29.5	24.7	20.1	17.0	16.0	16.9	18.4	22.3	27.2	30.4	(23)
(24)		MCWB	18.8	18.8	18.2	16.4	14.9	13.5	13.0	13.2	13.8	15.7	16.9	17.8	(24)	
(25)		10%	DB	29.7	29.5	27.1	22.5	18.5	15.8	14.9	15.6	16.8	20.0	24.6	27.6	(25)
(26)		MCWB	18.2	18.3	17.4	16.0	14.5	13.0	12.6	12.7	13.3	14.6	16.0	16.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.7	22.2	19.9	18.7	16.6	15.9	16.6	16.8	19.2	20.2	21.2	(27)
(28)		MCDWB	31.6	32.0	29.5	24.7	20.8	17.5	17.0	17.9	20.2	24.9	28.1	30.3	(28)	
(29)		2%	WB	21.6	21.6	20.4	18.7	17.0	15.3	14.6	15.0	15.7	17.5	18.7	19.8	(29)
(30)		MCDWB	28.5	29.0	27.2	22.5	19.1	16.7	15.9	16.6	18.7	22.9	26.2	29.4	(30)	
(31)		5%	WB	20.3	20.4	19.4	17.7	16.0	14.4	13.7	14.0	14.6	16.2	17.8	18.6	(31)
(32)		MCDWB	28.2	28.2	25.7	21.8	18.5	15.9	15.3	15.9	17.6	20.9	24.5	27.7	(32)	
(33)		10%	WB	19.1	19.3	18.4	16.9	15.1	13.4	12.7	13.0	13.6	15.2	16.9	17.5	(33)
(34)		MCDWB	27.0	26.9	24.2	20.8	17.4	15.0	14.4	15.1	16.1	18.9	23.2	25.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	15.5	14.9	14.3	13.0	12.1	10.7	10.0	10.4	11.0	12.4	13.9	15.1	(35)	
(36)		5% DB	MCDBR	19.2	18.4	17.8	16.9	15.2	12.5	11.4	12.7	14.1	16.4	18.6	20.3	(36)
(37)		MCWBR	7.0	6.5	6.8	7.9	9.1	8.5	8.1	8.4	8.5	9.0	8.0	7.4	(37)	
(38)		5% WB	MCDBR	15.9	15.6	14.5	12.9	11.5	10.2	9.6	10.5	11.9	14.0	15.5	17.5	(38)
(39)		MCWBR	7.7	7.2	7.1	7.3	8.0	8.0	7.6	7.8	8.1	8.5	8.0	7.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.327	0.316	0.308	0.302	0.301	0.296	0.306	0.326	0.324	0.326	0.323	(40)	
(41)		taud	2.581	2.593	2.622	2.636	2.624	2.605	2.618	2.572	2.491	2.518	2.545	2.575	(41)	
(42)		Ebn at Noon	1009	990	966	920	872	845	870	907	938	981	1005	1018	(42)	
(43)		Edh at Noon	105	100	91	80	71	68	70	83	101	107	108	106	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.76	6.87	5.48	3.90	2.85	2.32	2.49	3.27	4.39	5.73	6.95	7.73	(44)	
(45)		RadStd	0.46	0.30	0.33	0.25	0.21	0.14	0.12	0.18	0.23	0.34	0.43	0.43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-79	N/A	N/A

Nomenclature: See separate page