

SOUTHERN CROSS AP, Australia

WMO: 956340

Lat: 31.2353S

Lon: 119.3564E

Elev: 1141

StdP: 14.10

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.4	33.6	17.6	14.0	77.1	21.6	16.9	73.6	26.2	59.7	23.8	58.6	1.7	200	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	103.0	65.0	99.6	64.6	96.5	64.0	71.6	85.6	69.6	85.5	67.8	85.3	13.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	108.4	75.6	65.0	96.4	74.1	62.6	88.5	72.6	36.2	85.4	34.4	85.8	32.8	85.3	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.7	19.7	27.5	109.3	1.6	2.4	26.3	111.0	25.4	112.4	24.5	113.8	23.3	115.5		
(5)			26.5	73.8	1.6	2.3	25.3	75.4	24.3	76.8	23.4	78.1	22.2	79.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	78.5	77.6	72.8	65.8	57.6	52.0	50.0	51.7	56.0	63.9	70.6	75.2	(6)
(7)		DBStd	11.85	6.78	6.37	6.81	6.07	5.46	4.55	4.39	4.94	5.94	6.85	7.21	7.13	(7)
(8)		HDD50	137	0	0	0	0	5	29	55	37	11	0	0	0	(8)
(9)		HDD65	1995	2	1	12	62	239	391	464	412	278	104	25	5	(9)
(10)		CDD50	5329	885	772	706	474	239	89	56	90	189	431	618	780	(10)
(11)		CDD65	1712	422	353	253	86	8	0	0	1	7	69	193	320	(11)
(12)		CDH74	22509	5631	4330	2910	970	120	5	0	38	244	1183	2646	4432	(12)
(13)		CDH80	11699	3292	2380	1399	324	18	0	0	5	67	457	1302	2455	(13)
(14)	Wind	WSAvg	10.0	12.5	11.9	11.2	9.0	7.8	7.9	8.1	8.4	9.6	10.5	11.6	12.0	(14)
(15)	Precipitation	PrecAvg	12.7	0.9	1.0	0.9	1.2	1.5	2.0	1.6	1.3	0.8	0.6	0.8	0.6	(15)
(16)		PrecMax	22.7	4.9	5.3	6.7	4.2	4.4	7.2	3.9	5.4	2.0	2.3	2.7	2.5	(16)
(17)		PrecMin	7.2	0.0	0.0	0.0	0.0	0.1	0.6	0.2	0.4	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	3.0	1.1	1.2	1.3	1.0	1.2	1.2	0.9	0.9	0.5	0.6	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.5	106.0	100.6	92.8	81.9	73.2	70.5	79.0	87.5	95.5	101.1	105.8	(19)
(20)			MCWB	65.5	66.1	63.6	61.0	58.6	54.3	53.5	54.9	57.6	60.1	62.7	64.5	(20)
(21)		2%	DB	103.3	100.8	96.7	87.7	77.1	69.2	67.0	72.7	80.4	90.1	96.5	101.2	(21)
(22)			MCWB	65.8	66.1	64.0	61.2	56.9	53.3	52.3	54.1	55.4	59.2	61.7	63.9	(22)
(23)		5%	DB	99.6	97.2	92.2	83.6	73.4	66.1	63.8	68.4	75.6	85.1	92.4	96.9	(23)
(24)			MCWB	65.1	65.4	63.8	60.6	56.2	52.7	51.8	52.7	54.8	58.4	60.8	63.5	(24)
(25)		10%	DB	95.5	93.3	88.0	79.6	70.1	63.0	60.9	64.6	71.3	80.7	87.7	92.9	(25)
(26)			MCWB	64.7	65.3	63.3	59.9	55.7	52.3	51.5	52.1	53.9	57.4	59.3	62.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	75.0	70.0	66.6	63.4	59.9	58.3	59.4	60.9	64.5	67.3	70.1	(27)
(28)			MCDWB	85.4	85.6	81.9	78.9	71.2	64.6	62.8	67.6	77.0	81.9	85.4	87.8	(28)
(29)		2%	WB	71.6	72.3	68.0	64.5	61.2	57.6	55.8	56.9	58.5	62.0	65.0	67.8	(29)
(30)			MCDWB	86.2	84.9	82.8	77.5	68.9	62.9	60.7	65.4	73.8	80.3	84.4	87.6	(30)
(31)		5%	WB	69.8	70.0	66.5	63.0	59.5	55.7	54.2	55.2	56.8	60.3	63.5	65.9	(31)
(32)			MCDWB	86.8	84.7	82.2	76.2	68.0	61.4	59.8	63.8	70.5	79.3	84.0	87.7	(32)
(33)		10%	WB	67.7	67.8	65.1	61.5	57.7	53.9	52.6	53.3	55.1	58.7	61.8	64.3	(33)
(34)			MCDWB	87.0	84.5	81.2	74.8	66.2	60.2	58.7	62.3	68.2	76.8	82.5	87.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.8	26.2	24.8	24.6	23.7	22.4	21.7	24.7	27.7	28.4	28.1	28.9	(35)
(36)			MCDBR	33.5	31.6	30.2	29.8	28.9	27.7	27.2	32.5	35.6	35.0	33.4	33.5	(36)
(37)			MCWBR	10.0	9.7	9.8	11.6	13.6	15.1	15.5	17.0	16.1	13.0	10.8	10.3	(37)
(38)		5% WB	MCDBR	26.3	24.8	24.4	23.3	20.5	20.1	19.8	24.8	29.6	28.7	28.7	29.1	(38)
(39)			MCWBR	9.5	9.5	9.1	10.2	10.9	12.9	12.9	14.5	14.2	11.4	9.7	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.333	0.315	0.302	0.286	0.279	0.276	0.284	0.300	0.314	0.318	0.319	(40)	
(41)		taud	2.570	2.588	2.619	2.634	2.653	2.649	2.659	2.621	2.559	2.534	2.547	2.570	(41)	
(42)		Ebn at Noon	320	313	309	297	288	282	289	299	309	316	322	325	(42)	
(43)		Edh at Noon	34	32	29	26	23	22	22	26	30	34	35	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2527	2245	1929	1467	1117	928	982	1293	1727	2155	2454	2639	(44)	
(45)		RadStd	154	150	115	77	74	56	54	66	84	124	121	135	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page