

SALMON GUMS, Australia

WMO: 956390

Lat: 32.9869S

Lon: 121.6239E

Elev: 249

StdP: 98.37

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.1	1.4	-4.1	2.7	17.3	-2.6	3.1	15.9	9.9	16.2	9.1	15.7	1.1	310	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.4	37.1	18.5	34.7	17.8	32.5	17.4	20.8	30.1	19.7	28.7	19.0	27.5	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.6	22.6	17.4	12.8	21.2	16.6	12.2	20.6	61.2	30.4	57.4	28.7	54.8	27.8	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.3	8.2	-3.3	41.8	1.0	1.6	-4.0	42.9	-4.6	43.9	-5.1	44.8	-5.9	45.9		
(5)			-3.4	22.9	1.4	1.2	-4.4	23.7	-5.3	24.4	-6.0	25.1	-7.1	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	22.1	21.8	19.8	17.0	13.4	11.2	10.5	11.1	12.7	15.8	18.3	20.2	(6)
(7)		DBStd	5.38	3.60	3.67	3.89	3.54	3.15	2.52	2.51	2.94	3.41	3.86	4.05	4.00	(7)
(8)		HDD10.0	73	0	0	0	0	4	14	24	19	10	1	0	0	(8)
(9)		HDD18.3	1293	7	9	28	67	157	213	243	224	171	99	50	23	(9)
(10)		CDD10.0	2315	374	331	304	211	110	51	39	54	92	181	251	318	(10)
(11)		CDD18.3	494	122	107	74	28	4	0	0	1	4	21	51	83	(11)
(12)		CDH23.3	6068	1461	1155	808	263	40	1	0	24	92	372	720	1132	(12)
(13)		CDH26.7	2807	750	552	356	75	6	0	0	4	26	138	325	574	(13)
(14)	Wind	WSAvg	4.1	5.0	4.9	4.2	3.5	3.3	3.4	3.5	3.6	3.8	4.2	4.7	4.7	(14)
(15)	Precipitation	PrecAvg	368	39	23	38	25	31	32	38	36	29	28	27	22	(15)
(16)		PrecMax	620	171	105	157	78	77	64	68	120	69	82	80	97	(16)
(17)		PrecMin	196	1	0	4	0	7	11	8	10	2	4	0	3	(17)
(18)		PrecStd	89	47	26	36	20	19	15	16	21	18	21	20	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.4	39.1	37.1	31.7	27.4	22.2	21.5	26.4	29.9	33.6	36.9	39.4	(19)
(20)			MCWB	19.6	19.6	17.9	16.8	15.4	12.7	11.5	13.2	14.2	15.6	17.7	18.1	(20)
(21)		2%	DB	36.6	35.2	33.7	29.0	23.9	19.9	19.3	22.5	25.8	30.5	33.4	36.0	(21)
(22)			MCWB	18.5	19.0	17.9	16.7	13.8	12.2	11.3	12.1	13.8	15.3	16.3	17.8	(22)
(23)		5%	DB	33.7	32.7	30.5	26.3	21.9	18.3	17.6	19.9	23.0	27.6	30.3	32.8	(23)
(24)			MCWB	17.9	18.2	17.3	15.8	13.7	11.9	11.1	11.7	12.8	14.7	15.9	17.3	(24)
(25)		10%	DB	30.9	30.1	27.8	24.0	20.0	16.7	16.1	17.7	20.5	24.7	27.5	29.6	(25)
(26)			MCWB	18.0	18.1	16.9	15.4	13.2	11.1	10.7	11.1	12.1	14.0	15.3	16.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.2	20.3	19.2	18.1	15.2	13.9	14.8	15.7	18.0	19.4	20.9	(27)
(28)			MCDWB	32.2	31.5	28.2	26.2	21.9	18.4	17.8	20.5	25.2	27.4	29.5	31.5	(28)
(29)		2%	WB	20.8	21.1	19.4	18.0	16.5	13.9	12.9	13.6	14.6	16.4	18.2	19.1	(29)
(30)			MCDWB	30.9	29.6	27.5	23.7	20.1	17.4	16.5	18.9	22.7	25.9	27.4	29.7	(30)
(31)		5%	WB	19.6	19.7	18.7	17.1	15.0	12.9	11.9	12.6	13.7	15.5	17.2	18.0	(31)
(32)			MCDWB	28.8	28.5	26.3	22.2	19.6	16.1	15.8	17.8	20.3	24.6	26.4	29.5	(32)
(33)		10%	WB	18.7	18.8	17.9	16.3	14.0	12.0	11.2	11.7	12.8	14.6	16.2	17.1	(33)
(34)			MCDWB	27.2	26.9	24.5	21.6	18.3	15.7	14.9	16.7	19.4	22.9	25.1	27.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.4	14.5	13.9	13.3	12.6	11.0	10.9	12.5	14.4	15.2	15.5	15.9	(35)
(36)			MCDBR	20.4	18.7	17.9	16.1	14.9	13.0	13.3	16.3	18.7	19.7	19.9	20.8	(36)
(37)			MCWBR	5.8	5.3	5.4	6.3	7.3	7.4	7.3	8.1	8.2	7.3	6.2	6.0	(37)
(38)		5% WB	MCDWB	15.9	15.3	13.6	12.2	11.6	10.2	10.7	13.0	15.6	16.6	16.7	17.7	(38)
(39)			MCWBR	5.7	5.4	5.0	5.5	6.7	6.7	6.7	7.4	7.5	6.8	5.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.340	0.320	0.310	0.294	0.283	0.283	0.292	0.309	0.322	0.328	0.329	(40)	
(41)		taud	2.540	2.561	2.600	2.618	2.636	2.642	2.639	2.599	2.537	2.522	2.528	2.553	(41)	
(42)		Ebn at Noon	995	978	964	921	888	874	892	928	960	985	1003	1013	(42)	
(43)		Edh at Noon	110	104	93	82	71	66	70	82	97	107	110	109	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.51	6.60	5.45	4.12	3.08	2.63	2.85	3.75	5.02	6.19	7.08	7.78	(44)	
(45)		RadStd	0.43	0.47	0.35	0.22	0.18	0.11	0.15	0.19	0.20	0.40	0.46	0.48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.23	N/A	N/A	N/A	N/A	N/A	N/A	-60	+93	+44

Nomenclature: See separate page