

WANDERING, Australia

WMO: 956400

Lat: 32.6724S

Lon: 116.6700E

Elev: 904

StdP: 14.22

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 31.2	(c) 33.3	(d) 27.3	(e) 22.0	(f) 57.5	(g) 29.5	(h) 24.3	(i) 51.7	(j) 18.3	(k) 58.7	(l) 16.6	(m) 59.3	(n) 2.5	(o) 330	(p) 0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 28.7	(c) 98.3	(d) 65.3	(e) 94.7	(f) 64.7	(g) 91.4	(h) 64.0	(i) 69.8	(j) 86.6	(k) 67.9	(l) 85.6	(m) 66.4	(n) 84.1	(o) 9.0	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	96.4	73.3	62.8	88.4	72.2	61.0	82.7	70.6	34.3	86.5	32.7	84.7	31.5	83.8	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.6	(b) 17.1	(c) 14.9	(e) 27.9	(f) 104.7	(g) 2.3	(h) 3.3	(i) 26.2	(j) 107.1	(k) 24.8	(l) 109.0	(m) 23.5	(n) 110.9	(o) 21.9	(p) 113.3		
			DB													
			WB													
				27.3		2.5	3.1	25.5	75.1	24.1	77.0	22.7	78.7	20.9	81.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	73.4	73.0	68.9	61.9	54.8	51.0	49.3	50.0	52.0	57.4	65.2	69.8		
	DBStd	10.39	5.71	6.07	6.53	5.77	4.55	4.35	4.19	4.10	4.60	5.72	6.48	6.57		
	HDD50	200	0	0	0	0	10	38	65	52	30	5	0	0		
	HDD65	2600	6	10	36	127	316	419	486	465	390	245	76	24		
	CDD50	4031	725	643	585	356	160	69	44	52	90	235	457	615		
	CDD65	957	266	233	156	33	1	0	0	0	0	10	83	175		
	CDH74	12572	3401	2892	1877	431	26	0	0	1	21	240	1293	2390		
	CDH80	5853	1739	1436	808	107	1	0	0	0	2	60	541	1159		
(14) Wind	WSAvg	7.0	9.2	8.8	7.8	5.6	5.3	5.6	5.5	5.8	6.4	6.9	8.1	8.5		
(15) Precipitation	PrecAvg	22.2	0.6	0.6	0.7	1.4	2.7	4.0	4.2	3.3	2.1	1.3	0.8	0.5		
	PrecMax	31.3	6.1	2.6	3.7	3.9	5.8	9.7	8.7	5.7	4.2	5.1	2.0	3.3		
	PrecMin	14.3	0.0	0.0	0.0	0.0	0.5	0.7	1.5	0.8	0.7	0.0	0.0	0.0		
	PrecStd	3.9	1.2	0.7	0.8	1.1	1.4	1.9	1.8	1.2	0.9	0.9	0.6	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.2	101.6	98.3	88.6	77.4	68.6	65.7	69.8	76.8	86.4	96.4	101.7		
		MCWB	66.7	66.6	64.5	61.8	57.2	54.1	55.3	56.4	58.4	62.0	62.6	64.9		
	2%	DB	97.7	96.7	92.7	82.8	72.8	65.4	62.7	65.3	70.9	80.1	90.9	96.4		
		MCWB	65.5	66.0	64.8	61.2	56.1	54.5	53.9	55.1	57.7	60.5	61.3	64.5		
	5%	DB	93.6	92.7	88.3	79.0	69.3	62.9	60.7	62.4	66.5	75.6	86.5	91.6		
		MCWB	65.1	65.7	64.0	60.1	56.3	54.3	53.6	54.7	56.1	59.1	60.9	63.0		
	10%	DB	89.8	89.0	84.2	75.1	66.1	60.6	58.6	59.9	63.2	71.3	81.8	86.6		
		MCWB	64.0	64.8	63.0	59.4	55.7	53.5	52.9	53.4	54.7	57.3	59.4	61.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	72.8	70.0	66.6	62.5	60.1	58.5	59.6	61.5	64.4	65.8	68.3		
		MCDB	87.1	83.7	84.7	75.2	67.7	63.3	61.6	64.7	71.1	78.4	85.8	89.1		
	2%	WB	70.0	69.7	68.0	64.6	60.6	58.0	56.3	57.4	59.3	62.0	64.1	66.3		
		MCDB	85.3	88.8	81.7	74.7	66.1	61.8	59.7	62.6	67.9	75.8	81.9	88.0		
	5%	WB	67.7	67.6	66.4	62.9	59.0	56.3	54.7	55.8	57.1	60.2	62.6	64.7		
		MCDB	86.1	87.0	81.5	73.1	65.1	60.4	58.5	60.7	64.9	72.5	80.3	85.5		
	10%	WB	65.7	66.1	64.7	61.3	57.3	54.6	53.3	54.2	55.4	58.5	61.0	63.0		
		MCDB	84.3	84.3	78.9	71.5	63.5	58.6	57.6	58.9	62.2	69.4	77.7	82.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	28.7	28.1	26.4	24.7	23.4	20.1	19.0	20.0	22.5	25.7	27.9	28.0		
		MCDBR	35.8	35.1	33.1	31.6	29.9	23.5	21.3	24.4	29.7	33.3	36.6	36.2		
		MCWBR	10.9	10.9	11.2	13.7	15.8	14.7	14.3	15.7	17.3	15.2	11.9	10.8		
	5% WB	MCDBR	28.2	29.1	25.5	22.4	19.7	18.2	17.9	20.2	25.0	28.1	30.4	31.4		
		MCWBR	10.2	10.3	9.5	10.9	12.5	13.0	12.8	13.9	15.2	14.0	11.2	10.6		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.326	0.313	0.304	0.295	0.290	0.288	0.295	0.316	0.318	0.319	0.317		
	taud		2.545	2.574	2.600	2.614	2.612	2.612	2.611	2.585	2.492	2.513	2.533	2.562		
	Ebn at Noon		320	315	308	295	281	275	281	293	302	314	321	325		
	Edh at Noon		35	32	30	26	23	22	23	26	32	34	35	34		
(44) All-Sky Solar Radiation	RadAvg		2576	2308	1882	1353	1003	822	872	1124	1506	1972	2381	2620		
	RadStd		137	88	97	89	69	49	54	59	85	106	132	136		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page