

FORREST, Australia

WMO: 956460

Lat: 30.8453S

Lon: 128.1092E

Elev: 160

StdP: 99.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.1	3.3	-10.1	1.6	24.7	-7.8	2.0	22.7	14.3	15.3	13.0	15.9	3.2	50	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.9	40.9	18.8	38.6	18.4	36.1	17.9	22.7	30.4	21.5	29.9	20.5	29.4	6.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	15.9	24.2	19.3	14.3	23.1	18.1	13.3	22.0	68.1	30.8	63.2	29.6	59.5	29.7	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.6	11.3	10.2	-0.2	44.3	1.0	1.7	-1.0	45.5	-1.6	46.6	-2.1	47.5	-2.9	48.8		
			-1.6	24.9	1.5	1.8	-2.7	26.1	-3.6	27.2	-4.4	28.1	-5.5	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	24.3	23.9	21.7	18.8	15.1	12.3	11.7	13.1	15.9	18.8	21.1	23.0
	DBStd	5.57	3.87	3.81	3.70	3.10	2.83	2.23	2.31	2.95	3.60	4.10	4.09	3.82
	HDD10.0	13	0	0	0	0	0	3	7	3	1	0	0	0
	HDD18.3	856	1	1	8	31	108	183	204	164	93	44	16	3
	CDD10.0	3037	444	390	363	264	159	71	61	100	176	272	333	402
	CDD18.3	840	187	158	113	45	9	1	1	3	19	59	99	147
	CDH23.3	10931	2281	1779	1317	575	153	10	16	124	401	966	1411	1900
	CDH26.7	5805	1331	1006	681	227	42	1	1	30	159	491	767	1070
Wind	WSAvg	5.5	6.4	6.2	5.5	4.8	4.4	4.6	5.0	5.2	5.6	6.1	6.2	6.3
Precipitation	PrecAvg	200	14	20	17	19	18	16	13	16	16	14	17	20
	PrecMax	338	106	143	116	98	73	79	51	80	83	84	64	109
	PrecMin	84	0	0	0	0	0	0	1	0	0	0	0	0
	PrecStd	68	23	27	24	22	17	16	11	16	18	16	16	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	42.6	40.0	34.9	30.6	24.7	25.1	30.0	34.7	38.7	41.1	42.2
		MCWB	19.9	19.9	18.1	16.8	15.1	14.1	12.5	13.2	15.1	16.8	17.8	19.0
	2%	DB	40.7	39.6	36.9	32.0	27.3	22.1	22.6	26.8	31.2	35.5	37.8	39.2
		MCWB	19.0	19.6	18.0	16.6	14.9	12.7	11.8	12.6	14.6	16.2	17.5	18.2
	5%	DB	37.2	36.2	33.8	29.2	24.5	20.2	20.5	24.0	27.9	32.1	34.4	36.0
		MCWB	18.9	19.1	17.6	15.7	14.2	12.2	11.6	12.2	13.8	15.5	16.7	17.9
	10%	DB	33.9	33.0	30.2	26.7	22.0	18.7	18.5	21.0	25.0	28.8	31.0	32.8
		MCWB	18.7	19.2	17.2	15.6	13.3	11.8	10.9	11.3	13.2	14.7	16.4	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	24.7	22.3	20.2	18.2	16.8	15.8	15.6	18.0	19.5	20.7	23.1
		MCDB	30.3	32.2	28.2	26.9	23.3	20.4	19.5	21.7	25.4	29.3	29.6	29.7
	2%	WB	22.4	23.0	20.9	18.9	17.0	15.0	13.9	14.3	16.1	17.9	19.4	21.3
		MCDB	31.6	31.0	28.5	24.8	22.4	19.1	18.6	21.5	26.3	28.9	30.1	29.6
	5%	WB	21.0	21.6	19.9	18.0	15.9	13.6	12.7	13.2	14.9	16.7	18.4	20.1
		MCDB	31.0	29.5	27.4	23.6	20.8	17.7	17.6	20.7	24.6	28.1	29.3	30.0
	10%	WB	19.9	20.3	18.8	17.0	14.8	12.7	11.8	12.2	13.9	15.6	17.4	18.9
		MCDB	29.9	28.6	25.6	23.5	19.9	16.9	16.7	19.3	23.0	26.5	28.0	28.4
Mean Daily Temperature Range	5% DB	MDBR	15.9	14.9	14.3	14.2	13.3	13.0	13.3	14.8	15.9	16.6	16.3	16.2
		MCDBR	21.7	20.7	20.1	18.5	17.2	15.7	16.8	19.5	20.8	22.0	21.8	21.7
		MCWBR	5.8	5.7	6.3	7.0	7.6	8.4	8.8	8.9	7.9	7.7	6.6	6.4
	5% WB	MCDBR	15.9	14.6	13.9	13.4	12.5	12.2	13.1	15.3	17.1	18.1	17.5	16.4
		MCWBR	5.9	5.7	5.8	6.1	6.7	7.5	8.0	8.0	7.3	6.9	6.3	6.3
Clear-Sky Solar Irradiance	taub	0.362	0.364	0.340	0.327	0.306	0.291	0.294	0.304	0.334	0.345	0.355	0.351	
	taud	2.457	2.472	2.521	2.544	2.569	2.595	2.569	2.524	2.434	2.417	2.426	2.462	
	Ebn at Noon	978	957	948	909	881	875	887	921	937	965	978	991	
	Edh at Noon	120	114	102	90	78	72	77	90	109	119	123	120	
All-Sky Solar Radiation	RadAvg	7.64	6.85	5.73	4.48	3.47	3.00	3.28	4.25	5.54	6.71	7.41	7.90	
	RadStd	0.61	0.62	0.40	0.26	0.23	0.13	0.20	0.22	0.34	0.33	0.41	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page