

NORTH WALPOLE, Australia

WMO: 956470

Lat: 34.9469S

Lon: 116.7222E

Elev: 74

StdP: 100.45

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.6	7.4	2.8	4.7	11.1	3.6	4.9	10.7	10.8	12.4	9.8	12.9	1.9	310	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.3	29.0	20.0	26.7	19.4	25.0	18.7	21.1	26.8	20.2	24.9	19.5	23.5	4.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.2	22.6	18.6	13.6	21.9	18.0	13.0	21.3	61.4	27.0	58.4	24.9	55.8	23.5	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.3	7.4	4.5	35.4	1.0	2.4	3.8	37.1	3.3	38.5	2.7	39.8	2.0	41.6		
			3.9	22.7	0.7	0.8	3.3	23.2	2.9	23.7	2.5	24.1	2.0	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	18.8	19.3	18.5	16.5	14.9	13.3	12.2	12.4	12.9	14.2	15.8	17.1		
	DBStd	3.30	2.42	2.41	2.63	2.42	2.03	1.78	1.71	1.89	2.15	2.23	2.51	2.28		
	HDD10.0	6	0	0	0	0	0	1	2	2	1	0	0	0		
	HDD18.3	1192	21	14	27	66	108	152	189	183	164	130	86	52		
	CDD10.0	2004	273	260	265	195	152	98	72	78	88	131	173	221		
	CDD18.3	148	35	41	34	11	2	0	0	0	1	2	9	14		
	CDH23.3	829	213	197	184	43	5	0	0	0	6	14	62	104		
(14) Wind	WSAvg	3.7	3.8	3.8	3.6	3.2	3.2	3.7	3.9	3.9	4.0	3.7	3.6	3.6		
	PrecAvg	1175	24	25	46	81	141	178	203	168	138	81	60	38		
	PrecMax	1393	109	78	112	164	238	293	339	260	273	127	167	117		
	PrecMin	804	2	4	8	15	75	92	111	80	54	41	15	8		
	PrecStd	153	24	18	26	42	45	48	57	42	55	26	34	26		
	DB	31.5	31.0	31.9	27.7	23.9	20.2	18.9	21.1	23.4	25.2	29.2	29.5			
	MCWB	22.3	21.0	20.1	18.0	15.9	15.0	13.9	14.1	15.5	17.1	18.4	20.3			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	28.0	27.7	27.5	24.2	21.4	18.6	17.5	18.7	20.1	22.1	24.7	26.1			
	2% MCWB	21.0	20.2	19.1	17.6	15.5	13.9	13.5	13.8	15.0	16.8	18.5	19.7			
	5% DB	25.5	25.5	24.8	22.1	19.9	17.5	16.4	17.2	18.2	19.9	22.1	23.6			
	5% MCWB	19.5	19.3	18.6	17.0	15.2	13.5	13.1	13.2	14.3	15.8	17.3	18.3			
	10% DB	23.5	23.8	22.8	20.5	18.5	16.4	15.4	15.9	16.8	18.3	20.3	21.7			
	10% MCWB	18.5	18.5	17.9	16.5	14.8	13.0	12.6	12.8	13.5	14.9	16.3	17.0			
	WB	23.1	22.0	21.3	19.6	18.1	16.3	15.7	16.1	17.4	19.0	20.4	21.6			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	29.8	28.3	27.4	23.3	21.1	18.3	17.1	18.7	20.7	22.7	25.5	27.9			
	2% WB	21.3	20.7	20.2	18.6	16.9	15.2	14.5	14.9	15.8	17.4	18.9	20.0			
	2% MCDB	26.7	26.0	24.7	22.1	19.2	17.1	16.3	17.2	18.8	20.9	23.4	25.0			
	5% WB	20.0	19.8	19.3	17.8	16.1	14.5	13.7	13.8	14.8	16.2	17.8	18.7			
	5% MCDB	24.5	24.2	23.1	20.8	18.4	16.4	15.6	16.1	17.7	19.1	21.4	22.6			
	10% WB	19.0	19.1	18.6	17.0	15.4	13.8	12.9	13.1	13.8	15.2	16.6	17.6			
	10% MCDB	22.9	22.7	21.7	19.7	17.7	15.7	14.8	15.4	16.4	17.8	19.8	20.9			
(35) Mean Daily Temperature Range	MDBR	8.6	8.3	8.1	7.4	6.8	6.0	5.9	6.4	7.1	7.5	8.1	8.3			
	5% DB MCDBR	12.4	12.1	12.5	10.1	9.1	7.5	7.3	8.6	9.6	10.9	11.8	12.3			
	5% WB MCWBR	6.4	5.7	5.8	5.2	5.1	4.7	4.6	5.1	5.6	6.7	6.8	6.8			
	5% DB MCDBR	11.5	10.7	9.9	8.6	7.2	6.4	6.1	7.2	8.9	10.0	11.0	11.3			
	5% WB MCWBR	6.3	5.3	5.2	4.9	4.7	4.7	4.6	5.0	5.6	6.5	6.6	6.5			
(40) Clear-Sky Solar Irradiance	taub	0.340	0.340	0.329	0.318	0.309	0.306	0.305	0.314	0.333	0.330	0.339	0.334			
	taud	2.579	2.591	2.619	2.647	2.642	2.630	2.625	2.592	2.522	2.547	2.544	2.582			
	Ebn at Noon	996	975	950	905	859	834	854	895	929	973	991	1006			
	Edh at Noon	105	100	91	78	69	66	69	81	98	103	108	106			
(44) All-Sky Solar Radiation	RadAvg	7.34	6.40	5.05	3.66	2.68	2.17	2.35	3.16	4.28	5.57	6.64	7.33			
	RadStd	0.49	0.34	0.34	0.21	0.18	0.12	0.11	0.16	0.18	0.34	0.39	0.40			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-79	N/A	N/A

Nomenclature: See separate page