

WUDINNA, Australia

WMO: 956540

Lat: 33.0431S

Lon: 135.4519E

Elev: 87

StdP: 100.29

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.3	2.8	-10.0	1.6	29.8	-7.2	2.1	28.8	13.2	15.4	12.1	14.8	1.5	40	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	40.7	18.2	38.4	17.8	36.1	17.4	21.2	30.1	20.2	30.7	19.3	30.0	6.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.1	23.0	17.7	12.8	22.2	16.3	11.7	21.2	62.1	28.8	58.5	30.3	55.4	29.8	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature										
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years				
							Min	Max	Min	Max	Min	Max	Min	Max			
1%	2.5%	5%	(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	10.9	9.6	DB	-1.1	44.5	1.2	1.6	-2.0	45.6	-2.7	46.6	-3.4	47.5	-4.2	48.7		
				WB	-1.5	22.7	1.2	1.5	-2.4	23.8	-3.1	24.6	-3.8	25.4	-4.7	26.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	24.1	23.4	21.0	18.1	14.5	11.7	11.4	11.8	14.3	17.1	19.9	22.0	
	DBStd	5.89	4.48	4.32	4.15	3.72	3.08	2.37	2.30	2.92	3.74	4.37	4.67	4.70	
	HDD10.0	36	0	0	0	0	1	9	11	12	2	1	0	0	
	HDD18.3	1077	2	4	17	49	127	199	215	205	134	79	34	13	
	CDD10.0	2741	438	376	342	243	141	61	54	67	129	219	297	373	
	CDD18.3	741	182	147	100	42	8	1	0	1	12	39	82	128	
	CDH23.3	10550	2544	1924	1303	530	59	2	1	20	211	711	1291	1954	
CDH26.7	5681	1519	1101	658	196	9	0	0	2	62	318	688	1128		
Wind	WSAvg	4.7	5.0	4.6	4.4	4.1	4.2	4.2	4.7	4.7	4.8	5.1	5.0	5.0	
Precipitation	PrecAvg	321	16	17	16	18	28	44	43	41	33	23	20	23	
	PrecMax	558	118	78	60	47	61	89	80	79	76	77	53	103	
	PrecMin	153	0	0	0	0	3	14	10	5	2	1	1	0	
	PrecStd	74	23	20	17	14	14	20	17	21	21	21	14	23	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	42.5	39.6	35.4	28.1	22.1	22.1	25.8	31.8	36.1	40.5	42.7	
		MCWB	19.4	19.8	17.3	17.0	14.5	12.4	12.1	12.5	14.1	15.6	16.9	18.6	
	2%	DB	41.1	39.1	35.8	31.3	25.0	19.4	19.2	22.6	28.3	33.1	36.6	39.4	
		MCWB	18.6	18.9	17.1	15.6	13.5	11.7	11.2	12.0	13.3	15.0	16.4	17.6	
	5%	DB	38.0	36.9	33.2	28.6	22.5	17.7	17.4	20.2	25.7	30.2	33.8	36.5	
		MCWB	18.0	18.3	17.1	15.0	12.9	11.5	11.1	11.4	12.7	14.2	15.8	17.0	
	10%	DB	34.8	33.5	30.4	26.4	20.4	16.2	16.0	17.9	23.0	27.4	30.7	33.2	
		MCWB	17.7	17.6	16.4	14.3	12.7	11.4	10.8	10.8	12.1	13.3	15.1	16.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	22.7	21.7	19.0	16.3	14.9	14.2	14.9	15.7	17.8	20.3	21.6
			MCDB	29.1	32.4	27.8	24.2	21.9	18.7	16.8	20.0	26.3	28.8	27.3	28.6
2%		WB	20.9	21.3	20.2	17.6	15.3	13.6	13.1	13.6	14.5	16.3	18.4	20.1	
		MCDB	32.9	29.8	27.9	24.6	20.0	16.4	16.1	18.4	23.4	27.2	28.5	29.8	
5%		WB	20.0	20.0	19.0	16.7	14.6	12.9	12.3	12.6	13.7	15.3	17.4	18.8	
		MCDB	32.9	30.7	27.6	24.3	18.9	15.5	15.5	17.5	22.1	25.7	29.1	30.0	
10%		WB	19.0	19.0	17.9	15.8	13.8	12.2	11.6	11.8	12.8	14.5	16.4	17.6	
		MCDB	31.2	30.0	26.4	22.9	18.3	14.9	14.8	16.4	20.3	24.1	27.9	29.4	
Mean Daily Temperature Range	5% DB	MDBR	16.6	15.9	15.1	14.2	11.1	9.7	9.5	11.9	14.4	16.4	16.7	16.7	
		MCDBR	21.2	20.4	18.9	17.3	13.6	11.3	11.3	15.5	18.9	20.5	20.9	21.5	
		MCWBR	5.8	5.6	5.7	6.1	5.7	6.1	5.8	7.1	7.3	7.2	6.7	6.5	
	5% WB	MCDBR	15.6	15.4	14.0	13.3	10.1	8.2	9.2	12.4	15.7	17.1	16.5	15.7	
		MCWBR	5.4	5.0	5.0	5.5	5.4	5.4	5.7	6.9	6.9	6.8	6.1	6.3	
Clear-Sky Solar Irradiance	taub		0.342	0.342	0.324	0.315	0.306	0.295	0.295	0.302	0.331	0.342	0.344	0.334	
	taud		2.507	2.528	2.560	2.569	2.569	2.587	2.583	2.547	2.459	2.431	2.458	2.514	
	Ebn at Noon		996	976	959	914	869	856	875	914	936	964	987	1008	
	Edh at Noon		113	107	97	86	76	70	74	86	105	117	118	113	
All-Sky Solar Radiation	RadAvg		7.87	7.04	5.77	4.27	3.08	2.61	2.81	3.72	5.04	6.35	7.25	7.79	
	RadStd		0.37	0.39	0.32	0.27	0.13	0.12	0.12	0.22	0.34	0.43	0.35	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+95	+51

Nomenclature: See separate page