

MINLATON, Australia

WMO: 956590

Lat: 34.7481S

Lon: 137.5275E

Elev: 33

StdP: 100.94

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	4.6	-2.9	3.0	25.7	-0.8	3.5	22.3	15.9	12.4	14.4	13.5	3.7	80	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	38.0	19.5	35.8	18.8	33.5	18.2	22.0	31.5	20.8	29.7	19.8	29.1	6.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	14.6	24.0	18.2	13.1	22.9	17.0	12.1	22.0	64.6	30.7	60.3	29.3	56.7	29.2	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.2	13.0	11.4	1.6	42.0	0.8	1.8	1.0	43.3	0.5	44.4	0.0	45.4	-0.6	46.7		
(5)			1.2	23.2	0.9	1.8	0.6	24.6	0.1	25.6	-0.4	26.7	-1.1	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	22.7	22.0	20.2	17.6	14.6	12.0	11.2	11.4	13.2	16.0	18.7	20.6		
	DBStd	5.37	4.58	4.17	3.74	3.06	2.44	2.09	1.86	2.33	2.96	4.29	4.58	4.74		
	HDD10.0	27	0	0	0	0	0	5	9	10	2	1	0	0		
	HDD18.3	1165	6	6	19	49	121	191	222	216	157	102	51	25		
	CDD10.0	2452	393	337	317	228	142	64	46	53	99	186	260	329		
	CDD18.3	549	141	109	78	27	4	1	0	0	3	29	61	96		
	CDH23.3	6509	1746	1228	796	237	29	4	0	4	41	383	762	1279		
	CDH26.7	3251	963	627	352	70	6	1	0	1	5	160	367	700		
(14) Wind	WSAvg	6.2	6.8	6.7	6.3	5.7	5.8	5.6	5.9	5.8	6.1	6.3	6.4	6.6		
(15) Precipitation	PrecAvg	405	13	16	16	32	47	55	60	52	44	33	20	18		
	PrecMax	613	64	97	58	106	106	158	118	100	101	84	69	84		
	PrecMin	265	1	0	0	0	5	9	22	16	15	2	0	1		
	PrecStd	86	14	22	16	27	24	29	23	22	22	23	16	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	39.2	36.9	31.8	27.0	22.1	20.1	23.1	27.2	34.3	37.7	40.7		
		MCWB	20.1	20.3	18.9	17.2	14.5	14.0	12.8	13.4	14.7	17.8	18.7	19.5		
	2%	DB	38.3	36.2	33.2	28.6	23.0	18.5	17.3	19.9	24.2	31.0	34.3	36.9		
		MCWB	19.7	19.8	18.1	15.8	14.1	12.7	11.5	12.4	14.0	16.6	17.9	19.0		
	5%	DB	35.5	33.7	30.7	26.0	20.7	16.8	15.8	17.6	21.8	27.7	31.3	34.0		
		MCWB	19.1	19.1	17.9	15.5	13.8	12.6	11.6	11.9	13.2	15.0	16.7	17.9		
	10%	DB	32.4	30.7	28.2	23.7	18.9	15.7	14.8	15.7	19.4	24.4	28.0	30.6		
		MCWB	18.4	18.4	17.2	14.9	13.6	12.4	11.6	11.6	12.9	14.4	16.0	17.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	23.5	22.0	18.9	16.9	15.7	14.6	14.9	17.1	20.7	21.6	23.1		
		MCDB	30.2	34.3	28.1	23.9	20.8	18.1	16.6	18.7	22.7	29.1	30.4	33.2		
	2%	WB	21.7	21.7	20.4	17.9	16.0	14.3	13.5	13.9	15.5	17.3	19.2	20.7		
		MCDB	32.5	30.6	27.9	22.5	19.1	16.3	15.1	17.0	21.0	26.3	29.5	29.4		
	5%	WB	20.5	20.4	19.3	17.0	15.2	13.6	12.7	13.1	14.4	16.0	18.0	19.3		
		MCDB	31.0	28.9	26.6	22.2	18.3	15.8	14.5	15.8	19.1	23.4	27.2	29.0		
	10%	WB	19.3	19.4	18.3	16.2	14.5	12.9	12.1	12.4	13.5	15.1	16.9	18.1		
		MCDB	29.8	27.9	25.7	21.6	17.7	15.1	14.0	14.9	17.8	22.1	25.2	27.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	11.9	11.3	10.4	8.5	7.4	7.4	8.9	10.5	12.3	12.9	13.0		
		MCDBR	17.8	16.3	15.2	13.5	11.2	8.6	8.6	11.5	14.4	16.9	17.2	18.3		
		MCWBR	5.3	5.0	4.9	5.3	5.5	5.2	5.3	6.3	6.6	6.4	5.7	5.4		
	5% WB	MCDBR	13.9	12.8	12.5	10.4	8.1	6.8	6.8	8.9	11.6	14.0	14.1	13.9		
		MCWBR	5.5	5.1	5.4	5.3	5.1	4.9	5.1	5.9	6.5	6.3	5.8	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.343	0.324	0.317	0.310	0.301	0.300	0.308	0.334	0.340	0.346	0.338		
	taud		2.537	2.559	2.609	2.614	2.614	2.629	2.622	2.582	2.495	2.480	2.487	2.538		
	Ebn at Noon		992	972	956	906	857	840	861	902	928	963	983	1002		
	Edh at Noon		110	103	91	81	71	66	69	82	101	110	115	110		
(44) All-Sky Solar Radiation	RadAvg		7.62	6.69	5.40	3.95	2.75	2.28	2.48	3.41	4.65	5.96	7.03	7.46		
	RadStd		0.37	0.30	0.20	0.22	0.12	0.12	0.10	0.20	0.34	0.36	0.34	0.28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-92	+157	+69

Nomenclature: See separate page