

SNOWTOWN, Australia

WMO: 956700

Lat: 33.7675S

Lon: 138.2183E

Elev: 358

StdP: 14.51

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	34.7	19.9	15.1	79.5	23.9	18.3	78.7	32.2	58.9	29.5	58.6	5.3	0	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.6	103.6	65.5	99.4	64.3	95.0	63.1	70.2	85.1	68.6	84.6	66.9	84.0	15.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.9	100.4	73.4	64.3	91.3	72.2	62.0	84.3	70.9	34.4	85.7	33.0	84.3	31.6	84.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.8	25.3	22.2	DB	29.4	110.0	1.7	2.7	28.2	112.0	27.2	113.5	26.2	115.1	24.9	117.0	(4)
(5)			WB	28.6	73.4	1.8	2.1	27.3	74.9	26.2	76.2	25.2	77.3	23.9	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	73.5	72.3	68.5	63.2	56.4	51.2	49.9	50.4	54.5	60.3	65.8	69.7		
	DBStd	10.49	7.82	7.51	7.21	6.17	4.80	4.05	3.79	4.42	5.33	7.04	7.83	7.99		
	HDD50	141	0	0	0	0	3	32	48	47	10	1	0	0		
	HDD65	2393	8	11	39	109	271	413	467	453	318	186	84	34		
	CDD50	4250	728	626	575	395	201	70	46	59	145	320	475	610		
	CDD65	1025	271	217	149	53	4	0	0	0	3	40	109	179		
	CDH74	15133	3777	2843	1953	716	56	1	0	7	147	909	1874	2850		
(13)	CDH80	8021	2191	1580	959	252	6	0	0	1	32	391	986	1623		
(14)	Wind	WSAvg	10.9	12.1	11.6	10.5	9.8	10.2	10.4	11.1	10.5	11.1	11.3	11.8		
(15) Precipitation	PrecAvg	16.3	0.8	0.7	0.7	1.1	1.7	2.0	2.3	1.9	1.9	1.5	1.0	0.7		
	PrecMax	25.4	4.5	4.6	3.3	4.0	4.2	5.0	4.3	3.7	4.8	4.6	2.9	2.4		
	PrecMin	8.2	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.5	0.1	0.0	0.0	0.0		
	PrecStd	4.0	1.0	1.0	0.7	1.0	1.0	1.3	1.1	0.9	1.1	1.2	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.2	106.6	101.1	93.5	79.9	68.4	67.2	73.9	84.2	96.0	102.2	106.9		
		MCWB	66.8	67.4	64.4	62.8	57.5	55.3	53.3	55.6	58.0	60.5	63.7	65.6		
	2%	DB	104.5	100.4	95.0	86.6	74.5	64.5	63.0	68.4	77.8	89.6	96.1	101.8		
		MCWB	65.8	65.7	63.5	59.9	56.2	53.1	52.6	53.5	56.1	58.3	62.0	63.7		
	5%	DB	98.8	95.9	90.4	82.1	70.2	61.7	60.2	64.0	73.4	84.0	91.5	95.6		
		MCWB	64.6	64.8	63.1	58.6	55.3	52.9	51.8	53.3	55.3	57.2	61.5	62.2		
	10%	DB	92.3	90.5	84.9	77.5	66.6	59.3	58.1	60.4	68.3	78.4	85.6	89.6		
		MCWB	63.7	64.1	61.8	57.6	55.0	52.3	51.4	51.8	54.1	56.1	59.5	61.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.1	73.5	70.5	66.1	61.2	58.3	57.2	59.0	61.6	63.5	68.7	70.9		
		MCDB	83.6	92.2	81.1	71.6	71.4	63.0	61.6	66.3	72.0	81.8	83.9	88.1		
	2%	WB	69.8	70.3	68.5	63.5	59.2	55.9	54.8	56.2	58.8	61.4	65.6	67.7		
		MCDB	86.5	85.5	81.9	75.6	67.4	60.4	59.3	64.1	71.4	78.2	83.4	84.5		
	5%	WB	68.0	68.3	66.2	61.5	57.6	54.5	53.3	54.3	56.8	59.8	63.9	65.4		
		MCDB	87.0	83.7	80.8	74.9	65.4	59.1	58.2	61.6	68.4	75.5	82.0	85.7		
	10%	WB	66.4	66.3	64.3	60.0	56.2	53.2	52.0	52.7	55.1	58.1	62.0	63.7		
		MCDB	85.5	83.4	80.4	73.1	63.7	57.8	56.8	59.2	66.0	73.5	79.1	82.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	29.6	28.4	26.9	24.8	19.9	17.0	17.1	20.8	25.6	29.9	29.8	29.7		
		MCDBR	39.1	36.9	33.9	31.5	25.7	20.4	20.2	27.1	35.1	39.7	38.7	39.5		
		MCWBR	11.9	11.7	11.5	12.6	12.0	11.8	12.5	15.6	16.4	15.6	13.4	12.8		
	5% WB	MCDBR	28.3	27.5	26.9	23.6	19.1	15.1	16.8	22.7	28.1	31.3	30.8	29.3		
		MCWBR	10.7	9.8	9.5	11.0	10.5	9.8	11.5	14.6	15.2	13.8	12.1	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.339	0.320	0.315	0.301	0.291	0.292	0.301	0.328	0.337	0.343	0.333		
	taud		2.494	2.520	2.561	2.553	2.582	2.594	2.582	2.534	2.453	2.436	2.454	2.505		
	Ebn at Noon		316	310	305	289	277	272	277	289	297	307	313	319		
	Edh at Noon		36	34	30	27	23	22	23	27	33	37	38	36		
(44) All-Sky Solar Radiation	RadAvg		2517	2246	1846	1360	955	784	850	1149	1566	1998	2305	2482		
	RadStd		132	123	95	69	40	50	39	75	118	121	115	103		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-167	+288	+131	

Nomenclature: See separate page