

ROSEWORTHY, Australia

WMO: 956710

Lat: 34.5106S

Lon: 138.6764E

Elev: 215

StdP: 14.58

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.8	37.0	21.3	16.1	80.7	25.1	19.3	78.2	29.9	59.4	27.8	59.3	6.3	50	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	103.5	65.5	99.0	64.8	94.7	63.6	70.9	84.7	68.7	85.1	67.0	84.8	14.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	102.7	74.4	64.6	92.0	72.7	61.9	83.3	71.4	34.9	83.5	33.0	84.3	31.6	84.9	98.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.4	24.5	21.2	DB	30.9	110.0	1.5	3.0	29.8	112.1	28.9	113.8	28.0	115.5	26.9	117.7
			WB	30.0	75.6	1.4	7.3	29.0	80.8	28.2	85.1	27.4	89.2	26.4	94.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	73.1	72.2	68.7	63.5	57.4	52.0	50.8	51.1	54.5	60.0	65.4	69.3	(6)
(7)		DBStd	10.59	8.58	8.30	7.86	6.79	5.27	3.92	3.78	4.56	5.58	7.93	8.92	9.07	(7)
(8)		HDD50	115	0	0	0	0	3	22	36	39	12	3	0	0	(8)
(9)		HDD65	2364	13	16	45	107	245	390	440	432	319	205	104	48	(9)
(10)		CDD50	4295	717	623	579	406	232	83	61	72	148	312	463	599	(10)
(11)		CDD65	1068	265	219	159	64	9	0	0	0	4	49	117	182	(11)
(12)		CDH74	14899	3750	2902	1956	676	67	1	0	8	116	834	1823	2766	(12)
(13)		CDH80	7863	2152	1573	959	253	10	0	0	1	26	369	953	1567	(13)
(14)	Wind	WSAvg	10.7	11.1	10.6	10.3	10.3	10.4	10.2	11.2	10.6	10.4	11.1	11.0	11.5	(14)
(15)	Precipitation	PrecAvg	17.6	0.9	0.8	0.8	1.5	1.8	1.8	2.1	2.1	2.0	1.7	1.1	0.8	(15)
(16)		PrecMax	25.3	4.3	3.6	2.9	4.5	4.2	3.7	4.2	4.6	3.6	4.2	2.7	3.8	(16)
(17)		PrecMin	8.5	0.0	0.0	0.0	0.0	0.2	0.2	0.5	0.4	0.4	0.0	0.0	0.0	(17)
(18)		PrecStd	3.9	0.9	0.9	0.8	1.1	1.1	1.0	0.9	1.1	0.9	1.2	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.6	105.6	101.9	94.6	80.9	69.3	67.7	74.1	83.7	96.1	101.8	107.0	(19)
(20)		MCWB	67.5	67.2	64.7	67.9	58.0	55.1	54.1	56.4	58.1	60.7	64.1	66.0	(20)	
(21)		2%	DB	104.6	99.7	95.1	86.7	74.7	64.7	63.2	67.9	76.8	89.3	96.2	101.6	(21)
(22)		MCWB	65.7	66.2	64.3	60.6	57.0	53.2	52.9	54.9	57.3	59.2	62.8	64.1	(22)	
(23)		5%	DB	98.1	95.4	90.2	81.5	70.3	62.0	60.5	63.7	71.7	83.4	91.1	95.2	(23)
(24)		MCWB	65.0	65.4	63.4	58.8	56.0	53.4	52.8	53.9	56.1	57.9	61.2	63.2	(24)	
(25)		10%	DB	91.8	90.1	84.9	76.7	66.6	59.6	58.2	60.1	66.5	77.2	85.1	89.1	(25)
(26)		MCWB	63.6	64.0	62.0	57.7	55.3	52.6	51.9	52.5	54.8	57.3	60.2	62.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	75.0	70.9	70.6	62.1	59.0	58.5	59.2	63.6	65.8	70.2	78.0	(27)
(28)		MADB	79.6	94.4	82.4	74.3	70.5	63.2	61.8	67.0	72.4	82.2	84.0	79.6	(28)	
(29)		2%	WB	69.8	69.7	68.3	63.9	59.6	56.3	55.7	56.8	59.5	62.4	66.2	68.4	(29)
(30)		MADB	86.0	84.4	81.7	75.6	68.1	61.2	59.8	64.9	71.2	77.9	82.1	86.0	(30)	
(31)		5%	WB	68.1	67.7	66.3	61.8	58.2	54.8	54.0	54.7	57.3	60.4	64.2	66.0	(31)
(32)		MADB	88.9	84.0	81.4	74.7	65.9	59.6	58.4	61.6	68.3	75.5	82.8	85.3	(32)	
(33)		10%	WB	66.4	65.9	64.3	60.1	56.8	53.4	52.6	53.2	55.6	58.7	62.0	63.9	(33)
(34)		MADB	87.6	84.7	82.4	72.1	64.1	58.2	57.0	59.5	64.8	74.0	80.1	82.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	27.4	26.2	24.7	22.3	17.7	15.6	15.2	18.8	22.9	27.3	28.4	27.5	(35)	
(36)		5% DB	MADB	35.5	32.7	31.0	28.4	22.5	18.3	17.6	23.9	31.0	36.2	35.4	35.5	(36)
(37)		MCWBR	11.7	12.1	10.9	11.5	10.4	10.5	10.7	13.8	14.5	13.7	12.7	12.7	(37)	
(38)		5% WB	MADB	26.4	25.3	24.1	21.9	17.7	14.4	15.0	20.5	26.1	28.9	29.0	26.4	(38)
(39)		MCWBR	11.7	11.2	11.0	11.7	10.1	9.5	10.4	13.3	14.7	13.7	12.3	12.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.340	0.323	0.316	0.305	0.293	0.294	0.306	0.332	0.342	0.346	0.337	(40)	
(41)		taud	2.492	2.521	2.555	2.559	2.572	2.594	2.579	2.522	2.445	2.425	2.446	2.497	(41)	
(42)		Ebn at Noon	315	310	304	288	273	269	275	286	295	305	312	318	(42)	
(43)		Edh at Noon	36	34	30	27	23	22	23	28	34	37	38	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2515	2227	1817	1320	912	749	811	1101	1505	1949	2292	2463	(44)	
(45)		RadStd	126	103	85	66	40	45	33	74	116	125	112	92	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (28 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-160	+274	+124	

Nomenclature: See separate page