

ADELAIDE MOUNT LOFTY, Australia

WMO: 956780

Lat: 34.9783S

Lon: 138.7089E

Elev: 2247

StdP: 13.54

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.4	37.6	15.0	12.8	65.0	21.4	17.5	64.1	39.7	46.2	35.0	45.2	11.0	110	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.7	89.2	61.1	85.5	60.1	82.0	58.9	65.7	78.4	63.8	77.2	62.1	76.2	8.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	91.4	68.3	59.6	82.8	66.6	57.3	76.2	64.4	31.7	79.2	30.2	77.0	28.9	76.4	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.4	28.0	24.0	DB	33.9	94.2	1.0	4.0	33.2	97.0	32.6	99.4	32.0	101.6	31.3	104.5	(4)
(5)			WB	32.8	68.4	1.2	2.8	32.0	70.5	31.2	72.1	30.5	73.7	29.7	75.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	63.5	63.6	59.9	55.5	50.1	45.7	44.5	45.4	48.7	52.7	56.6	60.1	(6)
(7)		DBStd	9.89	9.34	9.13	8.48	7.07	5.18	3.65	3.45	4.87	6.23	8.26	8.93	9.07	(7)
(8)		HDD50	755	2	1	4	19	62	137	177	164	98	60	24	7	(8)
(9)		HDD65	4458	147	130	214	299	464	578	637	608	488	394	285	214	(9)
(10)		CDD50	2142	419	383	311	183	64	9	5	21	61	145	222	319	(10)
(11)		CDD65	371	99	91	56	13	1	0	0	0	1	14	34	62	(11)
(12)		CDH74	3610	1158	889	426	51	0	0	0	0	1	104	301	680	(12)
(13)		CDH80	1187	459	294	94	8	0	0	0	0	0	21	74	237	(13)
(14)	Wind	WSAvg	10.1	9.4	8.9	8.8	9.1	9.9	11.2	12.1	11.7	11.5	10.5	9.2	8.9	(14)
(15)	Precipitation	PrecAvg	24.8	0.9	1.0	1.0	1.7	2.9	3.6	3.5	3.1	2.8	1.9	1.2	1.4	(15)
(16)		PrecMax	37.9	2.0	3.9	4.0	4.3	5.4	5.9	7.2	6.6	6.7	5.0	3.8	4.3	(16)
(17)		PrecMin	15.9	0.0	0.0	0.0	0.1	0.4	1.0	1.3	0.6	1.1	0.2	0.1	0.2	(17)
(18)		PrecStd	4.8	0.5	0.9	0.9	1.2	1.2	1.4	1.4	1.5	1.3	1.3	0.9	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.2	92.3	87.3	80.0	67.5	59.8	57.0	63.9	71.7	82.4	87.4	92.6	(19)
(20)			MCWB	62.5	64.9	59.9	58.2	52.0	50.1	47.1	50.8	53.6	57.7	60.5	62.1	(20)
(21)		2%	DB	89.8	87.5	82.3	74.1	63.8	55.5	54.0	59.7	67.6	76.4	81.4	86.7	(21)
(22)			MCWB	61.2	62.4	59.1	54.7	50.8	48.9	45.9	47.6	50.9	55.7	57.3	59.8	(22)
(23)		5%	DB	85.1	83.7	79.0	70.3	60.9	53.1	51.6	56.3	63.7	72.0	77.1	81.5	(23)
(24)			MCWB	60.0	60.2	58.4	53.3	50.1	47.8	45.1	46.5	49.7	53.9	56.3	57.4	(24)
(25)		10%	DB	80.5	79.7	74.9	67.0	57.8	50.9	49.6	53.3	59.8	67.7	72.9	76.9	(25)
(26)			MCWB	58.8	58.8	57.1	52.2	49.6	46.7	44.8	45.0	48.3	52.1	54.8	56.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.4	68.9	65.5	60.3	56.5	53.6	51.4	52.8	56.0	63.3	63.4	65.4	(27)
(28)			MADB	77.7	80.3	77.2	69.6	59.6	55.0	53.1	59.8	66.6	75.2	79.3	78.3	(28)
(29)		2%	WB	65.4	65.9	63.0	58.2	54.5	50.8	48.8	50.1	53.3	58.3	61.0	62.7	(29)
(30)			MADB	79.0	78.4	74.0	66.4	58.6	53.2	50.3	55.7	62.4	70.4	74.7	77.2	(30)
(31)		5%	WB	63.5	63.8	60.9	56.4	52.7	49.3	47.4	48.3	51.4	55.6	59.0	60.6	(31)
(32)			MADB	78.3	76.6	73.0	65.1	56.8	51.4	49.0	52.5	59.6	66.7	71.1	75.2	(32)
(33)		10%	WB	61.4	61.7	58.8	54.7	51.2	48.0	46.2	46.8	49.8	53.4	56.7	58.5	(33)
(34)			MADB	77.1	75.5	70.5	62.8	55.3	49.7	47.8	50.5	57.0	64.4	69.0	72.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.1	16.7	14.3	10.7	7.1	5.8	5.7	7.4	10.3	13.8	15.6	17.1	(35)
(36)			MADB	23.5	21.0	18.8	15.0	9.9	8.3	8.1	12.1	16.6	20.6	21.5	23.5	(36)
(37)			MCWBR	9.0	8.8	7.6	6.7	5.5	5.8	5.5	6.7	7.7	9.1	9.0	9.7	(37)
(38)		5% WB	MADB	21.2	18.3	18.3	13.6	8.5	7.0	6.7	10.5	14.5	19.1	19.7	20.9	(38)
(39)			MCWBR	10.5	9.5	9.1	7.4	6.0	5.7	5.6	7.0	8.1	10.1	10.0	10.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.311	0.297	0.290	0.282	0.275	0.274	0.284	0.302	0.313	0.316	0.308	(40)	
(41)		taud	2.585	2.606	2.643	2.643	2.648	2.653	2.648	2.602	2.541	2.511	2.536	2.586	(41)	
(42)		Ebn at Noon	325	319	312	297	283	277	283	295	305	314	322	328	(42)	
(43)		Edh at Noon	33	31	28	25	22	20	21	25	30	34	35	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2471	2167	1762	1276	874	720	781	1071	1469	1907	2253	2426	(44)	
(45)		RadStd	124	105	80	70	37	45	34	67	113	119	102	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.62	N/A	N/A	+3.64	+1.15	N/A	-194	-495	+428	+101	(46)
(47)	Regional (26 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-166	+283	+126	(47)

Nomenclature: See separate page