

RENMARK AP, Australia

WMO: 956870

Lat: 34.1983S

Lon: 140.6767E

Elev: 32

StdP: 100.94

Time Zone: 9.50 (AUA)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.1	0.6	-7.4	2.0	22.1	-5.6	2.4	18.8	11.3	15.9	10.2	15.8	0.7	260	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.1	40.4	18.8	37.9	18.2	35.7	17.6	21.6	29.8	20.5	30.5	19.5	30.4	5.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.5	23.5	17.8	12.8	22.8	16.1	11.5	22.3	63.3	29.2	59.1	30.4	55.8	30.3	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.2	8.2	DB	-4.0	44.1	0.9	1.4	-4.7	45.0	-5.2	45.9	-5.7	46.6	-6.4	47.6	(4)
(5)			WB	-4.5	23.1	0.9	1.4	-5.2	24.2	-5.7	25.0	-6.2	25.8	-6.9	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	24.8	24.1	20.9	16.8	13.1	10.4	10.0	11.1	13.9	16.9	20.2	22.4	(6)
(7)		DBStd	6.27	4.24	4.21	3.99	3.48	2.92	2.63	2.56	2.76	3.39	3.84	4.33	4.16	(7)
(8)		HDD10.0	82	0	0	0	1	5	26	32	17	2	0	0	0	(8)
(9)		HDD18.3	1221	1	3	16	69	163	238	258	224	140	76	27	7	(9)
(10)		CDD10.0	2647	458	395	339	205	102	38	32	52	121	214	306	384	(10)
(11)		CDD18.3	744	202	164	97	24	2	0	0	1	8	32	82	133	(11)
(12)		CDH23.3	10567	2806	2148	1261	366	33	1	1	19	169	588	1237	1938	(12)
(13)	CDH26.7	5590	1643	1197	616	129	3	0	0	2	53	259	633	1056	(13)	
(14)	Wind	WSAvg	4.0	4.6	4.5	4.0	3.2	3.2	3.7	3.9	4.2	4.4	4.5	4.5	(14)	
(15)	Precipitation	PrecAvg	259	18	18	12	19	22	21	27	25	29	30	22	17	(15)
(16)		PrecMax	517	97	103	81	131	91	61	70	75	113	108	108	68	(16)
(17)		PrecMin	90	0	0	0	0	0	1	2	1	3	0	0	0	(17)
(18)		PrecStd	88	19	23	16	24	17	15	16	14	24	28	22	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	42.2	38.5	34.0	26.7	21.5	21.6	25.7	31.3	36.1	40.0	41.9	(19)
(20)			MCWB	19.8	19.9	18.4	16.7	14.2	13.0	11.7	12.6	14.3	15.7	17.8	18.3	(20)
(21)		2%	DB	40.8	38.9	35.6	30.2	23.8	18.8	18.9	22.4	28.0	32.7	36.2	38.6	(21)
(22)			MCWB	19.2	19.0	17.7	15.8	13.9	11.9	11.2	11.5	13.5	15.3	16.9	17.7	(22)
(23)		5%	DB	37.9	36.2	33.0	27.4	21.4	17.2	17.1	19.7	24.7	29.6	33.2	35.7	(23)
(24)			MCWB	18.4	18.4	17.6	14.9	13.3	11.5	10.9	10.8	12.9	14.4	16.5	17.2	(24)
(25)		10%	DB	34.9	33.7	30.1	24.9	19.5	15.9	15.6	17.7	22.0	26.4	30.3	32.6	(25)
(26)			MCWB	18.1	17.9	16.7	14.4	12.7	11.1	10.3	10.4	12.1	13.7	15.6	16.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.3	20.7	19.0	16.4	14.9	13.9	14.0	16.2	18.2	20.5	21.6	(27)
(28)			MCD B	27.8	30.4	29.0	21.2	21.3	17.3	16.8	20.9	22.6	27.4	28.4	28.0	(28)
(29)		2%	WB	21.3	22.3	19.6	17.3	15.2	13.2	12.4	12.7	14.8	16.7	19.1	20.0	(29)
(30)			MCD B	31.4	29.5	29.2	25.2	20.3	16.8	16.5	19.3	23.7	26.0	29.0	28.2	(30)
(31)		5%	WB	20.3	20.8	18.6	16.3	14.2	12.3	11.5	11.8	13.8	15.6	18.1	18.8	(31)
(32)			MCD B	32.4	30.3	29.0	24.7	19.5	16.0	15.7	17.7	23.0	25.3	28.7	30.5	(32)
(33)		10%	WB	19.2	19.4	17.7	15.3	13.3	11.5	10.8	11.0	12.8	14.6	17.0	17.6	(33)
(34)			MCD B	32.3	30.6	28.4	23.3	18.4	15.1	14.8	16.7	20.5	24.5	27.1	30.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.1	15.2	14.6	14.4	12.4	11.4	11.4	12.8	14.2	15.2	15.4	15.9	(35)
(36)			MCD BR	20.5	19.1	18.7	18.8	15.4	13.0	13.3	16.9	19.1	20.7	20.0	20.5	(36)
(37)			MCWBR	6.7	6.1	6.7	8.2	7.7	7.5	7.3	8.4	8.3	7.9	6.8	7.0	(37)
(38)		5% WB	MCD BR	15.0	13.3	14.8	13.7	12.2	10.7	11.2	13.4	15.6	15.5	15.4	14.9	(38)
(39)			MCWBR	5.8	5.1	5.8	6.5	6.6	6.5	6.6	7.2	7.2	6.4	5.7	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.338	0.320	0.312	0.299	0.292	0.291	0.302	0.333	0.333	0.343	0.334	(40)	
(41)		taud	2.498	2.532	2.566	2.563	2.583	2.591	2.589	2.543	2.445	2.463	2.468	2.507	(41)	
(42)		Ebn at Noon	995	978	960	912	872	852	872	910	930	972	987	1006	(42)	
(43)		Edh at Noon	114	106	96	85	74	68	72	85	106	113	117	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.92	7.08	5.86	4.29	3.02	2.47	2.67	3.62	4.92	6.30	7.20	7.87	(44)	
(45)		RadStd	0.38	0.39	0.31	0.22	0.14	0.14	0.12	0.23	0.35	0.38	0.34	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	-12	-92	+151	+65

Nomenclature: See separate page