

WILCANNIA, Australia

WMO: 956950

Lat: 31.5194S

Lon: 143.3850E

Elev: 95

StdP: 100.19

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.2	2.5	-8.5	1.8	19.1	-7.0	2.1	19.3	10.4	17.2	9.5	16.9	2.8	230	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	42.1	20.1	40.2	19.7	38.4	19.0	23.2	30.1	22.1	31.5	21.2	31.9	5.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.4	25.4	19.9	14.8	24.8	18.4	13.4	24.4	69.7	29.5	65.3	30.9	62.0	31.8	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	9.5	8.4	DB	-1.4	44.6	1.0	1.6	-2.1	45.7	-2.6	46.7	-3.2	47.6	-3.9	48.7	
			WB	-2.2	24.5	1.0	1.5	-3.0	25.6	-3.6	26.5	-4.2	27.4	-5.0	28.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	29.0	27.6	23.9	19.6	14.5	11.4	10.9	12.3	16.0	20.0	23.6	26.3
	DBStd	7.26	4.21	4.23	3.88	3.66	3.09	2.72	2.59	3.00	3.66	4.21	4.49	4.22
	HDD10.0	45	0	0	0	0	2	16	19	8	1	0	0	0
	HDD18.3	912	0	0	4	27	124	209	231	189	91	30	6	1
	CDD10.0	3527	589	492	431	289	141	57	47	80	179	308	408	507
	CDD18.3	1354	331	259	176	66	6	1	1	2	20	81	164	249
	CDH23.3	18920	4947	3551	2141	785	80	3	4	45	376	1178	2277	3533
	CDH26.7	10732	3154	2132	1103	294	7	0	0	7	133	558	1257	2086
Wind	WSAvg	4.4	5.0	4.8	4.5	4.0	3.9	3.8	3.9	4.2	4.5	4.9	5.0	5.0
Precipitation	PrecAvg	263	32	21	26	23	24	19	18	19	15	23	17	25
	PrecMax	673	221	120	138	181	91	80	56	72	79	86	55	128
	PrecMin	88	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	129	55	29	31	35	23	19	15	17	18	22	17	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.9	43.7	39.6	34.8	27.6	23.3	23.8	27.2	33.5	37.3	42.4	42.6
		MCWB	20.7	21.6	19.4	17.6	15.3	14.7	13.2	13.4	15.4	17.1	19.4	19.5
	2%	DB	42.5	41.1	37.1	32.1	25.7	20.6	20.9	24.2	30.2	34.9	38.8	40.2
		MCWB	20.1	20.2	18.7	17.1	14.7	12.8	11.5	12.6	14.2	16.6	18.3	19.2
	5%	DB	40.5	38.7	34.7	30.1	23.5	18.7	18.8	21.8	27.7	32.5	36.0	38.3
		MCWB	20.0	19.5	18.0	16.4	14.1	12.1	11.1	11.6	13.6	15.7	17.3	18.4
	10%	DB	38.4	36.4	32.5	28.0	21.3	17.1	17.0	19.7	24.9	29.8	33.6	36.0
		MCWB	19.5	19.2	17.7	15.7	13.2	11.5	10.7	10.8	12.9	15.0	16.9	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	25.6	22.7	20.6	18.0	16.1	16.6	15.5	17.5	19.4	21.6	23.7
		MCDB	30.2	30.9	28.5	28.7	21.2	20.3	19.0	20.4	24.8	28.6	32.9	30.0
	2%	WB	23.0	23.6	21.3	18.8	16.2	14.5	13.4	13.9	15.8	18.2	20.5	21.7
		MCDB	30.8	31.1	28.0	26.0	22.3	18.2	17.9	21.9	26.2	28.3	30.8	30.3
	5%	WB	22.0	22.4	20.2	17.7	15.0	13.3	12.0	12.6	14.6	17.1	19.5	20.6
		MCDB	33.3	30.9	28.6	25.6	21.1	16.9	16.8	20.5	24.8	29.0	29.7	31.5
	10%	WB	21.1	21.2	19.2	16.7	14.0	12.3	11.0	11.4	13.5	16.1	18.5	19.5
		MCDB	33.8	31.5	29.2	25.5	20.4	15.9	16.2	18.6	23.3	27.9	29.3	32.2
Mean Daily Temperature Range	5% DB	MDBR	14.6	13.7	13.9	14.1	13.0	11.5	12.4	13.8	15.2	15.4	14.9	14.8
		MCDBR	17.1	16.3	16.8	16.5	15.5	13.8	14.8	16.7	19.4	19.1	18.3	17.2
		MCWBR	6.4	5.9	6.6	7.2	7.4	7.6	8.0	8.3	8.6	8.0	7.1	6.5
	5% WB	MCDBR	13.2	11.6	12.3	12.9	12.4	10.6	12.2	14.4	15.9	15.2	13.9	13.4
		MCWBR	5.3	4.3	5.0	5.9	6.4	6.1	7.1	7.8	7.6	7.0	5.7	5.5
Clear-Sky Solar Irradiance	taub		0.335	0.337	0.319	0.306	0.293	0.285	0.285	0.295	0.338	0.331	0.343	0.332
	taud		2.516	2.539	2.570	2.577	2.579	2.599	2.580	2.533	2.398	2.444	2.449	2.496
	Ebn at Noon		1004	983	968	930	893	878	894	928	931	978	989	1010
	Edh at Noon		113	107	97	86	76	71	75	88	113	116	120	116
All-Sky Solar Radiation	RadAvg		8.04	7.20	6.21	4.82	3.58	2.93	3.28	4.25	5.63	6.88	7.51	8.11
	RadStd		0.40	0.43	0.39	0.24	0.20	0.17	0.16	0.23	0.30	0.38	0.50	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page