

WHITE CLIFFS, Australia

WMO: 956990

Lat: 30.8517S

Lon: 143.0742E

Elev: 159

StdP: 99.44

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 3.7	(c) 4.7	(d) -9.3	(e) 1.7	(f) 23.0	(g) -7.6	(h) 2.0	(i) 23.1	(j) 11.7	(k) 18.3	(l) 10.5	(m) 17.8	(n) 3.2	(o) 190	(p) 0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	41.8	19.8	39.9	19.4	38.2	19.0	23.4	30.0	22.4	30.8	21.5	31.2	5.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.9	16.9	25.5	20.3	15.3	25.2	18.9	14.0	24.5	70.7	30.1	66.7	30.4	63.4	31.2	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.2	10.0	9.0	DB	1.3	44.0	0.7	1.7	0.8	45.2	0.4	46.2	0.0	47.2	-0.6	48.5	
			WB	-0.5	24.4	1.0	1.3	-1.2	25.4	-1.8	26.2	-2.4	26.9	-3.2	27.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.7	30.2	28.7	25.5	20.6	15.6	12.0	11.8	13.5	17.5	21.7	24.8	27.5
	DBStd	7.35	4.00	4.12	4.01	3.63	3.12	2.52	2.67	3.04	3.69	4.34	4.43	4.19
	HDD10.0	21	0	0	0	0	1	8	9	2	0	0	0	0
	HDD18.3	747	0	0	2	18	98	191	204	155	61	16	3	1
	CDD10.0	3934	627	523	481	317	173	68	64	111	224	363	443	542
	CDD18.3	1621	369	290	224	86	12	1	1	5	35	120	196	284
	CDH23.3	21438	5538	4004	2616	797	84	2	6	50	425	1479	2521	3916
Wind	WSAvg	4.8	5.3	5.2	4.9	4.3	4.1	4.1	4.2	4.5	4.9	5.2	5.2	5.4
	PrecAvg	266	39	23	25	19	25	15	19	16	17	22	20	21
	PrecMax	721	266	129	253	109	92	65	85	76	73	121	84	94
	PrecMin	106	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	133	56	30	43	27	23	16	19	17	17	23	18	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	43.2	39.0	34.6	27.6	22.3	24.1	27.8	33.3	37.6	42.1	42.3
		MCWB	20.3	20.3	19.5	17.9	15.4	13.8	13.4	14.0	14.4	17.2	18.9	19.2
	2%	DB	42.3	40.9	37.0	31.6	25.7	20.2	21.5	24.5	30.1	35.1	38.7	39.7
		MCWB	20.0	20.0	18.8	17.2	14.9	12.6	12.0	12.5	13.9	16.5	17.9	18.8
	5%	DB	40.2	38.7	35.1	29.8	23.8	18.6	19.5	22.3	28.1	33.1	36.2	37.8
		MCWB	19.9	19.5	18.3	16.1	14.2	12.0	11.5	11.6	13.3	15.8	17.4	18.3
	10%	DB	38.4	36.7	33.1	27.9	21.7	17.1	17.6	20.2	25.5	30.7	33.7	35.9
		MCWB	19.6	19.3	18.2	15.5	13.3	11.6	10.9	10.8	12.7	15.2	16.7	18.2
	0.4%	WB	24.8	25.6	22.8	20.8	18.7	16.0	17.7	15.2	17.6	20.0	21.6	24.0
		MCDB	30.3	31.9	29.2	27.8	21.2	18.3	20.4	20.1	23.2	27.1	31.7	29.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.5	23.3	21.7	18.8	16.5	14.4	14.1	13.7	15.7	18.5	20.6	22.2
		MCDB	30.1	30.1	29.6	25.3	22.3	17.7	18.5	22.0	25.8	28.5	29.7	29.1
	5%	WB	22.5	22.2	20.8	17.8	15.2	13.3	12.5	12.5	14.6	17.3	19.7	21.0
		MCDB	31.7	30.5	28.7	24.9	21.6	16.7	17.5	21.1	24.6	28.6	27.9	30.5
	10%	WB	21.5	21.2	19.8	16.8	14.2	12.5	11.2	11.5	13.5	16.4	18.8	19.9
		MCDB	32.9	31.2	28.5	25.1	20.8	16.0	16.8	19.3	23.5	28.3	28.2	31.0
Mean Daily Temperature Range	5% DB	MDBR	12.3	11.7	11.2	11.6	10.7	9.7	10.8	11.7	12.7	13.1	12.6	12.5
		MCDBR	14.2	13.6	13.0	13.5	12.5	11.5	12.8	14.1	16.1	15.4	15.0	14.2
		MCWBR	5.0	4.6	4.8	5.6	5.7	6.0	6.8	6.5	6.9	6.2	5.3	5.0
	5% WB	MCDBR	11.3	10.7	10.1	10.6	10.3	8.3	10.2	12.2	13.0	12.9	11.7	11.6
		MCWBR	4.8	3.8	4.1	4.5	5.3	4.7	6.0	6.1	6.4	5.8	4.6	5.0
Clear-Sky Solar Irradiance	taub	0.336	0.337	0.319	0.305	0.293	0.283	0.284	0.294	0.338	0.332	0.344	0.332	
	taud	2.513	2.540	2.570	2.578	2.574	2.596	2.576	2.527	2.391	2.432	2.444	2.496	
	Ebn at Noon	1004	984	970	933	897	884	899	931	933	977	989	1011	
	Edh at Noon	113	107	97	87	77	72	76	89	114	118	121	116	
All-Sky Solar Radiation	RadAvg	8.07	7.25	6.29	4.92	3.70	3.06	3.42	4.41	5.77	6.96	7.57	8.08	
	RadStd	0.38	0.44	0.39	0.24	0.21	0.16	0.17	0.22	0.29	0.37	0.49	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page