

GRIFFITH AP, Australia

WMO: 957040

Lat: 34.249S

Lon: 146.069E

Elev: 135

StdP: 99.71

Time Zone: 10.00 (AUS)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.4	1.5	-5.7	2.4	24.3	-3.9	2.8	20.9	10.5	13.3	9.7	12.4	0.9	320	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	39.8	19.2	37.5	18.9	35.6	18.5	22.3	30.2	21.4	30.1	20.6	29.9	5.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.7	23.6	19.3	14.3	23.3	17.9	13.1	23.2	66.4	29.8	62.9	29.8	60.0	29.9	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.2	8.2	-1.9	42.7	1.1	1.7	-2.7	44.0	-3.3	45.0	-3.9	45.9	-4.6	47.2		
(5)			-2.2	24.0	1.2	1.2	-3.1	24.9	-3.8	25.6	-4.5	26.2	-5.4	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	26.5	25.2	22.1	17.8	12.9	10.3	9.4	10.2	13.3	17.2	21.3	23.6		
	DBStd	6.97	4.28	4.11	3.98	3.59	3.03	2.62	2.27	2.66	3.52	4.20	4.41	4.23		
	HDD10.0	109	0	0	0	0	8	27	40	28	5	1	0	0		
	HDD18.3	1261	1	2	12	52	169	242	278	252	156	73	18	5		
	CDD10.0	2823	513	426	376	233	97	36	20	35	106	223	338	421		
	CDD18.3	934	255	195	129	35	1	0	0	1	7	38	106	168		
	CDH23.3	12023	3506	2388	1424	366	16	0	0	7	113	554	1397	2252		
(13)	CDH26.7	6176	2064	1281	637	100	1	0	0	1	27	213	676	1177		
(14)	Wind	WSAvg	4.0	4.6	4.5	4.1	3.5	3.2	3.4	3.3	3.7	4.1	4.3	4.5		
(15) Precipitation	PrecAvg	407	37	26	30	33	41	35	36	39	37	38	30	30		
	PrecMax	660	257	138	217	170	136	70	88	88	116	143	128	104		
	PrecMin	178	0	0	0	0	2	0	1	3	6	5	0	0		
	PrecStd	119	47	32	39	33	31	22	26	21	25	32	27	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	41.5	37.6	32.4	25.4	20.5	19.7	23.8	29.9	34.4	39.0	40.8		
		MCWB	20.6	20.4	18.8	16.9	14.7	13.3	11.9	12.7	14.3	16.2	18.1	18.9		
	2%	DB	40.4	38.3	34.5	29.3	23.0	18.2	17.6	20.3	26.3	31.6	35.9	37.7		
		MCWB	19.8	19.2	18.3	16.4	14.0	12.5	11.4	11.7	13.9	15.5	17.6	18.4		
	5%	DB	38.1	35.9	32.3	27.3	21.0	16.8	16.0	18.3	24.0	29.0	33.2	35.3		
		MCWB	19.5	19.2	17.6	15.7	13.3	11.8	11.1	10.9	13.4	15.1	17.1	17.9		
	10%	DB	35.7	33.5	30.3	25.3	19.1	15.3	14.5	16.6	21.5	26.3	30.6	32.9		
		MCWB	19.0	18.5	17.3	15.1	12.6	11.2	10.3	10.5	12.4	14.2	16.1	17.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	24.2	22.0	19.3	17.0	15.0	15.2	14.6	16.9	19.2	21.0	22.5		
		MCDB	30.7	28.3	26.4	25.1	19.2	17.3	16.5	17.5	23.9	24.4	28.9	27.4		
	2%	WB	22.1	22.7	20.8	18.0	15.1	13.7	12.9	13.2	15.6	17.6	19.8	21.0		
		MCDB	31.5	30.4	26.6	23.8	19.7	16.3	15.1	18.1	22.2	24.6	27.2	28.9		
	5%	WB	21.3	21.5	19.6	17.0	14.2	12.8	11.7	11.8	14.4	16.6	19.0	19.8		
		MCDB	31.7	30.1	27.3	24.1	19.1	15.5	14.7	17.1	21.5	24.4	27.1	29.1		
	10%	WB	20.6	20.5	18.6	16.0	13.4	11.9	10.7	10.9	13.2	15.6	18.0	18.9		
		MCDB	31.6	29.6	27.9	23.6	18.3	14.5	13.8	15.8	20.2	24.3	26.8	29.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	13.4	13.2	12.9	11.9	9.9	10.4	11.9	13.9	14.4	14.2	14.5		
		MCDBR	16.6	15.9	15.1	15.1	13.5	11.6	12.3	14.7	17.0	17.4	17.1	16.6		
		MCWBR	5.1	5.2	5.3	6.2	6.3	6.4	7.1	7.5	7.5	6.8	5.5	5.3		
	5% WB	MCDBR	13.7	12.0	12.0	12.2	11.4	8.7	9.9	12.5	14.1	13.3	12.7	12.5		
		MCWBR	5.3	4.7	5.0	5.2	5.8	5.5	6.2	6.9	7.0	6.1	4.9	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.339	0.339	0.319	0.307	0.296	0.289	0.285	0.292	0.322	0.326	0.342	0.335		
	taud		2.509	2.529	2.573	2.571	2.568	2.595	2.599	2.558	2.462	2.480	2.471	2.501		
	Ebn at Noon		998	976	961	918	874	856	880	921	942	979	988	1005		
	Edh at Noon		113	107	95	84	74	68	71	84	104	111	116	115		
(44) All-Sky Solar Radiation	RadAvg		7.82	6.92	5.84	4.36	3.17	2.48	2.73	3.69	5.11	6.42	7.19	7.90		
	RadStd		0.45	0.37	0.33	0.20	0.16	0.18	0.17	0.27	0.35	0.41	0.49	0.30		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		+0.49	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page