

CONDOBOLIN, Australia

WMO: 957080

Lat: 33.0683S

Lon: 147.2133E

Elev: 194

StdP: 99.02

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.1	0.2	-8.9	1.8	21.7	-6.8	2.2	18.5	10.7	13.4	9.7	13.5	0.6	290	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	39.3	18.9	37.3	18.5	35.4	18.0	22.4	28.7	21.5	28.6	20.8	28.6	5.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	16.0	24.2	19.8	14.9	23.7	18.6	13.7	23.3	67.0	28.7	63.6	28.5	60.8	28.5	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.8	9.4	8.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-3.4	42.2	1.4	2.2	-4.4	43.8	-5.2	45.2	-6.0	46.4	-7.0	48.1
			-3.9	24.0	1.4	1.4	-4.9	25.0	-5.7	25.8	-6.5	26.6	-7.5	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	26.7	25.7	22.2	17.3	12.8	9.9	8.9	10.0	13.4	17.3	21.3	24.1
	DBStd	7.11	3.99	3.78	3.64	3.49	3.01	2.65	2.52	2.83	3.51	4.17	4.30	3.98
	HDD10.0	132	0	0	0	0	8	34	51	33	5	1	0	0
	HDD18.3	1295	0	1	9	59	174	254	292	258	156	72	17	3
	CDD10.0	2833	516	438	378	220	93	30	18	34	106	227	338	436
	CDD18.3	954	258	206	128	28	2	0	0	1	6	40	105	181
	CDH23.3	12328	3446	2551	1392	354	16	0	0	8	117	591	1416	2439
	CDH26.7	6250	1984	1366	592	93	0	0	0	1	26	229	675	1284
Wind	WSAvg	3.7	4.5	4.1	3.7	3.0	2.9	2.9	3.1	3.4	3.8	4.1	4.3	4.5
Precipitation	PrecAvg	468	55	37	34	41	40	29	37	41	33	52	38	40
	PrecMax	677	255	113	136	229	138	88	90	85	108	154	106	139
	PrecMin	223	0	1	0	0	2	2	2	4	6	0	0	0
	PrecStd	137	60	35	33	47	32	22	22	23	26	39	30	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	41.1	36.5	32.2	25.2	20.7	20.2	24.2	29.8	34.6	39.3	40.5
		MCWB	20.0	20.1	17.7	16.3	15.0	13.3	11.8	13.5	14.2	15.9	17.5	18.7
	2%	DB	39.8	38.1	34.1	29.1	23.2	18.5	17.8	21.0	26.4	31.8	35.8	37.6
		MCWB	19.1	19.1	17.5	16.0	14.2	12.7	11.3	12.0	13.6	15.5	17.0	18.1
	5%	DB	37.5	35.8	32.0	27.2	21.3	17.0	16.0	18.8	24.1	29.3	33.1	35.4
		MCWB	19.2	18.6	17.6	15.4	13.5	12.1	10.8	11.2	13.1	15.0	16.6	17.5
	10%	DB	35.3	33.8	30.0	25.2	19.3	15.3	14.5	16.9	21.8	26.6	30.6	33.2
		MCWB	18.6	18.2	17.2	14.9	12.7	11.4	10.3	10.5	12.5	14.5	15.9	17.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	24.0	22.9	19.6	17.7	15.2	15.1	15.6	17.4	19.2	21.0	22.5
		MCDB	29.9	28.7	27.1	24.7	20.3	18.0	16.9	21.3	22.7	25.2	28.3	27.7
	2%	WB	22.4	22.3	21.2	18.1	16.2	13.9	12.8	13.7	15.8	17.8	19.9	21.2
		MCDB	29.4	29.0	26.2	23.9	19.7	16.4	15.2	17.9	21.0	25.3	26.6	27.2
	5%	WB	21.5	21.3	20.1	17.1	14.8	13.0	11.6	12.3	14.7	16.8	18.9	20.1
		MCDB	29.7	28.9	25.8	23.8	19.1	15.5	14.7	17.2	20.8	24.4	25.8	28.0
	10%	WB	20.7	20.4	18.9	16.0	13.7	12.0	10.6	11.1	13.6	15.7	17.9	19.0
		MCDB	30.1	28.6	26.6	23.1	18.3	14.9	13.9	16.0	19.9	24.1	25.9	28.8
Mean Daily Temperature Range	5% DB	MDBR	14.1	13.5	13.4	14.1	12.8	11.0	11.2	13.2	14.6	15.0	14.5	14.8
		MCDBR	16.2	15.9	15.4	16.3	15.2	13.4	14.0	16.5	18.1	18.1	17.5	17.0
		MCWBR	5.1	5.1	5.6	7.2	7.9	8.1	8.5	9.0	8.2	7.2	6.1	5.7
	5% WB	MCDBR	12.3	11.9	11.5	12.4	11.3	9.9	10.5	13.5	13.4	14.0	12.7	12.4
		MCWBR	4.8	4.7	5.0	6.1	6.3	6.6	7.0	8.2	7.3	6.5	4.9	5.3
Clear-Sky Solar Irradiance	taub	0.343	0.343	0.320	0.305	0.291	0.285	0.282	0.289	0.319	0.327	0.341	0.334	
	taud	2.514	2.542	2.588	2.592	2.592	2.616	2.611	2.570	2.469	2.479	2.483	2.521	
	Ebn at Noon	995	975	963	925	888	870	891	930	948	980	990	1007	
	Edh at Noon	113	106	94	84	74	68	71	84	104	111	115	113	
All-Sky Solar Radiation	RadAvg	7.76	6.81	5.81	4.52	3.33	2.59	2.90	3.85	5.29	6.49	7.16	7.84	
	RadStd	0.38	0.46	0.36	0.27	0.18	0.20	0.18	0.27	0.35	0.44	0.62	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.62	N/A	N/A	+1.59	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-89	N/A	N/A

Nomenclature: See separate page