

TRANGIE, Australia

WMO: 957100

Lat: 31.9861S

Lon: 147.9489E

Elev: 708

StdP: 14.32

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 33.0	(c) 35.1	(d) 19.9	(e) 15.3	(f) 70.2	(g) 23.2	(h) 18.0	(i) 67.0	(j) 21.2	(k) 55.5	(l) 19.1	(m) 55.9	(n) 3.0	(o) 150	(p) 0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 24.6	(c) 102.7	(d) 67.4	(e) 98.9	(f) 67.0	(g) 95.8	(h) 66.4	(i) 73.4	(j) 85.9	(k) 72.0	(l) 85.5	(m) 70.6	(n) 84.7	(o) 11.6	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.6	115.8	76.2	68.6	107.9	75.1	66.8	101.2	75.0	37.4	84.9	36.2	85.2	34.9	85.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	19.1	16.7	28.2	108.1	1.7	4.0	26.9	111.0	25.9	113.3	24.9	115.6	23.7	118.5
			27.6	75.5	1.9	1.3	26.2	76.5	25.1	77.3	24.1	78.0	22.7	79.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	80.9	78.6	73.4	66.1	57.1	51.6	49.9	52.0	58.1	65.5	72.0	76.7
	DBStd	12.30	6.50	6.58	5.89	5.97	5.37	4.56	4.55	4.98	6.23	7.04	7.21	6.65
	HDD50	137	0	0	0	0	6	35	58	33	5	0	0	0
	HDD65	1915	0	1	8	57	248	402	467	404	224	83	18	3
	CDD50	5644	959	801	726	483	228	83	56	95	246	480	660	827
	CDD65	1946	494	382	269	90	4	0	0	1	16	97	228	365
	CDH74	23328	6308	4460	2689	793	45	0	0	13	298	1280	2872	4570
	CDH80	11677	3587	2379	1159	200	1	0	0	1	75	477	1379	2419
(14) Wind	WSAvg	7.9	9.2	8.8	8.2	7.0	6.7	6.8	6.5	7.1	7.8	8.5	9.2	9.3
(15) Precipitation	PrecAvg	21.1	2.7	1.8	1.6	1.8	1.9	1.1	1.4	1.5	1.4	2.1	1.8	1.8
	PrecMax	37.9	8.6	11.9	6.5	12.5	7.1	3.3	3.9	3.3	4.0	9.8	6.9	7.0
	PrecMin	8.9	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.3	0.1	0.0
	PrecStd	6.5	2.5	2.3	1.7	2.6	1.8	0.9	1.0	0.9	1.1	1.9	1.6	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.4	106.9	97.7	89.9	78.3	69.1	69.3	75.9	87.2	94.2	103.1	104.8
		MCWB	69.4	70.6	66.9	63.3	59.8	56.2	52.8	56.5	58.6	61.4	65.7	65.7
	2%	DB	102.9	101.1	93.7	85.1	74.9	66.0	66.0	71.4	81.2	89.5	96.6	99.4
		MCWB	68.1	68.1	65.7	63.1	59.0	55.4	52.5	54.6	57.4	60.9	64.1	65.6
	5%	DB	99.0	96.7	90.0	81.8	72.1	63.7	63.0	67.5	76.9	85.3	92.3	95.8
		MCWB	68.3	67.5	65.0	61.6	57.4	54.3	52.2	53.3	56.0	60.0	63.0	65.2
	10%	DB	95.6	92.7	86.6	78.8	68.9	61.2	60.3	64.3	72.9	81.4	88.0	92.2
		MCWB	67.6	67.1	64.7	60.6	56.0	53.1	51.5	52.2	55.5	59.6	62.8	64.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.9	75.4	73.0	68.4	63.6	60.7	59.4	61.3	64.0	68.7	71.0	72.9
		MCDB	87.2	87.1	83.3	77.3	71.2	64.8	62.5	66.9	75.7	77.3	84.5	82.6
	2%	WB	73.3	73.6	70.3	66.0	61.1	58.0	56.5	57.9	61.2	65.7	69.2	71.1
		MCDB	87.9	85.2	81.4	76.9	69.7	62.0	60.6	66.2	72.0	77.8	83.0	83.4
	5%	WB	72.0	72.0	68.7	64.2	59.3	56.3	54.4	55.4	59.2	64.0	67.5	69.7
		MCDB	87.7	84.3	81.7	75.7	68.9	61.0	59.9	64.5	70.0	76.7	80.7	82.9
	10%	WB	70.7	70.3	67.3	62.6	57.5	54.6	52.4	53.2	57.3	62.2	65.7	68.2
		MCDB	86.7	84.1	80.9	74.2	66.8	59.8	58.6	62.2	69.2	75.9	79.6	81.6
(35) Mean Daily Temperature Range	MDBR		24.6	23.1	22.7	23.3	22.5	19.0	21.0	23.7	26.2	26.2	25.8	25.4
	5% DB	MCDBR	28.4	28.1	27.0	25.6	25.3	21.8	24.2	27.8	31.9	31.6	31.1	29.5
		MCWBR	8.3	8.7	10.0	9.6	11.9	12.2	13.6	14.4	13.8	12.1	10.4	9.7
	5% WB	MCDBR	23.5	21.1	21.5	21.1	20.7	16.7	18.0	23.0	23.8	23.7	23.7	22.5
		MCWBR	8.1	7.7	9.3	9.2	10.7	10.5	11.4	13.8	12.8	11.4	9.5	9.0
(40) Clear-Sky Solar Irradiance	taub		0.349	0.349	0.325	0.307	0.291	0.286	0.281	0.290	0.320	0.330	0.347	0.340
	taud		2.507	2.529	2.586	2.595	2.599	2.615	2.614	2.561	2.465	2.474	2.473	2.518
	Ebn at Noon		314	308	305	294	284	278	285	296	301	310	312	318
	Edh at Noon		36	34	30	27	24	22	23	27	33	36	37	36
(44) All-Sky Solar Radiation	RadAvg		2443	2165	1836	1464	1103	867	981	1281	1719	2073	2270	2469
	RadStd		126	153	125	93	59	60	58	81	104	147	214	121

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-142	+322	+221

Nomenclature: See separate page