

WALGETT, Australia

WMO: 957150

Lat: 30.0372S

Lon: 148.1222E

Elev: 440

StdP: 14.46

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 32.4	(c) 34.8	(d) 14.4	(e) 11.6	(f) 71.0	(g) 18.4	(h) 14.1	(i) 66.5	(j) 19.7	(k) 61.3	(l) 18.0	(m) 61.3	(n) 3.1	(o) 220	(p) 0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.7	104.6	67.5	101.2	67.5	98.2	66.8	74.3	87.4	73.0	86.8	71.8	86.2	11.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	118.4	76.9	69.7	110.9	77.0	68.0	104.5	76.3	38.1	86.6	37.0	86.3	35.8	86.1	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	18.5	16.6	26.6	109.3	2.4	4.5	24.8	112.5	23.4	115.1	22.0	117.6	20.3	120.8
			25.4	76.8	2.5	1.5	23.6	77.9	22.2	78.7	20.8	79.5	19.0	80.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	83.1	80.9	75.9	67.6	58.7	53.5	51.9	54.5	61.5	68.6	74.7	79.2
	DBStd	12.43	6.41	6.14	5.81	5.91	5.50	4.86	4.94	5.53	6.51	7.24	7.30	6.44
	HDD50	70	0	0	0	0	3	19	33	14	1	0	0	0
	HDD65	1534	0	0	2	40	206	346	408	331	145	47	8	1
	CDD50	6433	1025	866	804	529	273	123	91	153	347	576	741	905
	CDD65	2421	560	446	341	119	11	0	1	5	41	157	299	441
	CDH74	31327	7652	5625	3804	1285	154	5	8	98	783	2192	3844	5877
	CDH80	16595	4562	3165	1832	396	11	0	0	17	271	981	2008	3352
(14) Wind	WSAvg	8.4	9.9	9.4	8.7	7.4	6.7	7.1	6.8	7.6	8.3	9.0	9.6	9.8
(15) Precipitation	PrecAvg	20.0	3.2	1.9	1.6	1.6	1.9	0.9	1.3	1.3	1.1	1.5	1.7	1.8
	PrecMax	29.3	13.6	7.9	5.5	9.2	7.2	2.8	4.0	4.6	3.8	4.6	6.7	7.9
	PrecMin	8.3	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
	PrecStd	5.2	3.0	2.0	1.5	2.2	1.9	0.8	1.0	1.1	1.0	1.1	1.5	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.7	107.7	100.8	91.4	81.6	74.3	74.8	82.0	92.7	97.8	106.2	106.8
		MCWB	70.0	69.5	67.4	64.6	61.2	58.3	55.8	59.1	59.8	62.0	65.4	66.7
	2%	DB	104.5	102.4	96.2	87.5	78.0	70.7	70.6	76.5	87.0	93.4	100.3	102.2
		MCWB	68.6	68.5	66.8	63.6	59.5	57.2	54.9	55.6	58.5	61.5	63.8	66.4
	5%	DB	101.0	98.6	92.7	84.5	75.2	67.9	67.5	72.4	82.5	89.6	95.3	98.5
		MCWB	68.9	68.7	66.6	62.5	58.3	55.4	53.8	54.3	57.5	61.3	63.9	65.3
	10%	DB	97.6	94.8	89.6	81.7	72.3	65.0	64.2	68.9	78.2	85.8	90.8	95.1
		MCWB	68.3	67.9	66.1	61.8	57.2	54.2	52.4	52.9	56.4	60.5	63.7	65.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	76.1	74.4	70.2	65.6	62.3	62.2	62.8	65.5	69.3	72.8	74.3
		MCDB	91.8	88.1	83.6	80.2	70.6	67.9	66.1	73.7	74.9	80.8	82.1	86.1
	2%	WB	74.5	74.1	72.6	67.5	63.0	59.9	58.7	59.4	62.9	66.9	70.2	72.3
		MCDB	88.6	87.9	83.5	79.3	71.4	65.1	64.7	68.3	73.3	80.8	82.7	85.9
	5%	WB	73.1	72.7	70.9	65.4	61.0	58.1	56.2	56.8	60.9	65.1	68.6	70.8
		MCDB	88.1	87.4	82.5	77.3	70.9	64.1	63.1	67.5	74.0	79.6	82.1	84.8
	10%	WB	71.7	71.2	69.3	63.6	58.9	56.2	54.1	54.7	58.9	63.3	67.1	69.3
		MCDB	88.0	86.3	81.8	77.0	69.8	63.1	62.1	66.4	73.9	78.6	81.0	84.2
(35) Mean Daily Temperature Range	MDBR		24.7	23.8	24.3	26.2	26.2	23.2	25.2	28.1	29.8	28.8	26.4	26.6
	5% DB	MCDBR	28.2	28.5	28.3	29.1	29.4	27.1	29.4	32.9	36.1	33.4	31.5	31.2
		MCWBR	9.7	10.1	11.4	13.0	14.8	15.0	16.4	16.6	15.2	13.5	12.2	11.7
	5% WB	MCDBR	23.0	22.2	21.3	22.7	21.7	20.2	21.1	25.5	25.9	25.1	22.9	23.5
(40) Clear-Sky Solar Irradiance	taub		0.360	0.361	0.334	0.317	0.301	0.294	0.287	0.300	0.333	0.346	0.365	0.355
	taud		2.502	2.509	2.580	2.587	2.582	2.613	2.612	2.549	2.450	2.442	2.435	2.492
	Ebn at Noon		311	305	303	293	283	278	285	295	298	306	307	313
	Edh at Noon		36	35	31	28	25	23	24	28	34	37	39	37
(44) All-Sky Solar Radiation	RadAvg		2419	2204	1890	1542	1196	963	1098	1410	1798	2124	2281	2443
	RadStd		133	150	120	85	59	72	65	74	105	148	218	152

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+409	+365
(47) Regional (5 neighbors)		+1.04	N/A	N/A	+2.27	N/A	N/A	N/A	N/A	+486	+374

Nomenclature: See separate page