

PARKES, Australia

WMO: 957170

Lat: 33.1281S

Lon: 148.2428E

Elev: 324

StdP: 97.49

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.2	0.0	-5.7	2.4	18.8	-3.7	2.9	14.0	9.5	13.3	8.9	12.4	1.6	60	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	37.6	19.6	35.5	19.2	33.8	18.8	22.6	29.9	21.6	29.4	20.9	28.8	5.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	16.1	24.5	19.7	15.0	23.9	18.6	13.9	23.7	68.2	29.8	64.6	29.1	61.8	28.7	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.7	9.2	8.1	-3.0	41.0	1.1	2.1	-3.8	42.5	-4.5	43.8	-5.1	45.0	-5.9	46.6		
			-3.3	25.1	1.2	2.4	-4.1	26.8	-4.8	28.2	-5.5	29.5	-6.3	31.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	25.7	24.5	21.5	17.1	12.4	9.7	8.5	9.4	12.4	16.3	20.3	23.0
	DBStd	6.89	3.77	3.72	3.48	3.48	3.11	2.81	2.50	2.88	3.25	3.99	4.35	3.91
	HDD10.0	172	0	0	0	1	12	38	62	47	11	2	0	0
	HDD18.3	1407	1	2	12	62	186	258	306	277	180	89	27	7
	CDD10.0	2614	486	407	357	214	86	30	14	28	83	197	309	404
	CDD18.3	807	229	176	109	25	1	0	0	3	26	86	152	
	CDH23.3	9408	2768	1938	1055	258	7	0	0	2	49	380	1085	1866
	CDH26.7	4382	1481	957	397	54	0	0	0	5	116	480	892	
Wind	WSAvg	3.4	4.2	3.8	3.5	3.0	2.8	2.8	2.9	3.0	3.3	3.7	4.0	4.1
Precipitation	PrecAvg	634	70	54	46	45	58	39	52	56	46	60	55	52
	PrecMax	1008	252	206	137	299	205	104	133	114	117	162	186	136
	PrecMin	298	0	0	0	0	3	1	4	1	8	0	0	0
	PrecStd	169	63	48	34	50	42	26	30	30	28	39	43	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	39.7	35.1	30.9	24.4	20.5	18.9	23.1	27.1	32.4	37.9	38.4
		MCWB	20.2	20.9	18.8	17.5	15.3	13.7	12.6	14.3	14.7	16.0	19.0	18.8
	2%	DB	38.0	36.6	32.6	28.0	22.5	18.2	16.9	19.9	24.5	29.8	34.3	35.8
		MCWB	19.8	20.0	18.4	16.7	14.5	12.8	11.3	12.3	14.0	15.8	17.5	18.6
	5%	DB	35.8	34.2	30.5	26.2	20.8	16.8	15.5	18.0	22.4	27.6	31.7	33.7
		MCWB	19.7	19.5	18.0	15.8	13.6	12.1	10.8	11.6	13.5	15.3	17.1	18.3
	10%	DB	33.7	32.1	28.7	24.4	19.1	15.3	14.1	16.2	20.3	25.2	29.1	31.6
		MCWB	19.3	19.1	17.5	15.1	12.9	11.6	10.2	10.7	12.7	14.9	16.7	17.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	24.2	21.9	19.4	17.1	15.5	14.9	15.5	17.4	19.5	22.1	22.9
		MCDB	31.0	31.5	27.5	25.9	21.3	18.0	16.7	20.3	22.8	25.5	29.0	29.6
	2%	WB	22.2	22.8	20.6	17.9	15.8	14.1	12.8	13.7	16.0	18.0	20.2	21.3
		MCDB	31.0	29.6	27.3	24.1	19.9	16.6	15.0	17.7	21.5	24.3	28.2	28.6
	5%	WB	21.5	21.7	19.6	17.0	14.6	13.0	11.6	12.5	14.8	17.0	19.2	20.3
		MCDB	30.5	28.7	26.8	23.5	18.8	15.6	14.4	16.8	20.0	23.7	26.6	28.1
	10%	WB	20.8	20.9	18.8	16.1	13.6	12.0	10.6	11.2	13.7	16.1	18.2	19.4
		MCDB	29.7	27.9	26.1	22.6	18.1	15.0	13.3	15.6	18.6	22.8	25.3	27.5
Mean Daily Temperature Range	5% DB	MDBR	13.8	13.1	13.3	13.5	12.2	10.1	10.6	12.6	14.3	15.0	14.5	14.7
		MCDBR	16.0	15.6	15.2	15.3	14.3	12.2	13.2	15.4	17.8	18.0	17.4	16.8
		MCWBR	5.4	5.4	5.9	6.7	7.3	7.4	8.2	8.8	9.0	7.6	6.5	6.0
	5% WB	MCDBR	13.0	11.5	12.2	12.7	11.0	9.3	10.0	12.7	13.8	14.0	13.2	12.9
	MCWBR	5.2	4.8	5.5	6.1	6.1	6.2	6.7	7.9	7.9	6.8	5.7	5.8	
Clear-Sky Solar Irradiance	taub	0.345	0.347	0.321	0.304	0.288	0.283	0.278	0.286	0.315	0.327	0.342	0.337	
	taud	2.508	2.523	2.578	2.592	2.593	2.616	2.617	2.574	2.475	2.472	2.475	2.515	
	Ebn at Noon	993	970	962	927	892	872	895	933	952	979	989	1004	
	Edh at Noon	113	108	95	83	74	68	71	83	103	112	116	113	
All-Sky Solar Radiation	RadAvg	7.67	6.67	5.66	4.46	3.27	2.51	2.82	3.75	5.18	6.38	7.06	7.74	
	RadStd	0.39	0.49	0.39	0.31	0.20	0.21	0.18	0.28	0.38	0.48	0.62	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	-24	-92	+156	+72

Nomenclature: See separate page