

COONAMBLE, Australia

WMO: 957180

Lat: 30.9775S

Lon: 148.3797E

Elev: 597

StdP: 14.38

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.4	35.5	15.5	12.3	72.5	19.3	14.9	69.8	21.1	59.6	19.5	57.1	4.6	200	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	102.6	66.9	99.2	66.4	96.2	66.0	73.7	85.2	72.4	84.3	71.1	83.6	12.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	119.2	75.4	69.8	111.9	74.5	67.9	104.8	74.4	37.7	84.4	36.5	84.5	35.3	82.8	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	20.7	18.4	DB	28.6	108.0	1.5	4.4	27.5	111.2	26.6	113.8	25.7	116.3	24.6	119.5	(4)
(5)			WB	27.3	76.6	1.8	2.1	26.0	78.0	24.9	79.2	23.9	80.4	22.6	81.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	81.9	79.8	74.7	66.8	58.0	52.8	50.8	52.8	59.3	67.2	73.5	77.9	(6)	
	DBStd	12.26	6.29	6.12	5.75	5.47	5.35	4.57	4.53	5.11	6.00	6.70	6.77	6.35	(7)	
	HDD50	99	0	0	0	0	4	23	43	26	3	0	0	0	(8)	
	HDD65	1709	0	1	4	43	222	365	439	381	189	55	9	1	(9)	
	CDD50	6022	987	833	767	505	253	109	70	112	282	533	706	865	(10)	
	CDD65	2156	523	414	306	97	6	0	0	2	19	123	265	401	(11)	
	CDH74	26476	6812	4998	3184	946	74	0	0	31	433	1644	3300	5054	(12)	
	CDH80	13331	3894	2691	1410	223	3	0	0	3	123	655	1623	2706	(13)	
(14) Wind	WSAvg	9.5	10.9	10.5	9.8	8.4	8.1	8.2	7.9	8.5	9.3	10.2	10.9	10.9	(14)	
(15) Precipitation	PrecAvg	20.5	3.1	1.9	1.7	1.4	1.9	1.0	1.4	1.5	1.3	1.8	1.5	1.9	(15)	
	PrecMax	36.3	11.6	6.3	5.0	7.4	9.1	2.9	4.4	4.2	3.2	7.0	3.3	5.7	(16)	
	PrecMin	11.7	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0	0.0	(17)	
	PrecStd	5.5	2.8	1.6	1.4	1.7	1.9	0.8	1.0	1.1	0.9	1.4	1.2	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.7	106.9	98.3	89.4	79.2	71.6	71.7	77.7	88.8	95.4	103.9	105.0	(19)	
		MCWB	69.4	68.0	65.8	62.4	59.3	57.1	54.0	56.7	58.3	60.4	65.3	65.8	(20)	
	2%	DB	102.6	100.6	94.1	85.2	76.0	68.5	68.0	73.0	83.4	90.8	97.7	100.1	(21)	
		MCWB	67.6	67.3	65.7	62.7	58.6	55.7	53.9	54.3	57.0	61.1	63.3	64.9	(22)	
	5%	DB	99.1	96.9	90.8	82.4	73.4	66.0	65.0	69.4	78.9	87.0	93.4	96.2	(23)	
		MCWB	67.8	67.3	65.6	61.5	57.4	54.9	52.9	53.2	56.1	60.0	62.7	64.7	(24)	
	10%	DB	95.8	93.2	87.7	79.6	70.6	63.2	62.2	66.3	74.6	83.3	89.1	93.0	(25)	
		MCWB	67.3	66.6	64.8	60.7	56.3	53.7	52.1	51.9	55.3	59.6	62.9	64.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.1	75.3	73.4	69.2	65.1	61.6	62.4	61.9	64.7	68.8	71.7	74.3	(27)	
		MCDB	82.7	89.8	80.9	77.4	69.7	65.2	64.3	68.8	72.1	76.9	80.2	83.6	(28)	
	2%	WB	73.9	73.5	71.5	66.5	62.2	59.4	58.3	58.6	62.5	66.3	69.3	72.1	(29)	
		MCDB	86.5	85.6	81.1	75.7	69.3	62.6	62.1	65.5	71.6	76.4	81.0	80.9	(30)	
	5%	WB	72.4	72.0	69.8	64.5	60.1	57.6	55.6	56.0	60.2	64.4	67.9	70.3	(31)	
		MCDB	86.7	84.1	80.3	75.5	68.5	62.3	61.1	65.6	70.1	76.8	79.6	80.9	(32)	
	10%	WB	71.1	70.4	68.1	63.0	58.1	55.7	53.4	53.8	58.0	62.4	66.4	68.9	(33)	
		MCDB	85.9	84.2	80.7	75.2	67.5	61.1	60.2	63.9	69.1	76.2	79.6	81.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.7	23.2	22.9	24.2	23.6	20.5	22.5	25.9	27.8	27.3	25.8	24.9	(35)	
		MCDBR	27.3	27.4	26.3	26.4	26.3	24.0	26.5	30.0	34.4	32.3	30.8	29.3	(36)	
	5% WB	MCWBR	8.6	8.6	9.4	10.8	12.3	12.9	14.8	15.3	14.6	12.3	10.6	10.3	(37)	
		MCWBR	21.7	21.2	20.2	21.2	19.7	17.6	19.6	24.0	24.1	24.2	22.5	22.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.355	0.358	0.331	0.311	0.295	0.290	0.284	0.294	0.325	0.339	0.357	0.349	(40)	
		taud	2.509	2.515	2.585	2.599	2.594	2.616	2.612	2.558	2.463	2.462	2.459	2.508	(41)	
	Ebn at Noon		312	305	304	294	284	278	285	295	300	308	310	315	(42)	
		Edh at Noon	36	35	30	27	24	22	23	28	34	36	38	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2423	2190	1855	1498	1150	915	1040	1347	1759	2097	2270	2455	(44)	
	RadStd		128	148	126	86	60	64	61	77	104	146	223	142	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-142	+448	+344

Nomenclature: See separate page