

COONAMBLE, Australia

WMO: 957180

Lat: 30.9775S

Lon: 148.3797E

Elev: 182

StdP: 99.16

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 0.8	(c) 2.0	(d) -9.2	(e) 1.8	(f) 22.5	(g) -7.0	(h) 2.1	(i) 21.0	(j) 9.5	(k) 15.3	(l) 8.7	(m) 13.9	(n) 2.1	(o) 200	(p) 0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 13.2	(c) 39.2	(d) 19.4	(e) 37.3	(f) 19.1	(g) 35.7	(h) 18.9	(i) 23.2	(j) 29.5	(k) 22.4	(l) 29.1	(m) 21.7	(n) 28.7	(o) 5.4	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.0	24.1	21.0	16.0	23.6	19.9	15.0	23.6	69.9	29.1	67.0	29.2	64.2	28.2	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	9.3	8.2	-1.9	42.2	0.8	2.5	-2.5	44.0	-3.0	45.4	-3.5	46.8	-4.1	48.6
			-2.6	24.8	1.0	1.1	-3.3	25.6	-3.9	26.2	-4.5	26.9	-5.2	27.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	27.7	26.5	23.7	19.3	14.5	11.6	10.5	11.5	15.2	19.6	23.1	25.5
	DBStd	6.81	3.49	3.40	3.20	3.04	2.97	2.54	2.51	2.84	3.34	3.72	3.76	3.53
	HDD10.0	55	0	0	0	0	2	13	24	14	2	0	0	0
	HDD18.3	949	0	1	2	24	123	203	244	212	105	31	5	1
	CDD10.0	3346	548	463	426	281	141	61	39	62	157	296	392	481
	CDD18.3	1198	291	230	170	54	3	0	0	1	11	68	147	223
	CDH23.3	14709	3784	2777	1769	526	41	0	0	17	241	913	1833	2808
	CDH26.7	7406	2163	1495	783	124	2	0	0	2	68	364	902	1503
Wind	WSAvg	4.2	4.9	4.7	4.4	3.8	3.6	3.7	3.5	3.8	4.1	4.6	4.9	4.9
Precipitation	PrecAvg	521	79	48	43	36	49	25	35	39	32	45	39	48
	PrecMax	923	294	159	126	187	230	73	111	106	81	178	83	144
	PrecMin	296	0	0	0	0	2	1	0	0	0	4	0	0
	PrecStd	140	70	41	35	42	48	20	25	29	23	36	30	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	41.6	36.8	31.9	26.2	22.0	22.1	25.4	31.6	35.2	40.0	40.5
		MCWB	20.8	20.0	18.8	16.9	15.2	14.0	12.2	13.7	14.6	15.8	18.5	18.8
	2%	DB	39.2	38.1	34.5	29.6	24.5	20.3	20.0	22.8	28.6	32.7	36.5	37.8
		MCWB	19.8	19.6	18.7	17.0	14.8	13.1	12.2	12.4	13.9	16.2	17.4	18.3
	5%	DB	37.3	36.1	32.7	28.0	23.0	18.9	18.4	20.8	26.0	30.5	34.1	35.7
		MCWB	19.9	19.6	18.7	16.4	14.1	12.7	11.6	11.8	13.4	15.6	17.0	18.1
	10%	DB	35.4	34.0	31.0	26.5	21.5	17.3	16.8	19.0	23.7	28.5	31.7	33.9
		MCWB	19.6	19.2	18.2	15.9	13.5	12.0	11.2	11.1	13.0	15.4	17.2	17.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	24.1	23.0	20.7	18.4	16.4	16.9	16.6	18.2	20.4	22.1	23.5
		MCDB	28.2	32.1	27.2	25.2	20.9	18.4	18.0	20.5	22.3	25.0	26.8	28.7
	2%	WB	23.3	23.1	21.9	19.2	16.8	15.2	14.6	14.8	16.9	19.0	20.7	22.3
		MCDB	30.3	29.8	27.3	24.3	20.7	17.0	16.7	18.6	22.0	24.7	27.2	27.2
	5%	WB	22.4	22.2	21.0	18.1	15.6	14.2	13.1	13.3	15.7	18.0	20.0	21.3
		MCDB	30.4	28.9	26.8	24.2	20.3	16.8	16.2	18.7	21.1	24.9	26.4	27.2
	10%	WB	21.7	21.3	20.1	17.2	14.5	13.2	11.9	12.1	14.4	16.9	19.1	20.5
		MCDB	29.9	29.0	27.1	24.0	19.7	16.2	15.7	17.7	20.6	24.5	26.4	27.5
Mean Daily Temperature Range	5% DB	MDBR	13.2	12.9	12.7	13.5	13.1	11.4	12.5	14.4	15.4	15.1	14.3	13.8
		MCDBR	15.2	15.2	14.6	14.7	14.6	13.3	14.7	16.7	19.1	17.9	17.1	16.3
		MCWBR	4.8	4.8	5.2	6.0	6.8	7.1	8.2	8.5	8.1	6.9	5.9	5.7
	5% WB	MCDBR	12.0	11.8	11.2	11.8	10.9	9.8	10.9	13.3	13.4	13.5	12.5	12.2
		MCWBR	4.6	4.4	4.7	5.3	5.9	6.4	7.2	7.7	7.5	6.5	5.4	5.2
Clear-Sky Solar Irradiance	taub	0.355	0.358	0.331	0.311	0.295	0.290	0.284	0.294	0.325	0.339	0.357	0.349	
	taud	2.509	2.515	2.585	2.599	2.594	2.616	2.612	2.558	2.463	2.462	2.459	2.508	
	Ebn at Noon	984	963	958	927	895	877	899	931	947	971	976	993	
	Edh at Noon	114	109	96	85	76	70	74	87	106	114	119	114	
All-Sky Solar Radiation	RadAvg	7.64	6.90	5.85	4.72	3.62	2.88	3.28	4.25	5.54	6.61	7.16	7.74	
	RadStd	0.40	0.47	0.40	0.27	0.19	0.20	0.19	0.24	0.33	0.46	0.70	0.45	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-79	+249	+191

Nomenclature: See separate page