

TEMORA, Australia

WMO: 957220

Lat: 34.4292S

Lon: 147.5111E

Elev: 281

StdP: 97.99

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.8	-0.8	-5.3	2.5	18.6	-3.6	2.9	12.7	9.6	11.0	8.9	10.9	1.0	190	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.2	38.6	19.3	36.4	18.9	34.4	18.3	21.9	30.8	21.1	29.6	20.5	29.0	5.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.3	23.4	19.0	14.3	23.3	17.9	13.3	23.1	65.4	30.9	62.5	29.7	60.1	28.4	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.6	7.8	-3.5	41.8	1.1	1.8	-4.3	43.2	-4.9	44.2	-5.5	45.2	-6.3	46.6		
(5)			-4.0	23.6	1.2	1.1	-4.8	24.3	-5.6	25.0	-6.2	25.6	-7.1	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	25.5	24.2	21.3	16.3	11.5	8.8	7.9	8.4	11.2	15.7	19.7	22.2		
	DBStd	7.00	3.85	3.64	3.58	3.40	2.70	2.47	2.16	2.29	2.74	3.95	4.09	3.87		
	HDD10.0	221	0	0	0	2	15	51	73	62	16	2	0	0		
	HDD18.3	1585	1	2	15	78	212	285	324	309	215	103	31	9		
	CDD10.0	2414	481	398	349	189	61	17	7	11	52	177	292	379		
	CDD18.3	737	224	167	106	16	1	0	0	0	1	20	73	130		
	CDH23.3	9544	2950	1898	1141	236	4	0	0	1	36	422	1063	1793		
	CDH26.7	4679	1679	962	466	55	0	0	0	0	5	142	479	890		
(14) Wind	WSAvg	3.5	4.3	4.2	3.9	3.1	2.7	2.8	2.9	3.0	3.4	3.7	4.1	4.2		
(15) Precipitation	PrecAvg	552	50	34	36	48	53	38	53	53	50	53	45	43		
	PrecMax	949	288	148	161	207	128	127	149	117	138	161	207	148		
	PrecMin	220	0	0	0	0	2	1	0	7	7	1	3	0		
	PrecStd	171	59	33	39	53	38	28	34	27	31	38	42	38		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	40.9	36.0	31.2	23.7	18.7	17.5	20.7	27.0	33.1	38.1	39.9		
		MCWB	20.3	20.8	18.4	16.7	14.8	12.2	12.4	13.4	14.0	15.6	18.4	18.3		
	2%	DB	39.1	37.3	33.2	28.1	21.7	16.7	15.7	18.1	23.7	30.3	34.3	36.5		
		MCWB	19.7	19.2	18.1	16.3	13.9	11.7	11.5	12.0	13.1	15.3	16.9	18.2		
	5%	DB	37.0	34.5	31.1	26.0	20.0	15.4	14.4	16.3	21.5	27.9	31.8	34.0		
		MCWB	19.5	18.9	17.6	15.5	13.2	11.2	10.7	10.9	12.7	15.3	16.9	17.7		
	10%	DB	34.8	32.2	29.3	24.0	18.2	14.2	13.1	14.7	19.3	25.5	29.2	31.7		
		MCWB	19.0	18.4	17.2	14.9	12.5	10.8	9.8	10.1	12.1	14.5	16.2	17.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.7	21.4	19.1	16.8	13.9	15.0	14.2	16.2	18.8	21.0	22.1		
		MCDB	32.4	29.2	27.0	25.6	19.7	15.4	15.7	18.1	21.3	25.4	29.0	28.1		
	2%	WB	21.9	22.0	20.3	17.8	15.0	12.9	12.3	12.9	15.0	17.7	19.7	20.6		
		MCDB	32.2	30.2	26.3	23.1	20.4	15.0	14.6	17.3	20.9	24.3	27.6	27.9		
	5%	WB	21.2	21.1	19.5	16.8	14.0	12.0	11.1	11.5	13.9	16.7	18.7	19.8		
		MCDB	31.1	28.8	26.2	22.6	18.6	14.6	13.7	15.4	19.3	23.8	27.4	27.2		
	10%	WB	20.6	20.1	18.6	15.8	13.0	11.3	10.2	10.5	12.7	15.7	17.6	18.7		
		MCDB	30.5	28.6	26.0	22.5	17.4	13.9	12.7	14.2	18.1	23.1	25.8	27.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	13.8	13.6	14.2	13.2	10.6	10.4	12.4	15.0	16.1	15.3	15.5		
		MCDBR	18.1	17.2	16.4	17.2	15.9	12.8	13.1	15.6	19.8	20.4	19.1	18.6		
		MCWBR	5.5	5.5	5.8	7.8	9.0	8.3	8.9	9.9	10.5	8.7	6.6	6.0		
		MCDBR	14.1	12.6	11.4	13.3	13.3	9.9	11.2	13.5	15.3	15.2	14.3	13.1		
	5% WB	MCWBR	5.1	4.7	4.9	6.5	7.9	6.7	8.0	9.0	9.3	7.6	5.6	5.5		
(40) Clear-Sky Solar Irradiance	taub		0.347	0.340	0.321	0.306	0.293	0.285	0.281	0.288	0.316	0.325	0.342	0.336		
	taud		2.468	2.520	2.550	2.559	2.562	2.597	2.604	2.562	2.465	2.468	2.461	2.491		
	Ebn at Noon		989	975	959	918	877	859	884	925	947	980	988	1004		
	Edh at Noon		118	107	97	85	74	67	70	83	104	112	118	116		
(44) All-Sky Solar Radiation	RadAvg		7.72	6.74	5.72	4.32	3.11	2.37	2.61	3.54	4.98	6.29	7.05	7.79		
	RadStd		0.40	0.43	0.35	0.24	0.17	0.20	0.15	0.28	0.41	0.48	0.55	0.27		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.44	N/A	N/A	+1.16	N/A	N/A	N/A	N/A	+119	N/A

Nomenclature: See separate page