

COONABARABRAN AP, Australia

WMO: 957280

Lat: 31.3303S

Lon: 149.2700E

Elev: 2118

StdP: 13.61

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.0	38.7	18.6	15.1	63.2	22.5	18.3	62.1	21.3	52.7	20.0	50.8	10.2	210	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	95.2	65.8	92.2	64.8	89.1	64.2	70.5	83.1	69.2	81.4	68.0	80.1	11.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	109.2	72.6	65.9	103.5	72.5	64.5	98.3	71.7	35.8	82.4	34.6	81.1	33.6	79.9	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	19.1	17.4	DB	33.2	100.5	1.2	4.6	32.3	103.8	31.5	106.5	30.9	109.1	30.0	112.4	(4)
(5)			WB	31.7	73.1	0.9	1.6	31.0	74.2	30.5	75.2	29.9	76.0	29.3	77.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	75.6	73.6	69.1	62.9	55.9	50.3	49.1	51.5	57.4	63.1	68.1	72.3	(6)
(7)		DBStd	10.73	6.30	6.35	5.41	5.36	4.81	3.92	4.28	4.99	6.34	6.91	6.94	6.55	(7)
(8)		HDD50	172	0	0	0	1	10	43	68	41	7	2	0	0	(8)
(9)		HDD65	2182	3	5	22	100	284	441	492	418	242	120	42	13	(9)
(10)		CDD50	4681	795	662	591	388	192	52	42	88	229	409	543	690	(10)
(11)		CDD65	1216	333	247	148	37	1	0	0	0	14	62	135	239	(11)
(12)		CDH74	11542	3430	2408	1071	182	1	0	0	2	90	509	1370	2479	(12)
(13)		CDH80	4563	1551	1025	291	19	0	0	0	0	11	108	518	1040	(13)
(14)	Wind	WSAvg	9.6	10.2	9.9	9.2	8.3	8.5	8.8	9.3	9.7	10.2	10.1	10.4	10.5	(14)
(15)	Precipitation	PrecAvg	28.1	3.2	2.9	2.0	1.8	1.7	2.5	2.1	1.7	2.0	2.0	2.9	3.3	(15)
(16)		PrecMax	47.1	8.9	6.1	6.2	9.3	4.3	6.1	8.4	4.7	8.1	5.7	11.7	9.3	(16)
(17)		PrecMin	14.6	0.0	0.6	0.0	0.0	0.0	0.8	0.1	0.1	0.1	0.0	0.3	0.6	(17)
(18)		PrecStd	7.5	2.3	1.6	1.6	2.1	1.3	1.4	1.8	1.3	1.7	1.5	2.5	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.0	99.3	90.0	82.8	72.4	63.8	65.6	70.8	81.4	87.2	96.5	97.1	(19)
(20)			MCWB	67.3	67.2	64.5	61.0	56.5	52.9	53.1	53.3	55.8	59.3	63.6	63.4	(20)
(21)		2%	DB	95.0	94.1	86.7	78.7	69.2	61.7	61.9	67.0	76.4	82.9	90.3	93.0	(21)
(22)			MCWB	66.3	66.9	63.7	60.6	55.5	51.9	50.2	51.5	55.1	58.7	62.0	63.5	(22)
(23)		5%	DB	91.9	90.3	83.2	75.7	66.9	59.7	59.3	63.8	72.3	79.6	85.7	89.4	(23)
(24)			MCWB	66.0	65.2	62.7	59.2	54.2	50.9	49.9	50.3	53.7	58.1	61.2	62.6	(24)
(25)		10%	DB	88.4	86.4	80.0	72.9	64.5	57.3	56.9	60.9	68.9	76.3	81.8	86.1	(25)
(26)			MCWB	65.7	64.4	62.7	58.2	53.1	50.1	48.7	48.7	52.6	57.3	60.6	62.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.6	73.1	69.8	66.1	60.9	56.5	58.3	58.4	60.9	64.7	68.6	70.1	(27)
(28)			MADB	86.3	87.6	78.4	74.1	64.8	59.1	60.7	65.8	71.8	74.5	83.0	82.6	(28)
(29)		2%	WB	70.8	70.5	68.3	63.3	58.6	54.8	54.6	54.8	58.5	62.7	66.3	68.2	(29)
(30)			MADB	83.8	83.6	76.3	71.9	65.0	57.8	56.9	60.7	68.7	73.3	78.4	79.4	(30)
(31)		5%	WB	69.4	68.7	66.6	61.4	56.5	53.2	52.1	52.5	56.5	61.1	64.9	67.0	(31)
(32)			MADB	82.2	81.5	75.6	71.4	63.6	56.9	56.1	60.5	66.5	72.5	76.5	78.6	(32)
(33)		10%	WB	68.3	67.1	65.1	59.8	54.8	51.7	49.8	50.4	54.6	59.5	63.5	65.7	(33)
(34)			MADB	81.4	80.0	75.1	69.8	62.3	56.2	55.7	59.0	65.0	72.1	75.2	77.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	20.8	20.6	18.6	18.1	15.5	13.3	13.9	16.0	18.0	20.1	21.1	21.6	(35)
(36)			MCDBR	24.1	24.2	22.0	20.1	17.4	16.0	16.8	19.0	21.2	23.0	25.5	25.2	(36)
(37)			MCWBR	8.2	8.3	8.8	8.6	8.2	8.4	9.1	9.7	9.9	10.0	9.4	9.1	(37)
(38)		5% WB	MCDBR	20.4	20.7	18.0	18.1	14.5	12.4	12.6	16.3	17.5	20.3	19.9	20.2	(38)
(39)			MCWBR	8.6	8.4	9.0	8.7	8.2	7.6	8.9	10.2	10.0	10.8	9.1	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.341	0.314	0.296	0.280	0.275	0.270	0.278	0.309	0.323	0.343	0.335	(40)	
(41)		taud	2.535	2.560	2.637	2.647	2.642	2.660	2.659	2.617	2.511	2.507	2.492	2.545	(41)	
(42)		Ebn at Noon	316	311	309	299	290	284	291	301	306	313	314	319	(42)	
(43)		Edh at Noon	35	33	29	25	23	21	22	26	32	35	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2353	2125	1788	1455	1118	885	1012	1310	1724	2042	2207	2388	(44)	
(45)		RadStd	137	163	129	88	65	66	60	80	109	160	228	158	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+1.04	N/A	N/A	+2.27	N/A	N/A	-32	-151	+382	+261

Nomenclature: See separate page