

MURRURUNDI GAP, Australia

WMO: 957470

Lat: 31.7417S

Lon: 150.7936E

Elev: 730

StdP: 92.86

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.3	3.3	-6.6	2.3	15.5	-4.6	2.8	14.1	16.5	9.5	15.1	8.7	5.8	130	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	32.7	18.0	31.0	17.7	29.3	17.4	20.7	26.7	20.0	26.1	19.3	25.2	6.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	15.3	22.3	18.3	14.5	21.5	17.6	13.8	21.0	63.1	26.8	60.6	25.9	58.3	25.5	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.7	13.0	11.6	DB	0.0	35.6	1.0	2.2	-0.7	37.2	-1.3	38.4	-1.9	39.7	-2.6	41.3	(4)
(5)			WB	-1.2	22.5	0.8	0.9	-1.7	23.2	-2.2	23.7	-2.6	24.2	-3.2	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	22.1	21.0	19.1	15.8	12.4	9.3	8.6	10.0	13.2	16.1	18.5	20.3
	DBStd	5.55	3.49	3.37	2.88	2.89	2.71	2.28	2.37	2.77	3.37	3.77	3.81	3.56
	HDD10.0	151	0	0	0	1	9	39	58	35	7	2	0	0
	HDD18.3	1459	7	10	26	84	186	272	303	259	159	90	43	21
	CDD10.0	2151	374	308	281	176	82	17	13	34	102	191	255	318
	CDD18.3	416	122	85	48	9	0	0	0	0	3	21	47	80
	CDH23.3	3472	1127	716	296	34	0	0	0	0	17	133	431	718
	CDH26.7	1122	429	248	59	2	0	0	0	0	1	19	131	232
Wind	WSAvg	6.1	6.3	6.6	6.1	5.8	5.2	6.1	6.1	6.1	6.1	6.2	6.3	6.4
Precipitation	PrecAvg	744	74	71	52	41	47	63	53	50	55	61	81	99
	PrecMax	1144	226	265	161	145	105	172	211	114	134	153	278	166
	PrecMin	378	7	0	11	3	0	17	2	0	5	0	14	29
	PrecStd	170	55	59	36	33	31	41	44	34	32	39	53	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	34.7	30.4	26.5	21.2	17.3	16.7	20.0	25.4	28.7	33.6	33.7
		MCWB	19.7	18.8	17.7	15.6	13.1	11.3	11.2	11.9	12.7	14.2	17.7	18.1
	2%	DB	32.8	31.8	28.3	24.1	19.5	14.8	15.1	17.8	23.0	26.4	30.1	31.4
		MCWB	18.4	18.2	17.5	15.1	12.6	10.4	9.9	10.3	12.1	14.1	16.3	17.1
	5%	DB	30.9	29.8	26.5	22.5	18.1	13.7	13.8	16.4	21.0	24.7	27.7	29.5
		MCWB	18.3	17.8	17.1	14.8	12.0	10.2	9.5	9.6	11.6	13.8	15.9	16.7
	10%	DB	29.1	27.6	24.8	20.9	16.8	12.7	12.6	15.0	19.2	22.9	25.7	27.5
		MCWB	18.2	17.9	16.7	14.4	11.5	9.9	8.9	8.8	11.1	13.6	15.3	16.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.8	20.2	18.1	15.6	12.9	13.7	13.7	15.1	17.7	19.6	20.7
		MCDB	28.5	29.0	25.2	21.5	17.2	13.9	15.1	18.3	20.5	21.8	27.5	26.3
	2%	WB	20.9	20.6	19.3	16.8	14.3	11.9	11.9	11.8	14.2	16.5	18.5	19.6
		MCDB	26.8	27.0	24.1	21.2	17.1	13.4	13.3	15.2	18.8	21.7	25.5	25.5
	5%	WB	20.2	19.7	18.6	15.8	13.1	11.2	10.6	10.6	13.2	15.6	17.7	18.9
		MCDB	26.3	25.8	23.3	20.4	16.8	12.7	12.2	14.6	18.3	21.1	23.9	24.5
	10%	WB	19.5	19.0	17.9	15.0	12.2	10.5	9.3	9.6	12.2	14.7	16.9	18.2
		MCDB	25.6	24.9	22.5	19.2	15.8	12.1	11.8	13.7	17.3	20.3	22.6	24.0
Mean Daily Temperature Range	5% DB	MDBR	10.7	10.2	9.1	8.4	7.3	5.7	6.4	7.7	8.9	9.9	10.3	10.7
		MCDBR	13.1	13.4	11.4	10.1	8.2	6.9	7.5	9.0	10.8	11.8	12.8	13.4
		MCWBR	3.8	4.1	4.0	4.1	4.0	3.9	4.4	4.8	4.8	4.8	4.5	4.3
	5% WB	MCDBR	10.7	10.8	9.4	9.0	7.1	5.0	5.5	7.5	8.7	10.1	10.4	10.5
		MCWBR	4.3	4.3	4.1	4.1	4.1	3.4	4.3	4.8	4.9	5.4	4.7	4.8
Clear-Sky Solar Irradiance	taub	0.342	0.343	0.318	0.297	0.280	0.275	0.270	0.278	0.306	0.322	0.345	0.339	
	taud	2.532	2.549	2.609	2.640	2.644	2.661	2.658	2.621	2.519	2.507	2.485	2.529	
	Ebn at Noon	997	977	969	940	911	892	914	949	965	987	988	1003	
	Edh at Noon	111	105	93	81	71	66	69	81	100	109	116	112	
All-Sky Solar Radiation	RadAvg	7.04	6.27	5.26	4.30	3.36	2.65	3.05	4.00	5.27	6.12	6.58	7.08	
	RadStd	0.47	0.52	0.44	0.31	0.24	0.22	0.21	0.27	0.35	0.55	0.67	0.54	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	-88	+172	+89

Nomenclature: See separate page