

MERRIWA, Australia

WMO: 957540

Lat: 32.1853S

Lon: 150.1736E

Elev: 1232

StdP: 14.05

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 30.3	(c) 32.8	(d) 22.1	(e) 17.3	(f) 57.5	(g) 25.9	(h) 20.8	(i) 53.7	(j) 23.8	(k) 58.5	(l) 21.9	(m) 56.5	(n) 2.7	(o) 280	(p) 0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 24.4	(c) 97.9	(d) 68.3	(e) 94.4	(f) 67.3	(g) 91.1	(h) 66.6	(i) 73.0	(j) 86.9	(k) 71.5	(l) 83.9	(m) 70.2	(n) 82.3	(o) 11.4	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	114.9	75.8	68.3	109.0	74.6	67.1	104.2	73.7	37.5	87.2	36.1	83.6	35.0	82.1	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.8	(b) 19.5	(c) 17.6	(e) 25.3	(f) 103.9	(g) 1.5	(h) 5.1	(i) 24.3	(j) 107.6	(k) 23.4	(l) 110.6	(m) 22.6	(n) 113.4	(o) 21.6	(p) 117.1		
(a) 21.8	(b) 19.5	(c) 17.6	(e) 24.8	(f) 76.8	(g) 1.7	(h) 2.3	(i) 23.6	(j) 78.4	(k) 22.6	(l) 79.8	(m) 21.7	(n) 81.1	(o) 20.5	(p) 82.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	75.0	72.6	68.9	61.6	54.3	50.0	48.3	50.2	55.9	61.9	67.9	71.4		
	DBStd	10.59	6.02	5.91	4.94	5.06	4.23	3.87	3.86	4.11	4.98	6.44	6.17	6.11		
	HDD50	191	0	0	0	1	10	46	81	47	4	2	0	0		
	HDD65	2380	3	6	17	125	333	451	519	460	276	139	37	14		
	CDD50	4364	775	632	586	349	142	46	27	52	182	371	538	664		
	CDD65	1077	313	217	138	24	0	0	0	0	4	43	125	213		
	CDH74	12321	3446	2207	1233	269	9	0	0	5	184	839	1661	2468		
(13)	CDH80	5559	1792	1039	429	60	0	0	0	0	38	300	718	1183		
(14)	Wind	WSAvg	8.1	9.0	9.4	8.0	6.9	6.7	7.6	8.1	8.2	8.4	8.9	9.1		
(15) Precipitation	PrecAvg	24.6	2.6	2.7	1.7	1.5	1.3	1.9	1.6	1.5	1.7	2.1	2.7	3.3		
	PrecMax	36.3	5.3	9.0	5.8	5.4	4.2	10.5	6.3	4.1	4.6	6.1	6.5	6.8		
	PrecMin	13.5	0.3	0.2	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.2	0.4	0.6		
	PrecStd	5.5	1.6	1.9	1.5	1.5	1.1	2.0	1.3	1.1	1.2	1.3	1.6	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.1	102.4	93.3	86.5	75.3	66.6	69.2	74.3	84.1	92.0	99.4	100.1		
		MCWB	71.1	68.5	66.1	62.9	58.2	55.1	55.7	55.3	58.0	62.2	66.8	67.4		
	2%	DB	98.2	95.7	89.3	80.7	71.6	63.1	64.9	70.0	79.5	87.4	92.7	95.3		
		MCWB	69.2	68.6	66.9	62.8	57.9	53.7	51.7	53.0	56.8	60.9	64.3	67.2		
	5%	DB	94.2	91.2	84.7	76.5	68.4	60.9	61.4	66.1	74.6	83.1	87.9	91.5		
		MCWB	68.6	68.0	66.3	61.9	56.3	52.7	51.2	52.0	55.7	60.7	64.1	65.5		
	10%	DB	90.3	86.2	81.0	73.2	65.5	58.8	58.6	62.3	70.4	78.4	83.5	87.1		
		MCWB	68.4	67.6	65.8	60.9	55.3	52.2	50.6	50.5	54.7	59.5	62.8	65.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.2	74.7	73.5	68.4	63.7	58.4	60.4	59.2	62.1	67.8	70.2	72.8		
		MCDB	92.4	88.8	79.9	75.8	67.6	62.8	64.9	67.3	73.8	81.4	87.9	88.4		
	2%	WB	73.2	72.9	70.7	65.5	60.8	56.4	55.9	56.0	60.2	65.2	68.3	70.5		
		MCDB	88.7	85.5	79.6	73.1	67.0	59.8	59.4	64.5	70.9	77.6	82.9	84.2		
	5%	WB	71.8	71.1	69.1	64.0	58.5	54.9	53.3	53.7	58.3	63.3	67.0	69.1		
		MCDB	85.1	82.6	77.7	72.0	65.1	58.2	57.7	62.8	68.9	75.6	80.1	81.8		
	10%	WB	70.5	69.6	67.5	62.4	56.7	53.8	51.3	51.8	56.4	61.6	65.6	67.8		
		MCDB	83.2	81.0	76.0	70.9	63.5	57.2	56.7	60.2	66.9	73.9	77.6	80.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.4	23.1	22.4	23.5	23.7	19.7	22.5	25.2	27.5	27.6	25.9	25.0		
		MCDBR	32.9	31.6	29.1	27.9	28.3	23.1	27.4	32.5	35.7	36.1	34.2	33.4		
		MCWBR	9.9	10.1	11.4	12.5	15.5	14.3	16.6	17.7	17.0	14.7	11.8	10.8		
	5% WB	MCDBR	25.3	24.2	23.1	23.0	22.9	17.7	20.9	26.9	27.5	28.1	26.5	25.5		
		MCWBR	9.3	9.6	10.7	11.6	13.5	11.9	14.6	15.9	15.3	13.8	10.7	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.360	0.359	0.333	0.310	0.292	0.285	0.280	0.288	0.317	0.334	0.360	0.353		
	taud		2.502	2.527	2.584	2.621	2.618	2.645	2.643	2.603	2.510	2.494	2.463	2.508		
	Ebn at Noon		310	305	302	293	283	278	285	297	302	309	308	313		
	Edh at Noon		36	34	30	26	23	21	22	26	32	35	37	36		
(44) All-Sky Solar Radiation	RadAvg		2253	1988	1665	1353	1053	826	954	1254	1662	1949	2101	2286		
	RadStd		141	165	144	102	69	65	63	81	108	176	208	171		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	-14	-155	+311	+162

Nomenclature: See separate page