

SCONE, Australia

WMO: 957580

Lat: 32.0336S

Lon: 150.8264E

Elev: 728

StdP: 14.31

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.7	32.9	22.8	17.6	61.7	26.4	20.9	53.6	24.9	57.1	22.1	59.0	1.8	290	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	98.7	68.1	95.1	67.5	91.7	67.0	73.4	85.8	72.0	84.3	70.8	82.6	11.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.4	115.0	75.8	69.0	109.7	74.8	67.7	104.5	73.9	37.4	85.5	36.2	84.4	35.1	82.7	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.8	20.3	18.2	DB	26.8	104.4	1.0	4.3	26.0	107.5	25.4	110.0	24.8	112.4	24.1	115.5
			WB	26.2	76.0	1.2	1.4	25.3	77.0	24.6	77.8	24.0	78.6	23.1	79.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	75.3	74.0	69.7	62.8	55.9	51.3	49.7	51.8	57.6	63.1	68.6	72.7
	DBStd	10.39	5.99	5.64	5.06	4.75	4.62	4.26	4.11	4.90	5.31	5.93	6.67	5.84
	HDD50	132	0	0	0	0	5	35	57	33	2	0	0	0
	HDD65	2071	1	3	12	96	283	410	475	410	231	107	36	7
	CDD50	4748	785	671	612	383	188	75	47	90	231	407	557	702
	CDD65	1211	322	254	159	29	1	0	0	1	10	49	142	244
	CDH74	13825	3634	2538	1467	380	30	0	0	22	243	874	1794	2843
	CDH80	6296	1906	1211	548	79	1	0	0	1	54	299	810	1387
(14) Wind	WSAvg	7.3	8.8	8.7	7.6	6.2	5.5	5.7	6.0	7.0	7.3	7.6	8.6	8.7
(15) Precipitation	PrecAvg	27.9	4.3	2.5	2.6	1.8	2.3	1.7	1.5	1.6	1.7	2.6	2.4	2.9
	PrecMax	40.1	10.5	10.1	9.6	5.7	7.0	5.4	3.9	4.6	3.9	6.9	7.0	6.7
	PrecMin	14.3	0.5	0.0	0.0	0.0	0.2	0.2	0.0	0.0	0.0	0.2	0.1	0.4
	PrecStd	6.3	2.9	2.4	2.2	1.5	1.9	1.2	1.1	1.1	1.0	1.8	1.7	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.5	101.6	95.4	87.1	77.4	70.3	70.3	77.1	85.8	92.4	99.9	101.7
		MCWB	69.5	70.0	67.3	63.4	59.9	58.3	54.7	58.2	59.2	62.2	67.1	67.2
	2%	DB	99.1	96.1	90.3	81.9	73.8	66.0	66.1	71.9	80.7	87.1	93.8	96.1
		MCWB	69.2	69.0	66.6	62.7	58.4	55.7	52.9	54.9	58.2	61.6	65.2	66.2
	5%	DB	95.0	91.8	85.9	78.3	70.3	63.2	63.0	68.4	76.2	83.0	89.0	92.2
		MCWB	68.8	69.1	66.7	61.8	57.7	54.3	51.9	53.6	57.7	60.8	64.7	66.0
	10%	DB	90.8	87.5	82.0	75.0	67.2	60.8	60.2	64.7	72.0	78.8	84.1	88.2
		MCWB	68.3	68.5	66.4	61.3	56.6	53.5	51.3	52.2	56.2	60.5	63.8	66.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	75.5	73.1	68.4	65.0	60.8	59.1	61.1	63.9	68.1	71.8	73.2
		MCDB	88.0	90.3	82.2	75.8	70.0	66.5	63.8	72.8	76.0	80.6	87.9	86.0
	2%	WB	73.5	73.3	70.9	65.7	62.3	58.3	56.3	58.1	61.8	65.7	69.5	71.1
		MCDB	85.8	86.2	80.0	75.1	68.3	62.3	60.9	66.5	72.5	77.2	83.3	84.8
	5%	WB	72.2	71.8	69.5	64.0	60.2	56.7	54.4	55.8	60.1	64.0	67.9	69.7
		MCDB	84.9	83.4	78.3	73.1	66.5	60.6	59.6	64.1	70.2	75.7	80.5	82.7
	10%	WB	70.9	70.4	68.1	62.7	58.3	55.1	52.6	53.9	58.3	62.4	66.4	68.4
		MCDB	83.3	81.0	76.9	71.3	64.5	59.0	58.3	61.8	68.5	73.9	78.4	80.9
(35) Mean Daily Temperature Range	MDBR		24.8	23.3	22.7	24.4	23.5	20.2	22.3	25.4	26.5	26.7	25.2	25.4
	5% DB	MCDBR	33.1	31.3	29.9	30.2	28.3	24.4	27.5	32.1	34.2	35.2	34.1	33.6
		MCWBR	9.4	9.7	10.7	13.6	14.7	14.8	16.2	17.2	15.8	14.1	11.4	10.5
	5% WB	MCDBR	24.2	23.7	21.4	23.9	21.1	18.7	20.3	25.1	26.4	26.2	25.6	25.3
		MCWBR	8.5	8.8	9.1	11.7	11.8	12.3	13.4	15.0	14.2	12.8	10.1	9.7
(40) Clear-Sky Solar Irradiance	taub		0.374	0.371	0.344	0.319	0.300	0.294	0.290	0.297	0.329	0.348	0.375	0.368
	taud		2.472	2.500	2.562	2.602	2.600	2.624	2.611	2.577	2.480	2.457	2.431	2.475
	Ebn at Noon		306	301	298	290	280	275	281	293	298	305	304	309
	Edh at Noon		37	35	31	27	24	22	23	27	33	36	39	37
(44) All-Sky Solar Radiation	RadAvg		2194	1939	1629	1328	1045	825	955	1256	1653	1912	2050	2215
	RadStd		146	165	142	102	75	67	68	84	107	177	206	178

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.24	N/A	-2.12	+3.13	N/A	N/A	-38	-203	+430
(47) Regional (24 neighbors)		+0.83	N/A	N/A	N/A	N/A	N/A	-158	+302	+148

Nomenclature: See separate page