

SCONE, Australia

WMO: 957580

Lat: 32.0336S

Lon: 150.8264E

Elev: 222

StdP: 98.69

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.7	0.5	-5.1	2.5	16.5	-3.1	3.0	12.0	11.1	13.9	9.9	15.0	0.8	290	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	37.1	20.0	35.1	19.7	33.2	19.4	23.0	29.9	22.2	29.1	21.6	28.1	5.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.4	24.3	20.6	15.7	23.8	19.8	14.9	23.3	69.2	29.7	66.4	29.1	63.8	28.1	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.1	8.1	-2.9	40.2	0.6	2.4	-3.3	41.9	-3.7	43.3	-4.0	44.7	-4.4	46.4		
(5)			-3.2	24.4	0.7	0.8	-3.7	25.0	-4.1	25.4	-4.5	25.9	-4.9	26.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	24.1	23.3	21.0	17.1	13.3	10.7	9.8	11.0	14.2	17.3	20.3	22.6	(6)	(7)
	DBStd	5.77	3.33	3.14	2.81	2.64	2.57	2.36	2.29	2.72	2.95	3.29	3.71	3.25	(7)	(8)
	HDD10.0	73	0	0	0	0	3	19	32	18	1	0	0	0	(8)	(9)
	HDD18.3	1151	1	2	7	53	157	228	264	228	128	59	20	4	(9)	(10)
	CDD10.0	2638	436	373	340	213	104	42	26	50	128	226	309	390	(10)	(11)
	CDD18.3	673	179	141	88	16	1	0	0	1	6	27	79	136	(11)	(12)
	CDH23.3	7681	2019	1410	815	211	17	0	0	12	135	486	997	1579	(12)	(13)
	CDH26.7	3498	1059	673	304	44	1	0	0	1	30	166	450	771	(13)	(14)
(14) Wind	WSAvg	3.3	3.9	3.9	3.4	2.8	2.5	2.5	2.7	3.1	3.2	3.4	3.8	3.9	(14)	(15)
(15) Precipitation	PrecAvg	708	108	64	65	45	59	44	37	40	44	65	62	74	(15)	(16)
	PrecMax	1019	267	257	245	146	178	136	98	118	100	175	177	170	(16)	(17)
	PrecMin	364	13	1	0	1	5	5	0	1	0	4	2	9	(17)	(18)
	PrecStd	159	74	62	57	39	49	31	27	28	26	45	43	44	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.3	38.7	35.2	30.6	25.2	21.3	21.3	25.0	29.9	33.6	37.7	38.7	(19)	(20)
		MCWB	20.8	21.1	19.6	17.4	15.5	14.6	12.6	14.6	15.1	16.8	19.5	19.6	(20)	(21)
	2%	DB	37.3	35.6	32.4	27.7	23.2	18.9	18.9	22.2	27.0	30.6	34.3	35.6	(21)	(22)
		MCWB	20.6	20.5	19.2	17.0	14.7	13.2	11.6	12.7	14.6	16.5	18.5	19.0	(22)	(23)
	5%	DB	35.0	33.2	30.0	25.7	21.3	17.4	17.2	20.2	24.5	28.3	31.7	33.4	(23)	(24)
		MCWB	20.4	20.6	19.3	16.5	14.3	12.4	11.1	12.0	14.3	16.0	18.2	18.9	(24)	(25)
	10%	DB	32.7	30.8	27.8	23.9	19.6	16.0	15.7	18.2	22.2	26.0	28.9	31.2	(25)	(26)
		MCWB	20.2	20.3	19.1	16.3	13.7	11.9	10.7	11.2	13.4	15.8	17.7	18.9	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.2	22.8	20.2	18.3	16.0	15.1	16.2	17.7	20.0	22.1	22.9	(27)	(28)
		MCDB	31.1	32.4	27.9	24.3	21.1	19.2	17.6	22.6	24.4	27.0	31.0	30.0	(28)	(29)
	2%	WB	23.0	23.0	21.6	18.7	16.8	14.6	13.5	14.5	16.6	18.7	20.8	21.7	(29)	(30)
		MCDB	29.9	30.1	26.7	23.9	20.2	16.8	16.0	19.2	22.5	25.1	28.5	29.3	(30)	(31)
	5%	WB	22.3	22.1	20.8	17.8	15.7	13.7	12.4	13.2	15.6	17.8	19.9	20.9	(31)	(32)
		MCDB	29.4	28.6	25.7	22.8	19.1	15.9	15.3	17.8	21.2	24.3	27.0	28.2	(32)	(33)
	10%	WB	21.6	21.3	20.1	17.1	14.6	12.8	11.5	12.1	14.6	16.9	19.1	20.2	(33)	(34)
		MCDB	28.5	27.2	24.9	21.8	18.0	15.0	14.6	16.5	20.3	23.3	25.8	27.2	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	12.9	12.6	13.6	13.0	11.2	12.4	14.1	14.7	14.8	14.0	14.1	(35)	(36)
		MCDBR	18.4	17.4	16.6	16.8	15.7	13.6	15.3	17.8	19.0	19.6	18.9	18.7	(36)	(37)
	5% WB	MCWBR	5.2	5.4	6.0	7.6	8.2	8.2	9.0	9.5	8.8	7.9	6.3	5.8	(37)	(38)
		MCDWR	13.4	13.1	11.9	13.3	11.7	10.4	11.3	13.9	14.7	14.5	14.2	14.1	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.374	0.371	0.344	0.319	0.300	0.294	0.290	0.297	0.329	0.348	0.375	0.368	(39)	(40)
		taud	2.472	2.500	2.562	2.602	2.600	2.624	2.611	2.577	2.480	2.457	2.431	2.475	(40)	(41)
	Ebn at Noon		965	948	941	915	883	866	887	925	940	960	958	974	(41)	(42)
		Edn at Noon	118	111	98	84	75	69	73	84	104	114	122	118	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		6.92	6.11	5.13	4.19	3.29	2.60	3.01	3.96	5.21	6.03	6.46	6.98	(43)	(44)
	RadStd		0.46	0.52	0.45	0.32	0.24	0.21	0.21	0.26	0.34	0.56	0.65	0.56	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.69	N/A	-1.18	+1.74	N/A	N/A	-21	-113	+239	+145	(46)
(47)	Regional (24 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-88	+168	+82	(47)

Nomenclature: See separate page