

SYDNEY OLYMPIC PARK ARCHERY, Australia

WMO: 957650

Lat: 33.8339S

Lon: 151.0717E

Elev: 13

StdP: 14.69

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 41.0	(c) 42.9	(d) 26.0	(e) 20.0	(f) 64.7	(g) 29.0	(h) 23.0	(i) 61.3	(j) 22.8	(k) 59.7	(l) 19.1	(m) 61.0	(n) 2.9	(o) 300	(p) 0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 14.5	(c) 93.5	(d) 69.1	(e) 89.2	(f) 68.6	(g) 85.8	(h) 68.4	(i) 74.3	(j) 84.8	(k) 72.9	(l) 81.6	(m) 71.7	(n) 79.9	(o) 10.2	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	117.0	77.3	70.2	111.3	76.3	69.0	106.7	75.5	37.8	84.8	36.5	81.9	35.4	79.8	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.7	(b) 16.5	(c) 14.4	(e) 36.8	(f) 103.8	(g) 5.4	(h) 4.6	(i) 32.9	(j) 107.1	(k) 29.7	(l) 109.9	(m) 26.6	(n) 112.5	(o) 22.7	(p) 115.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	74.2	73.4	71.0	65.8	60.1	55.9	54.4	56.2	61.1	65.2	68.3	71.9		
	DBStd	8.26	5.13	4.63	4.24	4.59	3.81	3.23	3.21	3.98	5.09	5.70	5.76	5.32		
	HDD50	5	0	0	0	1	0	1	2	1	0	0	0	0		
	HDD65	1325	1	1	3	41	159	274	329	275	140	69	27	6		
	CDD50	5377	749	654	651	474	312	177	138	193	333	470	549	677		
	CDD65	1221	285	235	189	63	6	0	0	2	24	73	126	218		
	CDH74	7719	1916	1371	870	286	30	0	2	17	254	636	899	1438		
	CDH80	2573	712	411	211	59	1	0	0	0	68	225	351	535		
(14) Wind	WSAvg	6.0	6.8	6.7	6.0	4.9	4.9	5.2	5.4	6.1	6.3	6.4	6.8	6.8		
(15) Precipitation	PrecAvg	44.4	4.9	5.2	5.1	4.1	3.5	4.1	2.1	3.0	2.0	3.2	3.8	3.3		
	PrecMax	75.8	15.8	27.7	14.4	22.0	11.8	14.8	7.1	17.3	8.3	10.1	16.4	10.2		
	PrecMin	26.5	0.2	0.4	0.3	0.2	0.1	0.1	0.0	0.2	0.0	0.0	0.4	0.5		
	PrecStd	12.4	3.5	5.2	3.9	4.3	2.7	3.8	1.9	3.9	1.8	2.7	3.3	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.6	96.6	90.5	86.9	77.5	70.7	72.6	76.5	87.4	92.7	96.7	97.9		
		MCWB	72.0	70.2	69.1	65.9	60.8	57.3	56.9	56.2	61.5	62.3	67.3	69.2		
	2%	DB	92.0	88.9	85.1	80.3	73.8	67.5	67.7	71.8	81.0	86.2	89.0	90.6		
		MCWB	71.7	71.1	69.6	64.9	60.2	56.2	53.9	55.2	58.8	62.6	66.3	69.0		
	5%	DB	87.3	84.5	81.6	76.9	70.7	65.3	64.7	68.5	76.0	81.0	83.2	85.9		
		MCWB	71.3	70.5	68.7	64.0	59.0	55.4	53.0	54.3	58.1	62.4	66.1	68.1		
	10%	DB	83.4	81.2	78.6	74.0	68.2	63.3	62.4	65.5	71.9	76.3	78.5	81.6		
		MCWB	69.9	69.4	67.4	63.2	58.1	54.4	52.0	53.0	57.5	61.5	65.1	67.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.7	76.0	74.2	70.6	65.7	61.6	61.3	60.6	64.5	69.0	72.8	75.0		
		MCDB	91.0	87.9	82.4	79.9	69.4	65.9	66.7	69.4	76.1	79.8	86.1	88.3		
	2%	WB	74.6	73.7	72.1	68.1	63.7	59.3	57.6	58.5	62.6	66.8	70.0	72.4		
		MCDB	85.9	81.9	79.7	74.1	68.9	63.5	62.8	65.4	72.4	77.0	80.8	83.1		
	5%	WB	73.0	72.4	70.7	66.5	61.7	58.0	55.7	56.7	61.1	65.0	68.4	70.8		
		MCDB	81.7	80.0	77.5	72.8	67.7	62.4	60.7	64.1	70.9	74.7	78.0	79.9		
	10%	WB	71.6	71.1	69.4	65.1	60.0	56.6	54.0	55.1	59.6	63.5	66.7	69.3		
		MCDB	79.7	78.3	75.8	71.4	66.0	61.1	59.8	62.8	68.6	72.5	75.0	77.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	13.5	13.8	15.4	16.6	15.4	17.2	18.4	18.8	17.7	15.5	15.4		
		MCDBR	23.6	20.5	19.3	20.2	20.4	18.4	21.5	23.5	26.9	27.5	26.3	24.6		
		MCWBR	8.0	6.6	7.2	8.0	9.3	9.6	10.9	10.8	10.0	9.8	9.0	8.0		
		MCDBR	19.2	16.1	16.3	16.8	16.8	14.5	17.3	19.3	21.6	21.7	20.5	19.7		
	5% WB	MCWBR	7.3	6.6	6.9	7.7	8.9	9.0	10.3	10.4	9.8	9.6	8.3	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.397	0.397	0.363	0.335	0.320	0.312	0.302	0.310	0.344	0.363	0.387	0.398		
	taud		2.449	2.467	2.550	2.602	2.591	2.612	2.622	2.590	2.494	2.470	2.442	2.424		
	Ebn at Noon		298	292	291	282	270	264	274	287	292	299	299	299		
	Edh at Noon		38	36	31	26	23	22	23	26	32	36	38	39		
(44) All-Sky Solar Radiation	RadAvg		2052	1766	1504	1214	956	755	886	1171	1558	1808	1928	2102		
	RadStd		151	155	131	102	66	69	69	65	87	156	174	174		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	-1.93	N/A	N/A	+1.82	+2.03	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-4	-153	+331	+176

Nomenclature: See separate page