

SYDNEY OLYMPIC PARK ARCHERY, Australia

WMO: 957650

Lat: 33.8339S

Lon: 151.0717E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 5.0	(c) 6.1	(d) -3.3	(e) 2.9	(f) 18.2	(g) -1.7	(h) 3.3	(i) 16.3	(j) 10.2	(k) 15.4	(l) 8.5	(m) 16.1	(n) 1.3	(o) 300	(p) 0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 8.1	(c) 34.1	(d) 20.6	(e) 31.8	(f) 20.3	(g) 29.9	(h) 20.2	(i) 23.5	(j) 29.4	(k) 22.7	(l) 27.6	(m) 22.0	(n) 26.6	(o) 4.6	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 22.0	(b) 16.7	(c) 25.2	(d) 21.2	(e) 15.9	(f) 24.6	(g) 20.6	(h) 15.2	(i) 24.2	(j) 70.0	(k) 29.3	(l) 67.1	(m) 27.7	(n) 64.5	(o) 26.5	(p) 28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.8	(b) 7.4	(c) 6.4	(e) 2.7	(f) 39.9	(g) 3.0	(h) 2.6	(i) 0.5	(j) 41.7	(k) -1.3	(l) 43.3	(m) -3.0	(n) 44.7	(o) -5.2	(p) 46.6		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			2.7	39.9	3.0	2.6	0.5	41.7	-1.3	43.3	-3.0	44.7	-5.2	46.6		
			1.5	24.8	2.8	1.2	-0.5	25.6	-2.1	26.3	-3.7	27.0	-5.7	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	23.4	23.0	21.7	18.8	15.6	13.3	12.4	13.4	16.2	18.4	20.2	22.1
	DBStd	4.59	2.85	2.57	2.35	2.55	2.12	1.80	1.78	2.21	2.83	3.17	3.20	2.96
	HDD10.0	3	0	0	0	1	0	1	1	1	0	0	0	0
	HDD18.3	736	1	1	2	23	88	152	183	153	78	38	15	3
	CDD10.0	2987	416	363	362	263	173	98	77	107	185	261	305	376
	CDD18.3	678	158	131	105	35	3	0	0	1	13	41	70	121
	CDH23.3	4288	1064	762	483	159	17	0	1	9	141	353	499	799
CDH26.7	1429	396	228	117	33	1	0	0	0	38	125	195	297	
Wind	WSAvg	2.7	3.1	3.0	2.7	2.2	2.2	2.3	2.4	2.7	2.8	2.9	3.0	3.0
Precipitation	PrecAvg	1129	124	131	129	103	89	104	53	77	52	81	97	83
	PrecMax	1926	401	703	365	558	299	375	181	439	211	256	417	258
	PrecMin	672	5	11	8	5	2	2	0	6	0	0	9	13
	PrecStd	316	88	131	98	110	69	96	49	98	46	69	85	62
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.1	35.9	32.5	30.5	25.3	21.5	22.5	24.7	30.8	33.7	36.0	36.6
		MCWB	22.2	21.2	20.6	18.8	16.0	14.1	13.8	13.4	16.4	16.8	19.6	20.6
	2%	DB	33.3	31.6	29.5	26.9	23.2	19.7	19.8	22.1	27.2	30.1	31.7	32.6
		MCWB	22.1	21.7	20.9	18.3	15.6	13.5	12.2	12.9	14.9	17.0	19.0	20.5
	5%	DB	30.7	29.2	27.6	24.9	21.5	18.5	18.2	20.3	24.5	27.2	28.4	29.9
		MCWB	21.8	21.4	20.4	17.8	15.0	13.0	11.7	12.4	14.5	16.9	18.9	20.0
	10%	DB	28.6	27.3	25.9	23.3	20.1	17.4	16.9	18.6	22.2	24.6	25.9	27.5
		MCWB	21.1	20.8	19.7	17.4	14.5	12.5	11.1	11.7	14.1	16.4	18.4	19.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.8	24.5	23.5	21.5	18.7	16.4	16.3	15.9	18.1	20.6	22.7	23.9
		MCDB	32.8	31.1	28.0	26.6	20.8	18.8	19.3	20.8	24.5	26.5	30.1	31.3
	2%	WB	23.7	23.1	22.3	20.1	17.6	15.2	14.2	14.7	17.0	19.3	21.1	22.5
		MCDB	30.0	27.7	26.5	23.4	20.5	17.5	17.1	18.6	22.4	25.0	27.1	28.4
	5%	WB	22.8	22.5	21.5	19.2	16.5	14.5	13.1	13.7	16.1	18.3	20.2	21.6
		MCDB	27.6	26.6	25.3	22.7	19.8	16.9	15.9	17.9	21.6	23.7	25.5	26.6
	10%	WB	22.0	21.7	20.8	18.4	15.6	13.7	12.2	12.8	15.3	17.5	19.3	20.7
		MCDB	26.5	25.7	24.3	21.9	18.9	16.2	15.5	17.1	20.4	22.5	23.9	25.5
Mean Daily Temperature Range	5% DB	MDBR	8.1	7.5	7.7	8.5	9.2	8.5	9.6	10.2	10.4	9.8	8.6	8.5
		MCDBR	13.1	11.4	10.7	11.2	11.4	10.2	11.9	13.0	14.9	15.3	14.6	13.7
		MCWBR	4.4	3.7	4.0	4.4	5.2	5.3	6.0	6.0	5.5	5.5	5.0	4.4
	5% WB	MCDBR	10.6	9.0	9.1	9.3	9.3	8.1	9.6	10.7	12.0	12.1	11.4	11.0
		MCWBR	4.1	3.7	3.8	4.3	4.9	5.0	5.7	5.8	5.5	5.3	4.6	4.4
Clear-Sky Solar Irradiance	taub		0.397	0.397	0.363	0.335	0.320	0.312	0.302	0.310	0.344	0.363	0.387	0.398
	taud		2.449	2.467	2.550	2.602	2.591	2.612	2.622	2.590	2.494	2.470	2.442	2.424
	Ebn at Noon		941	920	917	890	850	833	864	904	921	943	944	944
	Edh at Noon		120	114	98	83	74	68	71	82	101	112	120	124
All-Sky Solar Radiation	RadAvg		6.47	5.57	4.74	3.83	3.01	2.38	2.79	3.69	4.91	5.70	6.08	6.62
	RadStd		0.47	0.49	0.41	0.32	0.21	0.22	0.22	0.21	0.27	0.49	0.55	0.55

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	-1.07	N/A	N/A	+1.01	+1.13	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	-2	-85	+184	+98

Nomenclature: See separate page