

ARMIDALE, Australia

WMO: 957730

Lat: 30.5272S

Lon: 151.6158E

Elev: 3542

StdP: 12.91

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 29.4	(c) 31.6	(d) 18.8	(e) 16.1	(f) 48.8	(g) 22.1	(h) 18.9	(i) 46.7	(j) 28.7	(k) 50.0	(l) 25.9	(m) 46.9	(n) 7.0	(o) 270	(p) 0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.1	86.2	63.6	83.3	63.1	80.3	62.3	68.4	77.8	66.9	76.2	65.5	74.4	12.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	109.2	71.2	64.2	102.7	69.4	62.9	97.8	68.5	34.9	77.7	33.5	76.2	32.4	74.6	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 24.8	(b) 21.7	(c) 19.2	(e) 24.6	(f) 91.1	(g) 1.7	(h) 3.6	(i) 23.4	(j) 93.8	(k) 22.5	(l) 95.9	(m) 21.5	(n) 97.9	(o) 20.3	(p) 100.5		
			DB													
			WB													
				23.5	70.6	2.1	2.1	22.0	72.1	20.8	73.3	19.6	74.5	18.1	76.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.0	67.2	66.1	62.7	56.7	49.8	45.5	44.1	46.0	52.0	57.0	61.2	64.9
	DBStd	9.49	5.24	4.98	4.23	4.31	4.29	4.25	4.17	4.71	5.52	5.78	6.05	5.41
	HDD50	587	0	0	0	5	56	145	189	141	39	10	2	0
	HDD65	3575	36	40	97	249	471	586	648	589	391	255	145	68
	CDD50	2788	534	452	393	206	50	8	6	17	99	225	336	462
	CDD65	303	105	72	25	0	0	0	0	0	1	5	30	65
	CDH74	2761	928	608	175	11	0	0	0	1	11	80	335	612
	CDH80	686	269	169	18	0	0	0	0	0	0	9	78	143
Wind	WSAvg	10.1	10.8	10.6	10.0	9.2	9.0	9.7	10.0	10.4	10.6	10.3	10.4	10.5
Precipitation	PrecAvg	30.1	4.6	3.0	2.4	1.9	2.1	1.5	1.8	1.7	1.8	2.6	3.2	3.5
	PrecMax	36.8	8.5	6.6	7.8	6.6	7.8	4.4	4.3	4.3	5.4	6.2	7.3	8.0
	PrecMin	18.1	0.5	0.2	0.1	0.1	0.3	0.1	0.0	0.0	0.2	0.9	0.4	1.0
	PrecStd	5.4	2.4	1.9	1.9	1.7	1.8	0.9	1.2	1.1	1.1	1.2	1.7	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.3	89.9	82.4	75.5	68.0	61.6	61.4	67.1	75.7	80.4	86.6	88.0
		MCWB	65.4	64.4	62.2	57.6	53.9	50.5	50.6	51.5	55.6	56.7	62.7	63.0
	2%	DB	86.1	85.0	78.4	71.9	64.5	58.2	57.9	62.5	71.0	75.9	81.8	84.0
		MCWB	64.1	64.3	61.7	56.7	52.2	49.8	48.7	48.9	53.3	56.6	60.5	62.4
	5%	DB	83.0	81.0	75.4	69.2	61.8	56.1	55.4	59.3	67.1	72.9	77.7	80.7
		MCWB	63.8	64.1	61.4	56.1	50.8	48.7	47.0	46.9	52.1	56.1	59.3	61.7
	10%	DB	79.4	77.4	72.8	66.5	59.2	53.7	53.0	56.4	63.8	69.6	73.6	77.3
		MCWB	63.1	63.3	60.9	55.4	50.1	48.0	45.7	46.1	50.8	55.2	58.8	61.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	71.1	68.7	62.4	58.1	54.7	56.1	55.2	58.5	63.1	66.3	68.3
		MCDB	79.5	81.5	73.4	68.0	63.0	57.5	58.2	63.4	70.1	71.2	79.6	79.0
	2%	WB	68.4	68.4	65.5	60.1	55.0	52.4	51.7	51.6	56.2	60.6	64.0	66.4
		MCDB	78.1	77.7	72.3	66.3	59.8	55.4	54.9	57.5	65.4	69.2	75.3	77.4
	5%	WB	66.9	66.7	63.9	58.5	53.2	50.8	49.0	49.6	54.6	58.7	62.4	64.8
		MCDB	76.2	75.5	70.7	65.2	58.5	53.9	52.6	55.8	63.1	67.7	72.3	74.3
	10%	WB	65.5	65.1	62.6	56.9	51.7	49.1	47.0	47.7	52.7	57.0	60.9	63.4
		MCDB	74.2	73.1	69.1	63.8	56.9	52.4	51.1	54.1	60.8	65.7	69.5	72.1
Mean Daily Temperature Range	5% DB	MDBR	20.1	18.8	18.2	18.5	18.4	15.6	16.8	19.3	20.5	20.7	20.0	20.3
		MCDBR	26.2	25.0	22.7	22.6	22.0	19.1	20.4	23.0	24.6	25.3	26.2	26.0
		MCWBR	9.0	9.2	9.4	9.8	11.2	11.3	11.8	12.5	12.1	11.2	10.6	9.9
	5% WB	MCDBR	20.2	19.6	18.0	18.1	17.0	14.0	14.9	17.8	19.6	20.8	20.8	20.4
		MCWBR	8.8	8.7	9.3	9.4	9.8	9.6	10.3	11.1	11.0	11.1	9.9	9.8
Clear-Sky Solar Irradiance	taub	0.327	0.320	0.299	0.284	0.265	0.260	0.256	0.271	0.298	0.318	0.333	0.330	
	taud	2.573	2.618	2.682	2.683	2.694	2.704	2.697	2.613	2.525	2.498	2.507	2.545	
	Ebn at Noon	321	318	315	305	297	292	298	305	310	315	318	321	
	Edh at Noon	34	31	28	25	22	20	22	26	32	35	36	35	
All-Sky Solar Radiation	RadAvg	2181	1960	1665	1389	1105	899	1019	1319	1707	1953	2057	2184	
	RadStd	150	174	129	86	75	71	78	104	133	174	211	193	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	N/A	-119	+284	+155

Nomenclature: See separate page